

Inflow Design Flood Control System Plan

**Texas Municipal Power Agency
Gibbons Creek Steam Electric Station**

Grimes County, Texas

October 12, 2016

www.erm.com

Texas Municipal Power Agency

Inflow Design Flood Control
System Plan: *Gibbons Creek
Steam Electric Station*

October 12, 2016

Project No. 0336706
Grimes County Texas



Jim Davidson
Partner-in-Charge



E. Doyon Main, P.E.
Project Engineer



Charles O. Johnson
Project Manager

Environmental Resources Management

206 East 9th Street, Suite 1700

Austin, Texas 78701

T: 512-459-4700

F: 512-597-8368

TABLE OF CONTENTS

1.0	PURPOSE AND OBJECTIVES	1
2.0	ASH POND INFLOW DESIGN FLOOD CONTROL SYSTEM PLAN	2
2.1	ASH PONDS UNIT DESCRIPTION	2
2.2	ASH PONDS PROCESS FLOW RATES	3
2.3	ASH PONDS HAZARD POTENTIAL CLASSIFICATION	3
2.4	ASH PONDS DESIGN STORM PRECIPITATION	4
2.5	ASH PONDS STORMWATER RUNOFF COEFFICIENT ANALYSIS	4
2.6	ASH PONDS STAGE-STORAGE ANALYSIS	4
2.7	ASH PONDS DESIGN STORM ROUTING ANALYSIS	5
2.8	ASH PONDS INFLOW DESIGN FLOOD CONTROL ANALYSIS	5
3.0	SCRUBBER SLUDGE POND INFLOW DESIGN FLOOD CONTROL SYSTEM PLAN	6
3.1	SCRUBBER SLUDGE POND UNIT DESCRIPTION	6
3.2	SCRUBBER SLUDGE POND PROCESS FLOW RATES	7
3.3	SCRUBBER SLUDGE POND HAZARD POTENTIAL CLASSIFICATION	7
3.4	SCRUBBER SLUDGE POND DESIGN STORM PRECIPITATION	7
3.5	SCRUBBER SLUDGE POND STORMWATER RUNOFF COEFFICIENT ANALYSIS	7
3.6	SCRUBBER SLUDGE POND STAGE-STORAGE ANALYSIS	8
3.7	SCRUBBER SLUDGE POND DESIGN STORM ROUTING ANALYSIS	8
3.8	SCRUBBER SLUDGE POND INFLOW DESIGN FLOOD CONTROL ANALYSIS	9
4.0	PROFESSIONAL ENGINEER'S CERTIFICATION	10
5.0	REFERENCES	11
5.1	TMPA DOCUMENTS	11
5.2	PUBLIC SOURCE DOCUMENTS	12

APPENDICES

- A *DESIGN FLOOD INFLOW CAPACITY CALCULATIONS*
- B *REFERENCE DOCUMENTS*

List of Tables

- 1 *Ash Pond Process Flow Rates*
- 2 *100-Year Design Precipitation*
- 3 *Ash Ponds Stage-Composite Runoff Coefficient*
- 4 *Ash Ponds Stage Storage Data*
- 5 *Ash Pond Design Flood Inflow Rates, 100-Year Storm*
- 6 *Scrubber Sludge Pond Process Flow Rates*
- 7 *Scrubber Sludge Pond Stage- Composite Runoff Coefficient*
- 8 *Scrubber Sludge Pond Stage-Storage Data*
- 9 *Scrubber Sludge Pond Design Flood Inflow Rates, 100-Year Storm*

List of Figures

- 1 *Site Base Map*
- 2 *Ash Ponds Stage - Composite Runoff Coefficient Curve*
- 3 *Ash Ponds Stage - Storage Curve*
- 4 *Ash Ponds 100-Year Design Storm Duration - Total NDW Freeboard Curve*
- 5 *SSP Stage - Composite Runoff Coefficient Curve*
- 6 *SSP Stage - Storage Curve*
- 7 *SSP 100-Year Design Storm Duration - Total NDW Freeboard Curve*

PURPOSE AND OBJECTIVES

Texas Municipal Power Agency (TMPA) owns and operates the Gibbons Creek Steam Electric Station (GCSES). The GCSES is located in unincorporated Grimes County, Texas. The GCSES generates coal combustion residuals (CCR) that are subject to regulation under Title 40, Code of Federal Regulations, Part 257 (40 CFR Part 257)(the CCR Rule). TMPA operates two CCR surface impoundments at the GCSES:

- (1) the Ash Ponds (APs); and
- (2) the Scrubber Sludge Pond (SSP).

The CCR Rule requires that each CCR surface impoundment control storm water runoff from a design storm event. The return frequency of the design storm event depends on the hazard classification of the CCR surface impoundment.

The CCR Rule requires that TMPA prepare the initial Inflow Design Flood (IDF) Control System Plan for each CCR surface impoundment no later than October 17, 2016 in accordance with 40 CFR 257.82(c)(3)(i). The CCR Rule requires that TMPA review and update the IDF Control System Plan for each surface impoundment at five year intervals following completion of the initial IDF Control System Plan in accordance with 40 CFR 257.82(c)(4).

The CCR Rule requires each owner and operator of a CCR Surface Impoundment to "...construct, operate, and maintain an inflow design flood control system...". The IDF control system must adequately manage flow into and out of the CCR unit resulting from the IDF required for the corresponding CCR surface impoundment hazard potential classification designated in 40 CFR Part 257.82(a)(3) and as determined in accordance with 40 CFR Part 257.73(a)(2).

This document includes the initial IDF Control System Plan for the APs and for the SSP at the TMPA GCSES.

2.0

ASH POND INFLOW DESIGN FLOOD CONTROL SYSTEM PLAN

This section is the initial IDF Control System Plan for the APs, including:

- unit description;
- process flow rates;
- hazard potential classification;
- design storm precipitation;
- storm water runoff coefficient analysis;
- stage-storage analysis;
- design storm routing analysis; and
- IDF control analysis.

2.1

ASH PONDS UNIT DESCRIPTION

The APs are three connected CCR surface impoundments constructed by TMPA in 1979 as part of the original GCSES plant construction. The APs are located on the GCSES site generally southeast of the GCSES electric power generation plant and west of Gibbons Creek Reservoir; see Figure 1.

As shown on TMPA Drawing No. 15-C-235, dated January 16, 1979, the APs are three adjoining ponds separated by earthen dikes and hydraulic gates. Each of the three APs is shown to be approximately 1820 feet long and 250 feet wide at the dike crest interior top of bank. Each of the APs is shown to have a common dike crest elevation. Each of the APs is shown to be approximately 20 feet deep from the dike crest to the pond bottom. Based on those dimensions, the total area inside the three APs is approximately 29.9 acres. The total area drained to the APs, including the interior and the dike crest areas, is approximately 34.8 acres.

The APs receive and store bottom ash transport water overflow from hydrobins used to dewater the bottom ash CCR produced by the GCSES. The bottom ash transport water overflow contains CCR. Roughly the same flow rate and volume of water is pumped from the APs to the plant ash transport water system as the plant ash transport water system returns to the APs.

TMPA records show that the APs received CCR prior to, on, and subsequent to October 14, 2015. Consequently, in accordance with 40 CFR 257.53, the APs are classified as “existing” CCR surface impoundments.

TMPA records indicate that the elevation of the crest of parts of the APs eastern and northern dikes are above the elevation of the adjoining exterior ground surface. Consequently, in accordance with 40 CFR 257.53, the APs are not classified as an “incised” CCR surface impoundment.

The APs are listed as active solid waste management unit (SWMU), SWMU 006, on the Notice of Registration (NOR) for Solid Waste Registration (SWR) No. 32271 issued to TMPA by the Texas Commission on Environmental Quality (TCEQ) on July 25, 2003.

2.2 *ASH PONDS PROCESS FLOW RATES*

The TMPA water balance shows that the APs can receive process flows from the following inlet process streams:

- Plant Collection Pond
- Plant Floor (Power Island) Drainage
- Ultrafiltration System Blowdown
- Reverse Osmosis Wastewater
- Make-Up Demineralizer Wastewater
- Treated Sewage Wastewater
- Scrubber Sludge Pond
- Boiler Blowdown
- Metal Cleaning
- SAL/SFL Stormwater/Leachate
- Dewatering Bins Overflow
- Service Water System Overflow

The TMPA water balance shows that the APs can discharge process flows via the following process streams:

- Ash Pond Discharge to Outfall 001; and
- Ash Pond water to bottom transport system.

A summary of APs process flows and flow rates used for the IDF control analysis is shown in Table 1.

2.3 *ASH PONDS HAZARD POTENTIAL CLASSIFICATION*

CCR surface impoundment hazard potential is required to be classified in accordance with 40 CFR 257.53. Hazard potential classification of the APs is based on TMPA assessment of the potential for loss of life, economic loss, environmental damage, disruption of lifeline facilities, or impact other concerns in accordance with 40 CFR 257.73(a)(2) and 257.73(f). TMPA will document hazard potential classification of the APs in a separate report.

For the purpose of this IDF Control System Plan analysis, it is assumed that TMPA will classify the APs as “Low” hazard potential.

2.4 *ASH PONDS DESIGN STORM PRECIPITATION*

Design storm precipitation data for a range of 100-year storm durations were obtained from Technical Paper No. 40 and Technical Paper No. 49 published by the U.S. Weather Bureau. A summary of the precipitation data is shown in Table 2.

2.5 *ASH PONDS STORMWATER RUNOFF COEFFICIENT ANALYSIS*

The volume of stormwater drained to the APs Pond during the design storm was calculated using the rational formula:

$$Q = C \times Pt \times A$$

Where:

Q = flow rate, cubic feet per second

C = stormwater runoff coefficient

Pt = precipitation for the corresponding design storm duration

A = drainage area

While the total drainage area is constant for any water stage in the APs, the part of the total area that is subject to direct precipitation (i.e. the pond water surface) and the area of exposed dike crest and side slopes vary with pond stage. As a result, the value of the area-weighted value of the stormwater runoff coefficient (the composite value of C, or Cc) varies with APs water stage.

TMPA data used and the results of calculations of the value of the composite stormwater runoff coefficient are shown in Table 3. The values of the composite storm water runoff coefficient as a function of normal dry weather (NDW) freeboard are shown on Figure 2. A utility in Microsoft "Excel" was used to calculate a second-order polynomial formula, as a best fit approximation of that relationship for use in the APs design storm water routing described below.

2.6 *ASH PONDS STAGE-STORAGE ANALYSIS*

The APs were not constructed with an emergency spillway to control overflow from the APs at a stage above the minimum 6-inch freeboard below the perimeter dike crest. Therefore, in order to prevent uncontrolled flow over the AP perimeter dikes, the volume of water contained in the APs above the NDW freeboard needs to be equal or less than the maximum volume of process water and stormwater received, less the volume of process water pumped from the SSP to the APs, and less a top surface freeboard of at least six inches when filled by water accumulated during the design storm.

TMPA data used to model the variation of the capacity above a range of NDW water surface and below the 6-inch minimum freeboard are shown in Table 4. The APs dike crest was assumed to be a single and constant overflow elevation. A reserve 6-inch minimum freeboard was assumed to account for uncertainty in dike crest elevation and wave action.

A plot of the stage-storage relationship is shown in Figure 3. A utility in Microsoft "Excel" was used to calculate a second-order polynomial formula, also shown on Figure 3, as a best fit approximation of that relationship for use in the design storm water routing described below.

2.7

ASH PONDS DESIGN STORM ROUTING ANALYSIS

The process and stormwater runoff flow volumes of each inflow and outflow stream were calculated for a range of design storm durations assuming a NDW freeboard level at the beginning of the storm. Those results were used to calculate the total volume of the stormwater to be contained in the APs for the corresponding duration. The volume of water contained above the NDW freeboard and the minimum 6-inch freeboard was calculated using the relationship obtained in the stage-storage relationship. The trial APs NDW freeboard level was adjusted until the net volume of process water and stormwater equaled the volume of water contained between the NDW freeboard and the 6-inch minimum freeboard for the corresponding design storm duration.

A summary of the APs 100-year design storm routing data and calculations are shown in Table 5. A plot of the NDW freeboard is shown on Figure 4. The maximum APs NDW freeboard required below the dike crest to contain the net process and 100-year design storm streams with no CCR solids in the storage space that would otherwise displace accumulated water is 2.0 feet. A summary of values used in the AP design storm routing analysis is presented in Appendix A, Table A-1.

2.8

ASH PONDS INFLOW DESIGN FLOOD CONTROL ANALYSIS

Based on TMPA data and published precipitation data, the APs can contain inflow from process streams and stormwater runoff from the 100-Year design storm with a 6-inch freeboard below the dike crest if the NDW water surface and the top surface of CCR solids in the APs are maintained at or below a level 2.0 feet below the APs dike crest.

3.0 SCRUBBER SLUDGE POND INFLOW DESIGN FLOOD CONTROL SYSTEM PLAN

This section is the initial IDF Control System Plan for the SSP, including:

- unit description;
- process flow rates;
- hazard potential classification;
- design storm precipitation;
- storm water runoff coefficient analysis;
- stage-storage analysis;
- design storm routing analysis; and
- IDF control analysis.

3.1 SCRUBBER SLUDGE POND UNIT DESCRIPTION

The SSP is a CCR surface impoundment constructed by TMPA in 1978 as part of the original GCSES plant construction. The SSP is located on the GCSES site generally south of the GCSES plant and west of the APs; see Figure 1.

The northern part of the SSP eastern dike adjoins the APs. The southern part of the SSP eastern dike adjoins undeveloped land. The SSP northern dike adjoins the coal pile storage area. The SSP southern dike adjoins a plant site drainage channel. The SSP western dike adjoins the plant collection pond and undeveloped land.

As shown on TMPA Drawing No. 11-C-019.1 dated April 16, 1987 the SSP is approximately 20 feet deep from the crest of the dike to the bottom. Based on the dimensions shown on the TMPA drawing, the total area inside the SSP is approximately 7.3 acres. The total area drained to the SSP, including the interior and the dike crest areas, is approximately 7.9 acres.

TMPA records show that the SSP received CCR prior to, on, and subsequent to October 14, 2015. Consequently, in accordance with 40 CFR 257.53, the SSP is classified as an “existing” CCR surface impoundment.

The elevation of the crest of parts of the SSP southern dike is above the elevation of the adjoining exterior ground surface. Consequently, in accordance with 40 CFR 257.53, the SSP is not classified as an “incised” CCR surface impoundment.

The SSP is listed as an active Solid Waste Management Unit, SWMU 004, on the NOR for SWR No. 32271 issued to TMPA by the TCEQ dated July 25, 2003.

3.2 SCRUBBER SLUDGE POND PROCESS FLOW RATES

The TMPA water balance shows that the SSP receives process flow from the Scrubber Purge Treatment system, and that water is pumped from the SSP to the APs as determined necessary by TMPA. A summary of SSP process flow sources and flow rates used for the IDF control analysis is shown in Table 6.

3.3 SCRUBBER SLUDGE POND HAZARD POTENTIAL CLASSIFICATION

CCR surface impoundment hazard potential is classified in 40 CFR 257.53. Hazard potential classification of the SSP is based on TMPA assessment of the potential for loss of life, economic loss, environmental damage, disruption of lifeline facilities, or impact of other concerns in accordance with 40 CFR 257.73(a)(2) and 257.73(f). TMPA will document hazard potential classification of the SSP in a separate report.

For the purpose of this IDF Control System Plan analysis, it is assumed that TMPA will classify the SSP as "Low" hazard potential.

3.4 SCRUBBER SLUDGE POND DESIGN STORM PRECIPITATION

Design storm precipitation data for a range of 100-year storm durations were obtained from Technical Paper No. 40 and Technical Paper No. 49 published by the U.S. Weather Bureau. A summary of the precipitation data is shown in Table 2.

3.5 SCRUBBER SLUDGE POND STORMWATER RUNOFF COEFFICIENT ANALYSIS

The volume of stormwater drained to the SSP during the design storm was calculated using the rational formula:

$$Q = C \times Pt \times A$$

Where:

Q = flow rate, cubic feet per second

C = stormwater runoff coefficient

Pt = precipitation for the corresponding design storm duration

A = drainage area

While the total drainage area is constant for any water stage in the SSP, the part of the total area that is subject to direct precipitation (i.e. the pond water surface) and the area of exposed dike crest and side slopes vary with pond stage. As a result, the value of the area-weighted value of the stormwater runoff coefficient (the composite value of C, or Cc) varies with the SSP water stage.

TMPA data used and the results of calculations of the value of the composite stormwater runoff coefficient are shown in Table 7. The values of the composite storm water runoff coefficient as a function of NDW freeboard are shown on Figure 5. A utility in Microsoft “Excel” was used to calculate a third-order polynomial formula, also shown on Figure 5, as a best fit approximation of that relationship for use in the SSP design storm water routing described below.

3.6

SCRUBBER SLUDGE POND STAGE-STORAGE ANALYSIS

The SSP was not constructed with an emergency spillway to control overflow of the SSP at a stage above the minimum 6-inch freeboard below the dike crest. Therefore, in order to prevent uncontrolled flow over the SSP dike crest, the volume of water contained in the SSP above the NDW freeboard needs to be equal or less than the maximum volume of process water and stormwater received, plus the volume of process water pumped from the SSP to the APs, and less a top surface freeboard of at least six inches when filled by water accumulated during the design storm.

TMPA data used to model the variation of the capacity above a range of NDW water surface and below the 6-inch minimum freeboard are shown in Table 8. The SSP dike crest was assumed to be a single and constant overflow elevation. A reserve 6-inch minimum freeboard was assumed to account for uncertainty in dike crest elevation and wave action.

A plot of the stage-storage relationship is shown in Figure 6. A utility in Microsoft “Excel” was used to calculate a third-order polynomial formula, also shown on Figure 6, as a best fit approximation of that relationship for use in the SSP design storm water routing described below.

3.7

SCRUBBER SLUDGE POND DESIGN STORM ROUTING ANALYSIS

The volume of each SSP process and stormwater inflow and process outflow stream was calculated for a range of design storm durations assuming a trial NDW freeboard level at the beginning of the storm. Those results were used to calculate the total volume of the stormwater to be contained in the SSP for the corresponding duration.

The volume of water contained above the NDW freeboard and the minimum 6-inch freeboard was calculated using the relationship obtained in the stage-storage relationship. The trial SSP NDW freeboard level was adjusted until the net volume of process water and stormwater equaled the volume of water contained between the NDW freeboard and the 6-inch minimum freeboard for the corresponding design storm duration.

A summary of the SSP 100-year design storm routing data and calculations are shown in Table 9. A plot of the NDW freeboard is shown on Figure 7. The maximum SSP NDW freeboard required below the dike crest to contain the net process and 100-year design storm streams with no CCR solids in the storage space that would otherwise displace accumulated water is 1.6 feet. A summary

of values used in the SSP design storm routing analysis is presented in Appendix A, Table A-2.

3.8 **SCRUBBER SLUDGE POND INFLOW DESIGN FLOOD CONTROL ANALYSIS**

Based on TMPA data and published precipitation data, the SSP can contain the net inflow from process streams and stormwater runoff from the 100-Year design storm with a 6-inch freeboard below the dike crest if the NDW water surface and the top surface of CCR solids in the SSP are maintained at or below a level 1.6 feet below the SSP dike crest.

4.0

PROFESSIONAL ENGINEER'S CERTIFICATION

In accordance with 40 CFR §257.82(c)(5), TMPA obtained the following certification by a qualified professional engineer that the Inflow Design Flood Control System Plan meets the requirements of 40 CFR §257.82. That certification is provided below.

I hereby certify that I have reviewed the hydrologic and hydraulic capacity and inflow design flood control systems for the Ash Ponds and Scrubber Sludge Pond CCR surface impoundments at the TMPA Gibbons Creek Steam Electric Station located in Grimes County, Texas, and attest that the Inflow Design Flood Control System Plan for each of those CCR surface impoundments meets the requirements of 40 CFR Part 257.82.

Seal:



E. Doyon Main, P.E.

Printed Name of Licensed Professional Engineer

A handwritten signature in blue ink, appearing to read "E. Doyon Main", written over a horizontal line.

Signature of Licensed Professional Engineer

Date: 10/12/2010

5.0

REFERENCES

Information used for this IDF Control System Plan for the APs and SSP are from TMPA and public sources as listed below and included in Appendix B.

5.1

TMPA DOCUMENTS

The following TMPA documents were used as sources of information used for this IDF Control System Plan for the APs and SSP.

B&V 1987	Ash Pond Study, Black and Veatch, Project No. 13957, File No. 13957.40.1000, October 5, 1987.
CDS/Muery 2003	Aerial Survey, CDS/Muery Services, Inc. September 15, 2003.
ERM 2010	Industrial Wastewater Permit and Major Amendment Application, ERM, TPDES Permit, Permit No. 02120, ERM Project No. 0115940, Report No. 15387H, September, 2010.
Morris 1982	Morris Instruction Manual 022C, Morris Pumps, Inc., December 20, 1982.
NSS 1983	Sludge Pond Study, Gibbons Creek Steam Electric Station, Grimes County, Texas, Job No. D-76602-52, NFS/National Soil Services, Inc. October 21, 1983.
T&G 1977a	Sections, Site-Grading, Gibbons Creek S.E.S. Unit No. 1, Texas Municipal Power Agency, Drawing No. C-230-003, Tippet & Gee, Inc., April 21, 1977, revised October 28, 1977.
T&G 1978a	Plant Site Layout, Gibbons Creek S.E.S. Unit No. 1, Texas Municipal Power Agency, Drawing No. C-230-001, Tippet & Gee, Inc. April 21, 1977, revised May 14, 1978.
T&G 1979a	Ash Ponds - Drop Inlets & Culvert Plans & Sections, Gibbons Creek S.E.S. Unit No. 1, Texas Municipal Power Agency, Drawing No. 15-C-235, Tippet & Gee, Inc. January 16, 1979, revised August 16, 1979.
T&G 1981a	Ash Ponds - Drop Inlets & Culvert Sections & Details, Gibbons Creek S.E.S. Unit No. 1, Texas Municipal Power Agency, Drawing No. 15-C-236, Tippet & Gee, Inc. June 1, 1979, revised June 25, 1981.
TMPA 1989	FGD Area Plan, Concrete Paving Additions, Drawing No. 15-C-215, Texas Municipal Power Agency, May 5, 1988, Last Revised November 17, 1989.

TMPA 2000	Sludge Pond, Gibbons Creek S.E.S. Unit No. 1, Texas Municipal Power Agency, Drawing No. 11-C-019.3, Texas Municipal Power Agency, February 15, 2000.
URS 2011	Scrubber Refurbishment Project 19-C-264, Dewatering Area Paving, Drawing No 19-C-254, URS, April 2, 2009, Revised June 1, 2011.
TMPA 2013	TMPA Water Balance Diagram, ERM Drawing No 10-C-301, September 24, 2010, Revised by Texas Municipal Power Agency, August 15, 2013.

5.2

PUBLIC SOURCE DOCUMENTS

The following public source documents were used as sources of information used for this IDF Control System Plan for the APs and Scrubber Sludge Pond.

NWS 1978	Hydrometeorological Report No. 51, Probable Maximum Precipitation Estimates, United States East of the 105th Meridian, National Oceanic and Atmospheric Administration, June 1978.
USWB 1961	Technical Paper No. 40, Rainfall Frequency Atlas of the United States for Durations from 30 Minutes to 24 Hours and Return Periods from 1 to 100 Years, U.S. Department of Commerce, Weather Bureau, 1961, Rev. January 1963.
USWB 1964	Technical Paper No. 49, Two- to Ten-Day Precipitation for Return Periods of 2 to 100 Years in the Contiguous United States, U.S. Department of Commerce, Weather Bureau, 1964.

Tables

TABLE 1

Ash Pond Process Flow Rates

Inflow Design Flow Control Plan for CCR Surface Impoundments
Texas Municipal Power Agency, Grimes County, Texas

Stream	Description	Inflow/ (Outflow)	Process Flow Rate kgpd	Source/Comments
1	Ash Pond Direct Precipitation	Inflow	0	No process flow.
2	Ash Pond Perimeter Storm Water Runoff	Inflow	0	No process flow.
3	Gypsum Pile Stack Out Runoff	Inflow	0	No process flow.
4	Plant Collection Pond	Inflow	0	No inflow assumed during the design storm event.
5	Plant Floor (Power Island) Drainage	Inflow	0	No process flow.
6	Ultrafiltration System Blowdown	Inflow	7	From TMPA water balance; see Note 1.
7	Reverse Osmosis Wastewater	Inflow	38	From TMPA water balance; see Note 1.
8	Make-Up Demineralizer Wastewater	Inflow	1.6	From TMPA water balance; see Note 1.
9	Treated Sewage Wastewater	Inflow	2	From TMPA water balance; see Note 1.
10	Scrubber Sludge Pond	Inflow	144	No inflow from SSP assumed during the first day.
11	Boiler Blowdown	Inflow	60	From TMPA water balance; see Note 1.
12	Metal Cleaning	Inflow	0	No inflow assumed during the design storm event.
13	SAL/SFL Stormwater/Leachate	Inflow	0	No inflow assumed during the design storm event.
14	Ash Pond Discharge to Outfall 001	Outflow	-3440	See Note 2.
15	Ash Pond water to bottom transport system	Outflow	-72	Assumed equal to ATW return flow to the Ash Ponds.
16	Dewatering Bins Overflow	Inflow	72	Assumed equal to ATW supply flow from the Ash Ponds.
17	Service Water System Overflow	Inflow	0	From TMPA water balance; see Note 1.

Abbreviations and Acronyms

AP	Ash Pond
ATW	Ash Transfer Water
kgpd	thousand gallons per day
SAL	Site A Landfill
SFL	Site F Landfill

Notes

1. From 2013 revised facility water balance, TMPA Drawing No 10-C-301, August 15, 2013.
2. Maximum daily flow according to TPDES Permit Renewal Application (Permit No. 02120, ERM Project No. 0115940 and Report No. 15387H) dated September 2010.

TABLE 2

100-Year Design Precipitation

Inflow Design Flow Control Plan for CCR Surface Impoundments
 Texas Municipal Power Agency, Grimes County, Texas

Storm Duration		Total Precipitation	Source ^{1,2}
hours	days	inches	
12	0.5	9.8	Chart 42, TP-40, p. 49
24	1	11.5	Chart 49, TP-40, p. 56
	2	13.0	Figure 17, TP-49, p. 11
	4	15.0	Figure 23, TP-49, p. 17
	7	16.7	Figure 29, TP-49, p. 22

Notes

1. "TP-40" data are from the indicated part of "Technical Paper No. 40", U.S. Weather Bureau, 1961, Rev. January 1963.
2. "TP-49" data are from the indicated part of "Technical Paper No. 49", U.S. Weather Bureau, 1964.

TABLE 3

Ash Ponds Stage-Composite Runoff Coefficient

Inflow Design Flow Control Plan for CCR Surface Impoundments
Texas Municipal Power Agency, Grimes County, Texas

Depth Below Dike Crest	Total Drainage Area (At) ¹	Pond Length At Depth Below Dike Crest (Lw) ^{2,3}	Pond Width At Depth Below Dike Crest (Ww) ^{2,3}	Water Surface Area At Depth Below Dike Crest (Aw) ⁴	Open Water Storm Water Runoff Coeff. (Cw) ⁵	Slope Area At W.S. Depth Below Dike Crest (As) ⁶	Slope Area Storm Water Runoff Coeff. (Cs) ⁵	Composite Storm Water Runoff Coeff. (Cc) ⁷
vf	acres	lf	lf	acres	in/in	acres	in/in	in/in
0	34.8	1,820	245	30.7	1.00	4.1	0.70	0.96
0.5		1,817	242	30.3		4.5		0.96
1		1,814	239	29.9		4.9		0.96
2		1,808	233	29.0		5.8		0.95
3		1,802	227	28.2		6.6		0.94
4		1,796	221	27.3		7.5		0.94

Abbreviations and Acronyms

cf	cubic feet
Coeff.	coefficient
in/in	inches per inch
lf	linear feet
sf	square feet
vf	vertical feet
W.S.	water surface

Notes

1. Data and calculations of the total drainage area are shown on Table A-1.
2. The length and width at the dike crest of each Ash Pond is from Dwg. No. 15-C-235, Rev. 1, Tippet & Gee, Inc., 8/16/1977.
3. The length and width of each Ash Pond at the depth below dike crest is based on the 3H:1V side slope calculated from dimensions and elevations shown on Dwg. No. 15-C-235, Rev. 1, Tippet & Gee, Inc., 8/16/1977.
4. $Aw = Lw * Ww / (43,560 \text{ sf/acre})$.
5. Runoff coefficient sources are shown on Table A-1.
6. $As = At - Aw$.
7. $Cc = (Cw * Aw + Cs * As) / (Aw + As)$.

TABLE 4

Ash Ponds Stage Storage Data

Inflow Design Flow Control Plan for CCR Surface Impoundments
Texas Municipal Power Agency, Grimes County, Texas

Below Dike Crest (h)	Each Pond Length At Dike Crest (a) ¹	Each Pond Width At Dike Crest (b) ¹	Length At Depth Below Dike Crest (c) ²	Width At Depth Below Dike Crest (d) ²	Total Volume Below Dike Crest, All Ash Ponds ³	Below 0.5-ft. Freeboard, All Ash Ponds ⁴
vf	lf	lf	lf	lf	MMgal	MMgal
0	1,820	245	1,820	245	0.0	0.0
0.5			1,817	242	5.0	0.0
1			1,814	239	9.9	4.9
2			1,808	233	19.5	14.5
3			1,802	227	28.8	23.8
4			1,796	221	37.8	32.8

Abbreviations and Acronyms

cf	cubic feet
lf	linear feet
MMgal	million gallons
vf	vertical feet

Notes

- The length and width at the dike crest of each Ash Pond is from Dwg. No. 15-C-235, Rev. 1, Tippet & Gee, Inc., 8/16/1977.
- The length and width of each Ash Pond at the depth below dike crest based on 3H:1V side slope calculated using dimensions and elevations shown on Dwg. No. 15-C-235, Rev., Tippet & Gee, Inc., 8/16/1977.
- The total volume of all three Ash Ponds was calculated as the product of $(h/6) * (a*b + (a+c)*(b+d) + c*d)$ multiplied by 3 (the number of identical Ash Pond), and converted to units of million gallons by multiplying by 7.48 gallons per cubic feet and dividing by 1,000,000.
- The total volume below 0.5-foot freeboard was calculated as the total volume below the dike crest at that depth minus the total volume in the one-foot freeboard to account for uncertainty in dike crest elevation and wave action.

TABLE 5

Ash Pond Design Flood Inflow Rates, 100-Year Storm

Inflow Design Flow Control Plan for CCR Surface Impoundments
Texas Municipal Power Agency, Grimes County, Texas

Stream	Description	Inflow/ (Outflow)	Process Flow Rate ¹ kgpd	Storm Water Runoff			12-Hour Storm Event			1-Day Storm Event			2-Day Storm Event			4-Day Storm		
				Runoff Coefficient	Drainage Area acres	AP NDW Freeboard ⁶ vf	Total Precip. ⁷ in.	Total Volume ⁸ MMgal	AP NDW Freeboard ⁶ vf	Total Precip. ⁷ in.	Total Volume ⁸ MMgal	AP NDW Freeboard ⁶ vf	Total Precip. ⁷ in.	Total Volume ⁸ MMgal	AP NDW Freeboard ⁶ vf	Total Precip. ⁷ in.	Total Volume ⁸ MMgal	
1	Ash Pond Direct Precipitation ²	Inflow	0	1.00	30.7	1.9	9.8	8.8	1.9	11.5	10.3	1.9	13.0	11.7	1.5	15.0	13.5	
2	Ash Pond Perimeter Storm Water Runoff ²	Inflow	0	0.70	4.1													
3	Gypsum Pile Stack Out Runoff ³	Inflow	0	0.90	1.4	----		0.3	----		0.4	----		0.4	----		0.5	
4	Plant Collection Pond	Inflow	0	0	0	----		0.0	----		0.0	----		0.0	----		0.0	
5	Plant Floor (Power Island) Drainage ⁴	Inflow	0	0.95	22.3	----		5.6	----		6.6	----		7.5	----		8.6	
6	Ultrafiltration System Blowdown	Inflow	7	0	0	----		0.0	----		0.0	----		0.0	----		0.0	
7	Reverse Osmosis Wastewater	Inflow	38	0	0	----		0.0	----		0.0	----		0.1	----		0.2	
8	Make-Up Demineralizer Wastewater	Inflow	1.6	0	0	----		0.0	----		0.0	----		0.0	----		0.0	
9	Treated Sewage Wastewater	Inflow	2	0	0	----		0.0	----		0.0	----		0.0	----		0.0	
10	Scrubber Sludge Pond ⁵	Inflow	144	0	0	----		0.0	----		0.0	----		0.1	----		0.4	
11	Boiler Blowdown	Inflow	60	0	0	----		0.0	----		0.1	----		0.1	----		0.2	
12	Metal Cleaning	Inflow	0	0	0	----		0.0	----		0.0	----		0.0	----		0.0	
13	SAL/SFL Stormwater/Leachate	Inflow	0	0	0	----		0.0	----		0.0	----		0.0	----		0.0	
14	Ash Pond Discharge to Outfall 001	Outflow	(3,440)	0	0	----		(1.7)	----		(3.4)	----		(6.9)	----		(13.8)	
15	Ash Pond water to bottom transport system	Outflow	(72)	0	0	----		(0.0)	----		(0.1)	----		(0.1)	----		(0.3)	
16	Dewatering Bins Overflow	Inflow	72	0	0	----		0.0	----		0.1	----		0.1	----		0.3	
17	Service Water System Overflow	Inflow	0	0	0	----		0.0	----		0.0	----		0.0	----		0.0	
Total Inflow								13.1			14.0			13.1			9.8	
Total Volume Contained Below 0.5-Foot Minimum Freeboard⁹								13.1			14.0			13.1			9.8	

Abbreviations and Acronyms

AP	Ash Pond	No.	Number
ID	identification	Precip.	precipitation
in.	inches	SAL	Site A Landfill
in/in	inches per inch	SFL	Site F Landfill
kgpd	thousand gallons per day	vf	vertical feet
MMgal	million gallons	yr	year
NDW	normal dry weather		

Notes

- Process flow rates are from Table 1.
- AP runoff coefficients and exposed areas were used to calculate composite runoff coefficient; see Table 3 and Figure 1.
- The storm water runoff coefficient is based on surface cover type in drawing 15-C-215, TMPA, November 17, 1989. The drainage area is based on the drainage area stated in TPDES Permit Renewal Application for Permit No. 02120, ERM Project No. 0115940, Report No. 15387H, September 2010.
- The storm water runoff coefficient is based on the surface cover stated on the unit construction drawings. The drainage area is from TPDES permit application.
- No transfer from the SSP to the APs assumed during the first day of the design storm.
- The AP NDW Freeboard was selected to produce a volume above the NDW equal the Total Inflow for the corresponding design storm duration. The AP NDW Freeboard includes 0.5-foot freeboard at the maximum storage volume to contain wave run-up.
- Total precipitation for the design storm duration indicated; see Table 2.
- Total Volume is the sum of the Process Flow and the stormwater runoff calculated using the composite runoff coefficient calculated using the indicated AP NDW Freeboard and the Stage-Composite Runoff Coefficient relationship developed using data shown on Table 3 and shown on Figure 2.
- The total volume contained above the AP NDW Freeboard Level and below the 0.5-foot freeboard level at the indicated total volume based on data in Table 4 and as shown on Figure 3.

TABLE 6

Scrubber Sludge Pond Process Flow Rates

Inflow Design Flow Control Plan for CCR Surface Impoundments
Texas Municipal Power Agency, Grimes County, Texas

Stream	Description	Inflow/ (Outflow)	Process Flow Rate ¹	Source/Comments
			kgpd	
1	SSP Direct Precipitation	Inflow	0	No process flow.
2	SSP Perimeter Storm Water Runoff	Inflow	0	No process flow.
3	Scrubber Purge Treatment System Discharge	Inflow	0	No process flow assumed during the design storm.
4	SSP Pumped Transfer to Ash Ponds	(Outflow)	(144)	No transfer to the APs assumed during the first day of the design storm.

Abbreviations and Acronyms

- AP Ash Pond
- kgpd thousand gallons per day
- SSP Scrubber Sludge Pond

Notes

1. From 2013 revised facility water balance, TMPA Drawing No 10-C-301, August 15, 2013.

TABLE 7

Scrubber Sludge Pond Stage-Composite Runoff Coefficient

Inflow Design Flow Control Plan for CCR Surface Impoundments
Texas Municipal Power Agency, Grimes County, Texas

Depth Below Dike Crest	Total Drainage Area (At) ¹	Pond Length At Depth Below Dike Crest (Lw) ^{2,3}	Pond Width 1 At Depth Below Dike Crest (Ww1) ^{2,3}	Pond Width 2 At Depth Below Dike Crest (Ww2) ^{2,3}	Water Surface Area At Depth Below Dike Crest (Aw) ⁴	Open Water Storm Water Runoff Coeff. (Cw) ⁵	Slope Area At Depth Below Dike Crest (As) ⁶	Slope Area Storm Water Runoff Coeff. (Cw) ⁵	Composite Storm Water Runoff Coeff. (Cc) ⁷
vf	sf	lf	lf	lf	acres	in/in	acres	in/in	in/in
0	7.9	750	380	470	7.3	1.00	0.5	0.70	0.98
0.5		747	377	467	7.2		0.6		0.98
1		744	374	464	7.2		0.7		0.97
2		738	368	458	7.0		0.9		0.97
3		732	362	452	6.8		1.0		0.96
4		726	356	446	6.7		1.2		0.95

Abbreviations and Acronyms

cf	cubic feet
Coeff.	coefficient
in/in	inches per inch
lf	linear feet
sf	square feet
SSP	Scrubber Sludge Pond
vf	vertical feet
W.S.	water surface

Notes

1. Data and calculation of the total drainage area is shown on Table A-2.
2. The length and width at the dike crest of the Scrubber Sludge Pond is from Dwg. No. 11-C-19.1, Tippet & Gee, Inc. 2/15/2000.
3. The length and width of the SSP the depth below dike crest is based on 3H:1V side slope calculated from dimensions and elevations shown on Dwg. No. 11-C-19.1, Tippet & Gee, Inc. 2/15/2000.
4. $Aw = Lw \cdot (Ww1 + Ww2) / 2$ (43,560 sf/acre).
5. Runoff coefficient sources are shown on Table A-2.
6. $As = At - Aw$.
7. $Cc = (Cw \cdot Aw + Cs \cdot As) / (Aw + As)$.

TABLE 8

Scrubber Sludge Pond Stage-Storage Data

Inflow Design Flow Control Plan for CCR Surface Impoundments
Texas Municipal Power Agency, Grimes County, Texas

Depth Below Dike Crest	SSP Length At Dike Crest (a) ¹	SSP Width 1 At Dike Crest (b1) ¹	SSP Width 2 At Dike Crest (b2) ¹	SSP Length At Depth Below Dike Crest (c) ²	SSP Width 1 At Depth Below Dike Crest (d1) ²	SSP Width 2 At Depth Below Dike Crest (d2) ²	SSP Total Volume Below Dike Crest ³	Total Volume Below 0.5-ft. Freeboard ⁴
vf	lf	lf	lf	lf	lf	lf	MMgal	MMgal
0	750	380	470	750	380	470	0.0	0.0
0.5				747	377	467	1.2	0.0
1				744	374	464	2.4	1.2
2				738	368	458	4.7	3.5
3				732	362	452	6.9	5.7
4				726	356	446	9.1	7.9

Abbreviations and Acronyms

cf	cubic feet
lf	linear feet
MMgal	million gallons
SSP	Scrubber Sludge Pond
vf	vertical feet

Notes

1. The length and width at the dike crest of the Scrubber Sludge Pond is from Dwg. No. 11-C-19.1, Tippet & Gee, Inc. 2/15/2000.
2. The length and width of the SSP at the depth below dike crest based on 3H:1V side slope based on dimensions and elevations shown on Dwg. No. 11-C-19.1, Tippet & Gee, Inc. 2/15/2000.
3. The total volume of the SSP at the indicated Depth Below Dike Crest was calculated as the product of $(h/6) * (a * (b1+b2)/2) + (a+c) * (b + (d1+d2)/2) + c * (d1+d2/2)$ converted to units of million gallons by multiplying by 7.48 gallons per cubic feet and dividing by 1,000,000.
4. The total volume below 0.5-foot freeboard was calculated as the total volume below the dike crest at that depth minus the total volume in the one-foot freeboard to account for uncertainty in dike crest elevation and wave action.

TABLE 9
Scrubber Sludge Pond Design Flood Inflow Rates, 100-Year Storm

Inflow Design Flow Control Plan for CCR Surface Impoundments
Texas Municipal Power Agency, Grimes County, Texas

Stream	Description	Inflow/ (Outflow)	Process Flow Rate ¹ kgpd	Storm Water Runoff		12-Hour Storm Event			1-Day Storm Event			2-Day Storm Event		
				Runoff Coefficient in/in	Drainage Area acres	SSP NDW Freeboard ⁴ vf	Total Precip. ⁵ in.	Total Volume ⁶ MMgal	SSP NDW Freeboard ⁴ vf	Total Precip. ⁵ in.	Total Volume ⁶ MMgal	SSP NDW Freeboard ⁴ vf	Total Precip. ⁵ in.	Total Volume ⁶ MMgal
1	SSP Direct Precipitation ²	Inflow	0	1.00	7.3	1.4	9.8	2.0	1.5	11.5	2.4	1.5	13.0	2.7
2	SSP Perimeter Storm Water Runoff ²	Inflow	0	0.70	0.5									
3	Scrubber Purge Treatment System Discharge	Inflow	0	0	0	----		0.0	----		0.0	----		0.0
4	SSP Pumped Transfer to Ash Ponds ³	(Outflow)	(144)	0	0	----		0.0	----		0.0	----		(0.3)
Total Inflow								2.0			2.4			2.4
Total Volume Contained Below 0.5-Foot Minimum Freeboard⁷								2.0			2.4			2.4

Stream	Description	Inflow/ (Outflow)	Process Flow Rate ¹ kgpd	Storm Water Runoff		4-Day Storm			7-Day Storm		
				Runoff Coefficient in/in	Drainage Area acres	SSP NDW Freeboard ⁴ vf	Total Precip. ⁵ in.	Total Volume ⁶ MMgal	SSP NDW Freeboard ⁴ vf	Total Precip. ⁵ in.	Total Volume ⁶ MMgal
1	SSP Direct Precipitation ²	Inflow	0	1.00	7.3	1.6	15.0	3.1	1.6	16.7	3.5
2	SSP Perimeter Storm Water Runoff ²	Inflow	0	0.70	0.5						
3	Scrubber Purge Treatment System Discharge	Inflow	0	0	0	----		0.0	----		0.0
4	SSP Pumped Transfer to Ash Ponds ³	(Outflow)	(144)	0	0	----		(0.6)	----		(1.0)
Total Inflow								2.5			2.4
Total Volume Contained Below 0.5-Foot Minimum Freeboard⁷								2.5			2.5


Abbreviations and Acronyms

ID	identification	Precip.	precipitation
in.	inches	SAL	Site A Landfill
in/in	inches per inch	SFL	Site F Landfill
kgpd	thousand gallons per day	SSP	Scrubber Sludge Pond
MMgal	million gallons	vf	vertical feet
NDW	normal dry weather	yr	year
No.	Number		

Notes

1. Process flow rates are from Table 1.
2. SSP runoff coefficients and exposed areas were used to calculate composite runoff coefficient; see Table 7 and Figure 4.
3. No transfer from the SSP to the APs assumed during the first day of the design storm.
4. The SSP NDW Freeboard was selected to produce a volume above the NDW equal the Total Inflow for the corresponding design storm duration. The SSP NDW Freeboard includes 0.5-foot freeboard at the maximum storage volume to contain wave run-up.
5. Total precipitation for the design storm duration indicated; see Table 2.
6. Total Volume is the sum of the Process Flow and the stormwater runoff calculated using the composite runoff coefficient calculated using the indicated SSP NDW Freeboard and the Stage-Composite Runoff Coefficient relationship developed using data shown on Table 7 and shown on Figure 5.
7. The total volume contained above the SSP NDW Freeboard Level and below the 1-foot freeboard level at the indicated total volume based on data in Table 8 and as shown on Figure 6.


Figures



BASE MAP NOTES:

1. TOPOGRAPHY: SURFACE CONTOURS ARE BASED ON AN AERIAL SURVEY OBTAINED BY THE TMPA FROM CDS/MUERY SERVICES, INC., BIBBONS, DWG., 09/15/03.
2. AERIAL SURVEY REFERENCE MARKERS: REFERENCE MARKERS USED FOR SITE A LANDFILL SURVEYS ARE AS FOLLOWS:

MARK	DESCRIPTION	NORTH	EAST	ELEV.
TMPA 1	1/2" IRON ROD W/RED CAP	10,221,597.53	3,628,876.61	339.19
TMPA 2	1/2" IRON ROD W/RED CAP	10,213,545.19	3,642,123.31	255.55
TMPA 3	1/2" IRON ROD W/RED CAP	10,237,953.03	3,659,938.58	308.38
TMPA 4	1/2" IRON ROD W/RED CAP	10,230,743.48	3,669,915.83	353.37



Environmental Resources Management

FIGURE 1
SITE BASE MAP
Texas Municipal Power Agency
Gibbons Creek Steam Electric Station
Carlos, Texas



DESIGN: C. J. [unclear]	DRAWN: E. C.	CHKD.: [unclear]	SHEET NO.
DATE: 10/11/2011	SCALE: AS SHOWN	REV.: [unclear]	of [unclear]
W.O. NO.: H-DWG-1110-12226-002-11-1-20-01 10/11/2011 12:11:11 PM			

Figure 2- Ash Ponds Stage - Composite Runoff Coefficient Curve




Figure 3 - Ash Ponds Stage - Storage Curve




Figure 4 - Ash Ponds 100-Year Design Storm Duration - Total NDW Freeboard Curve




Figure 5 - SSP Stage - Composite Runoff Coefficient Curve




Figure 6 - SSP Stage - Storage Curve





Figure 7 - SSP 100-Year Design Storm Duration - Total NDW Freeboard Curve



Design Flood Inflow Capacity Calculations
Appendix A

October 2016
Project No. 0336706

APPENDIX A - TABLE A-1

Ash Pond Design Flood Inflow Capacity Calculations

Inflow Design Flow Control Plan for CCR Surface Impoundments
Texas Municipal Power Agency, Grimes County, Texas

Calculation Inputs

Parameter	Estimated Quantity	Estimate Units	Source
Gallons per cubic foot	7.48	gal/cf	
Square feet per acre	43,560	ft ² /acre	
Concrete Runoff Coefficient	0.95	-	TxDOT Hydraulic Design Manual, July 2016, Table 4-10
Steep Grassed Slopes Runoff Coefficient	0.70	-	TxDOT Hydraulic Design Manual, July 2016, Table 4-10
Ponded Water Runoff Coefficient	1.00	-	

Ash Pond Stage-Storage Calculations

Parameter	Estimated Quantity	Estimate Units	Source
Side Slopes	3.0	H: 1V	
Int. TOB EL., Et	270	ft - datum unknown	Dwg. No. 15-C-235, Rev.1, Tippet & Gee, Inc., 8/16/1977
Int. TOS EL., Eb	250	ft - datum unknown	Dwg. No. 15-C-235, Rev.1, Tippet & Gee, Inc., 8/16/1977
Pond Total Depth (each of 3 APs), D	20	vf	Calculation: D=Et-Eb
Pond Bottom Area (each of 3 APs)			
Bottom length, Lb	1,700	lf	Dwg. No. 15-C-235, Rev.1, Tippet & Gee, Inc., 8/16/1977
Bottom width, Wb	125	lf	Dwg. No. 15-C-235, Rev.1, Tippet & Gee, Inc., 8/16/1977
Bottom area, Ab	212,500	sf (each AP)	Calculation: Ab=Lb*Wb
Pond Top Area (each of 3 APs)			
Top length, Lt	1,820	lf	Dwg. No. 15-C-235, Rev.1, Tippet & Gee, Inc., 8/16/1977
Top width, Wt	245	lf	Dwg. No. 15-C-235, Rev.1, Tippet & Gee, Inc., 8/16/1977
Top area, At	445,900	sf (each AP)	Calculation: At=Lt*Wt
Top area	10.24	acres (each AP)	Dwg. No. 15-C-235, Rev.1, Tippet & Gee, Inc., 8/16/1977
Pond Top Area (all 3 ponds)	30.71	acres (total)	Dwg. No. 15-C-235, Rev.1, Tippet & Gee, Inc., 8/16/1977
AP Total Drainage Area			
Perimeter Dike Crest Width Drained to AP, Wpdi	20	ft W	Assume all of the perimeter dike crest drains to the interior
Interior Dike Crest Width Drained to AP, Widi	20	ft W	Assume 100% of the interior dike crests drain to the interior
Top Length, Ltda	1,860	lf	Ltda = Lt+2*Wdi
Top Width, Wtda	815	lf	Wtda = 3*Wt+2*Wpdi+2*Widi
Top Area, Atda	1,515,900	sf (all APs)	Atda = Ltda*Wtda
	34.8	acres	Convert units at 43,560 sf/acre

Abbreviations and Acronyms

AP	Ash Pond	lf	linear feet
cf	cubic feet	No.	Number
Dwg.	Drawing	Rev.	Revision
El.	Elevation	sf	square feet
ft	feet	TOB	top of bank
ft W	feet width	TOC	toe of slope
gal	gallons	TxDOT	Texas Department of Transportation
H	horizontal	V	vertical
Int.	interior	vf	vertical feet

APPENDIX A - TABLE A-2

Scrubber Sludge Pond Design Flood Inflow Capacity Calculations

Inflow Design Flow Control Plan for CCR Surface Impoundments

Texas Municipal Power Agency, Grimes County, Texas

Calculation Inputs

Parameter	Estimated Quantity	Estimate Units	Source
Gallons per cubic foot	7.48	gal/cf	
Square feet per acre	43,560	ft/acre	
Concrete Runoff Coefficient	0.95	-	Table 4-10, Hydraulic Design Manual, TxDOT, July 2016
Steep Grassed Slopes Runoff Coefficient	0.70	in/in	Table 4-10, Hydraulic Design Manual, TxDOT, July 2016
Ponded Water Runoff Coefficient	1.00	in/in	

Scrubber Sludge Pond Stage-Storage Calculations

Parameter	Estimated Quantity	Estimate Units	Source
Side Slope	3.0	H:1V	
Int. TOB El.	280	ft - datum unknown	Dwg. No. 11-C-19.1, Tippet & Gee, Inc. 2/15/2000
Int. TOS El.	260	ft - datum unknown	Dwg. No. 11-C-19.1, Tippet & Gee, Inc. 2/15/2000
Pond Total Depth, D	20	vf	Calculation: D=Et-Eb
SSP Interior Area At Int. TOS			
Bottom length, Lb	630	ft	Dwg. No. 11-C-19.1, Tippet & Gee, Inc. 2/15/2000
Bottom width 1, Wb1	260	ft	Dwg. No. 11-C-19.1, Tippet & Gee, Inc. 2/15/2000
Bottom width 2, Wb2	350	ft	Dwg. No. 11-C-19.1, Tippet & Gee, Inc. 2/15/2000
Bottom area, Ab	192,150	sf	Ab = Lb * (Wb1+Wb2)/2
SSP Interior Area At Int. TOB			
Top length, Lt	750	ft	Dwg. No. 11-C-19.1, Tippet & Gee, Inc. 2/15/2000
Top width 1, Wt1	380	ft	Dwg. No. 11-C-19.1, Tippet & Gee, Inc. 2/15/2000
Top width 2, Wt2	470	ft	Dwg. No. 11-C-19.1, Tippet & Gee, Inc. 2/15/2000
Top area, At	318,750	sf	At = Lt * (Wt1+Wt2)/2
Top area, At	7.3	acres	Convert units at 43,560 sf/acre
SSP Total Drainage Area			
Dike Crest Width Drained to SSP, Wdi	10	ft W	Assume 50% of the dike crest drains to the interior
Top length, Lt _{da}	770	ft	Lt _{da} = Lt+2*Wdi
Top width 1, Wt _{da1}	400	ft	Wt _{da1} = Wt1+2*Wdi
Top width 2, Wt _{da2}	490	ft	Wt _{da2} = Wt2+2*Wdi
Top area, At _{da}	342,650	sf	At _{da} = Lt _{da} * (Wt _{da1} +Wt _{da2})/2
Top area	7.9	acres	Convert units at 43,560 sf/acre

Abbreviations and Acronyms

cf	Cubic feet	in	inches
Dwg.	Drawing	No.	Number
El.	Elevation	sf	Square feet
ft	feet	SSP	Scrubber Sludge Pond
ft W	feet, width	TOB	Top of bank
gal	gallons	TOS	Toe of slope
H	horizontal	TxDOT	Texas Department of Transportation
Int.	Interior	V	vertical

Reference Documents
Appendix B

October 2016
Project No. 0336706

**Ash Pond Study, Black and Veatch
Project No. 13957, File No. 13957.40.1000
October 5, 1987.**

Environmental Resources Management
206 East 9th Street, Suite 1700
Austin, Texas 78701
(512) 459-4700

**PRELIMINARY
DRAFT**

**TEXAS MUNICIPAL POWER AGENCY
GIBBONS CREEK STEAM ELECTRIC STATION**

ASH POND STUDY

**B&V PROJECT 13957
B&V FILE NO. 13957.40.1000**

**ISSUE DATE AND REVISION NO.
100587-0**

RECEIVED
OCT 09 1987
TMPA DOCUMENT CONTROL
G.C.S.E.S. # 1

CONTENTS

	<u>Page</u>
1.0 INTRODUCTION	1-1
2.0 SUMMARY	2-1
2.1 SCREENING OF ALTERNATE FUTURE SOLIDS REMOVAL METHODS	2-1
2.2 ALTERNATE PLANS FOR STUDY	2-1
2.3 TECHNICAL EVALUATION	2-1
2.4 ECONOMIC EVALUATION	2-1
3.0 EXISTING CONDITIONS	3-1
3.1 SYSTEM DESIGN	3-1
3.2 SYSTEM OPERATION	3-1
3.3 SOLIDS CHARACTERISTICS	3-1
3.4 PRESENT POND STATUS	3-5
3.5 MASS BALANCE	3-5
4.0 ASH POND CLEAN-OUT	4-1
4.1 GENERAL	4-1
5.0 FUTURE SOLIDS CONTROL	5-1
5.1 OBJECTIVE	5-1
5.2 REQUIREMENTS	5-1
5.3 ALTERNATE CONTROL METHODS	5-1
5.3.1 Mechanical Dewatering	5-1
5.3.2 Gravity Thickening	5-2
5.3.3 Dewatering Bins	5-2
5.3.4 Sedimentation Basins	5-3
5.3.5 Dredge Removal	5-7
5.3.6 Preferred Plan	5-7
5.4 ALTERNATE DEWATERING PLANS	5-7
5.4.1 Alternate NE	5-8
5.4.2 Alternate SW	5-8
5.4.3 Alternate PC	5-8
5.4.4 Dredge Alternate	5-14
5.5 EVALUATION OF ALTERNATE PLANS	5-14
5.5.1 Technical Evaluation	5-14
5.5.2 Economic Evaluation	5-17
5.6 SCHEDULE	5-24

LIST OF TABLES

	<u>Page</u>
TABLE 3-1 PIPE LINE LISTING	3-3
TABLE 3-2 ASH SYSTEM MASS BALANCE	3-6
TABLE 5-1 CAPITAL COSTS - ALTERNATE NE	5-18
TABLE 5-1 CAPITAL COSTS - ALTERNATE SW	5-19
TABLE 5-3 CAPITAL COSTS - ALTERNATE PC	5-20
TABLE 5-4 CAPITAL COSTS - DREDGE ALTERNATE	5-21
TABLE 5-5 OPERATING COSTS - DREDGE ALTERNATE	5-22
TABLE 5-6 COST SUMMARY	5-23

LIST OF FIGURES

FIGURE 3-1 ASH POND FLOW DIAGRAM	3-2
FIGURE 3-2 ASH POND ARRANGEMENT	3-4
FIGURE 5-1 SEDIMENTATION BASINS ALTERNATE ARRANGEMENT PLAN	5-4
FIGURE 5-2 HYDRAULIC PROFILE	5-5
FIGURE 5-3 DECANT STRUCTURE	5-6
FIGURE 5-4 SECTIONS - ALTERNATE NE	5-9
FIGURE 5-5 FLOW DIAGRAM - ALTERNATE NE	5-10
FIGURE 5-6 SECTIONS - ALTERNATE SW	5-11
FIGURE 5-7 FLOW DIAGRAM - ALTERNATE SW	5-12
FIGURE 5-8 SECTIONS - ALTERNATE PC	5-13
FIGURE 5-9 FLOW DIAGRAM - ALTERNATE PC	5-15
FIGURE 5-10 PROJECT SCHEDULE	5-25

TEXAS MUNICIPAL POWER AGENCY
GIBBONS CREEK STEAM ELECTRIC STATION
ASH POND STUDY

1.0 INTRODUCTION

The Gibbons Creek Steam Electric Station of Texas Municipal Power Agency produces substantial quantities of combustion wastes. A portion of these wastes, consisting of bottom ash, economizer ash, and pyrites, is sluiced to hydrobins where the wastes are dewatered. The hydrobin drains and overflow discharge to three ash ponds for clarification before the ash sluice water is recycled or discharged to the Gibbons Creek reservoir. Various other wastewater streams also enter the ash ponds. The ash ponds have partially filled in the discharge area resulting in the need to remove solids from the pond to maintain operation.

The purpose of this study is to determine the most practical and economical methods to control future accumulation in the ash ponds.

2.0 SUMMARY

2.1 SCREENING OF ALTERNATE FUTURE SOLIDS REMOVAL METHODS

This study investigates various mechanical and sedimentation methods of future solids control. The preferred method for future analysis is to utilize sedimentation basins for dewatering solids from the ash discharge streams and to haul the dewatered solids to a landfill.

2.2 ALTERNATE PLANS FOR STUDY

After a screening process, four alternate plans have been selected for further study, all involving sedimentation basins.

- o Alternate NE. Install sedimentation basins to the northeast of Ash Pond A to intercept the solids before they enter the ash ponds.
- o Alternate SW. Install sedimentatin basins to the southwest of Ash Pond C to intercept the solids before they enter the ash ponds.
- o Alternate PC. Install sedimentation basin in the north end of Ash Pond C to intercept the solids before they enter the ash ponds.
- o Dredge Alternate. Allow the solids to accumulate in Ash Ponds A and B and dredge them to sedimentation basins installed in the north end of Ash Pond C.

2.3 TECHNICAL EVALUATION

Except for the Dredge Alternate, all plans require considerable piping relocation. The Dredge Alternate requires increased operating labor, electrical energy and maintenance not required by the other plans. All plans introduce additional truck traffic between the ash ponds and the landfill.

2.4 ECONOMIC EVALUATION

The capital costs, differential operating costs, and differential cumulative present worth costs of each plan are as follows.

<u>Plan</u>	<u>Capital Costs, 1987 \$</u>	<u>Differential Operating Costs, 1987 \$</u>	<u>Differential Cumulative Present Worth Costs, 1987 \$</u>
Alternate NE	1,380,580	--	2,208,900
Alternate SW	1,781,730	--	2,850,800
Alternate PC	991,370	--	1,586,200
Dredge Alternate	763,020	75,530	2,939,100

Cumulative present worth costs are for a 35 year period based on a fixed charge rate of 13 percent, a discount rate of 8.6 percent, escalation of 6 percent per year, and indirect costs of 15 percent of capital costs. Alternate PC becomes the most economic plan approximately 3 years after initial operation.

3.0 EXISTING CONDITIONS

3.1 SYSTEM DESIGN

Bottom ash, economizer ash, and pyrites are pumped to two parallel hydrobins for dewatering. The collected ash is trucked from the hydrobins to a landfill. The hydrobin drains and overflow discharge to three rectangular ponds, each approximately 1700 feet long, 240 feet wide, 20 feet deep. Other waste streams from plant sumps, the plant collection pond and sanitary sewage also enter the pond. Water from these ash ponds is recycled to the ash and scrubber system with any excess being discharged to the plant reservoir. Figure 3-1 shows a simplified flow diagram of the system. Table 3-1 lists the various pipelines that discharge into the ponds.

Ash water can be recycled from single ponds, operating in parallel, or ponds operating in series as shown on Figure 3-2. A series of box culverts and drop outlets allow operator selection of the recycle mode. The ponds are designated A, B, and C from east to west.

3.2 SYSTEM OPERATION

The ash ponds receive a fairly constant flow from all streams except the plant collection pond discharge which is periodically pumped to the ash ponds as the collection pond level rises. The ash pond discharge to the reservoir is increased during those periods of collection pond discharge to maintain the ash pond level.

The rate of bottom ash produced since the plant has been operating has exceeded the design capacity of the hydrobins resulting in a greater amount of solids overflowing into the ash ponds than was anticipated at the design stage. The solids entering the ponds settle rapidly and accumulate at the entering (north) end of the ponds with little distribution over the pond length.

3.3 SOLIDS CHARACTERISTICS

Recent field data indicates that the only streams containing appreciable solids are the hydrobin drain and overflow, the discharge from




FIGURE 3-1
ASH POND FLOW DIAGRAM

TABLE 3-1. PIPE LINE LISTING

<u>Pipe Designation</u>	<u>Size Inch</u>	<u>Service</u>
AHB-4-18	18	Hydrobin Drain
AHF-1-14	14	Fly Ash from Silo Air Separator
AHB-1-8	8	Bottom Ash Bypass
WSD-26-12	12	Sump 25 Discharge
WSD-18-10	10	Ash Loading Area Sump Discharge
WSD-40-18	18	Sump 23 Discharge
AWS-27-6	6	Ash Water Recirculation
AWS-28-12	12	Ash Water Return
WSD-92-12	12	Sump 22 Discharge
CPW-2-14	14	Plant Collection Pond Transfer
JDS-1-4	4	Sanitary Sewer
SWS-11-2	2	Service Water
AWS-6-20	20	Ash Water Pump suction from Ash Ponds




FIGURE 3-2
ASH POND ARRANGEMENT

Sump 25 located in the boiler area and the discharge from Sump 23 located at the ash water pump complex.

These streams have a typical combined solids content of 0.2 percent by weight in an average flow of 3900 gpm. These streams deposit about 2000 cubic feet per day of solids in the ponds. The solids are characteristically fine in particle size with most passing through a 200 mesh screen. Field testing demonstrated that the ash particles settle and dewater rapidly. Density of the wet compacted solids varies considerably and is assumed to average about 45 pounds per cubic foot.

3.4 PRESENT POND STATUS

In April of 1987, soundings were made in the three ponds to determine the volume of solids present. The inventory in April of 1987 is calculated to be as follows.

Pond A - 850,000 ft³ - 13 percent of capacity

Pond B - 350,000 ft³ - 5 percent of capacity

Pond C - 2,000,000 ft³ - 30 percent of capacity

An attempt was made by TMPA to remove solids from Pond C by draining and using a drag line and mobile equipment. It was found that the accumulated material would not support mobile equipment.

On a trial basis, a floating dredge was placed in Pond A and some solids were sluiced to a temporary dewatering/sedimentation basin. This trial operation was successful.

As of September 1987, Ponds A and B contain slightly more solids than in April. Pond C has had approximately 10 percent of the 2,000,000 ft³ removed by dragline. Ponds A and B are now in operation, but Pond C is still out of service and dewatered.

3.5 MASS BALANCE

An estimated water and solids mass balance is given in Table 3-2. Due to the large volume of the ponds, variations in inlet and outlet flows do not appreciably affect the average values or the pond water inventory.

TABLE 3-2. ASH SYSTEM MASS BALANCE

<u>Stream</u>	<u>Average Flow GPM</u>	<u>Average Solids lb/day</u>
Flows In		
Service Water	30	--
Sump 23	100	2,000
Hydrobins	1,600	52,000
Sump 25	1,080	35,000
Sewage	10	--
Loading Area	500	1,000
Sump 22	100	--
Collection Ponds	<u>480</u>	<u>--</u>
<u>Total In</u>	3,900	90,000
Flows Out		
Ash Water Return	3,600	0
Discharge	300	0
Retained	<u>0</u>	<u>90,000</u>
<u>Total Out</u>	3,900	90,000

4.0 ASH POND CLEAN-OUT

4.1 GENERAL

The ash ponds now have an accumulation of solids in the northern end which prevents even distribution of the water and entering solids. Cleanout of the accumulated solids will be required to restore the ponds to efficient use.

The evaluation of alternate solids control methods which follows assumes that Ponds A and B will have had as much ash removed as practical and that rehabilitation of Pond C by filling the northern end with compacted fill will have been completed.

Since all of the alternate plans considered include sedimentation basins, the removal of solids from Ponds A and B could be accomplished by dredging and sluicing to the new basins after installation.

5.0 FUTURE SOLIDS CONTROL

5.1 OBJECTIVE

The objective of this analysis is to determine the most practical and economical method of preventing the future accumulation of solids in the ash ponds.

5.2 REQUIREMENTS

- (1) The present ash ponds are to remain in service. The cost of rehabilitation of the ash ponds is not to be included in the evaluation.
- (2) New facilities will not degrade the present overall plant operation.
- (3) New facilities or construction will not require new environmental permits nor affect the existing discharge permits.

5.3 ALTERNATE CONTROL METHODS

Alternate control methods to be considered will be mechanical equipment and gravity sedimentation. All methods will be capable of dewatering the solids from the hydrobins and waste sumps to the degree that they can be loaded on a truck for transport to the landfill.

5.3.1 Mechanical Dewatering

Four types of mechanical dewatering systems are considered: vacuum filtration, pressure filtration, centrifuge, and cyclone separation.

5.3.1.1 Vacuum Filtration. Vacuum filters are available in either belt type or drum type. In either case the water in the waste stream is pulled through a cloth screen by a vacuum with the solids forming a cake on the screen from which they can be removed and conveyed to a truck.

Vacuum filters are designed for the hydraulic flow which must be handled. In general, vacuum filters cannot be used when the solids concentration is less than about 20 percent by weight. The waste streams at GCSSES contain only 0.2 percent by weight of solids, so a thickening step

will have to precede the vacuum filter. Once thickened, the solids load to the filter will be relatively low and the filter size will be minimal.

5.3.1.2 Pressure Filtration. Pressure filters for high solids are called filter presses. The waste water is forced under pressure through a cloth or screen with the solids remaining adhered to the screen.

Filter presses have the same hydraulic limitations as vacuum filters and will require a prethickening step to increase the feed concentration.

5.3.1.3 Centrifuge. The dilute streams can possibly be fed directly to a centrifuge but the equipment is sized for hydraulic flow and will be very large if the 0.2 percent stream is fed without pre-thickening.

Centrifuges are very subject to wear by erosion and are not commonly used on abrasive material such as bottom ash.

5.3.1.4 General. The equipment discussed above has not been historically used for separation of fine bottom ash from water. Pilot studies will be required prior to seriously considering mechanical dewatering.

5.3.2 Gravity Thickening

Theoretically, the solids in the waste streams being considered can be thickened to about 20 percent by weight by gravity settling in a continuous flow settling tank with mechanical scrapers. Because of the rapid settling characteristics of the solids and their density, the design of a thickener will require a special scraper and solids removal features. The thickened solids will still be too fluid to transfer directly to a truck. Further dewatering will be required.

5.3.3. Dewatering Bins

Dewatering bins (hydrobins) are not considered in this analysis. If a new hydrobin is installed in series with the existing hydrobins, the fine material overflowing or draining from the upstream hydrobins will not tend to be retained in the new hydrobin.

If a new hydrobin is used in parallel with the existing hydrobins, dewatering time will increase and overflow will likely decrease. The increased dewatering time will result in an increased drain flow counterbalancing reduced overflow. Solids carry-through may not decrease.

Hence there is no guarantee that the solids carryover to the ash ponds will be reduced by installing a new hydrobin.

5.3.4 Sedimentation Basins

The solids in the waste streams have been shown to be readily settled by gravity. It is estimated that under quiescent conditions, better than 99 percent of the solids will settle out in one hour. Therefore a basin with minimal retention time can be used to remove most of the solids before the waste streams enter the ash ponds. The solids can then be removed by excavating equipment, loaded on trucks and transported to the landfill.

By the use of parallel basins, one basin will be filling while the other is being cleaned, allowing continuous operation.

Each basin will be designed to accumulate the solids from 30 days operation and will have a water retention time of 2 hours. At an average flow of 3900 gpm with a solids concentration of 0.2 percent by weight, the water volume required will be about 60,000 cubic feet and the solids volume about 60,000 cubic feet. Selecting an accumulated solids depth of 3 feet as a practical limit with an equal depth of water on top, the total basin depth to the water level will be 6 feet. This design will be based on burning a higher ash lignite than that presently being burned, which will allow for changes in burned fuel characteristics. The basins will have an area of 2300 square feet at the bottom.

The basin will be designed to have the waste stream enter at one end and the water overflow a weir at the opposite end into the ash pond. After 30 days, the flow will be switched to the second basin and the full basin decanted and drained through an outlet structure. An access ramp in each basin will allow an excavating shovel to enter and remove the solids to trucks.

The basins will be constructed with sloped earthen walls covered by a synthetic liner for leachate control and a concrete pavement to provide a stable working surface for removal equipment.

The basin locations are shown in plan view on Figure 5-1. A hydraulic profile is shown on Figure 5-2 and the outlet and decanting structure is on Figure 5-3.

5-5






FIGURE 5-2
HYDRAULIC PROFILE



DECANT STRUCTURE

FIGURE 5-3

Pipe lines AHB-4-18 from the hydrobins, AHB-1-8, the bottom ash bypass, WDSW-26-12 from Sump 25 and WSD-40-18 from Sump 23 will be run into the sedimentation basins and all other lines will be allowed to enter the ash ponds directly. A line from the ash water recycle line will also be routed to the basin to provide a source of water for cleaning.

5.3.5 Dredge Removal

With this plan, the solids will be discharged into the ash ponds as with the present operation. As solids accumulate, they will be periodically sluiced, using a floating dredge, to sedimentation basins for final dewatering before excavation and trucking. Based on using a 1000 gpm dredge, the dredging operation will be required for about 1100 hours per year.

5.3.6 Preferred Plan

Based on the above discussion, sedimentation basins and dredge removal are the plans preferred for further analysis. These alternates present the most proven operation and deviate the least from present operating procedures.

5.4 ALTERNATE DEWATERING PLANS

Four alternate plans have been selected for evaluation.

- o Alternate NE. Direct solids discharge to sedimentation basins located to the northeast of Ash Pond A.
- o Alternate NW. Direct solids discharge to sedimentation basins located to the southwest of Pond C.
- o Alternate PC. Direct solids discharge to sedimentation basins located in the north end of Pond C.
- o Dredge Alternate. Solids discharge to Ponds A or B with a dredge used to sluice the solids to sedimentation basins located in the north portion of Ash Pond C.

5.4.1 Alternate NE.

For this plan, the sedimentation basins will be located adjacent to the northeast corner of Ash Pond A as shown on Figure 5-1. Sectional views are shown on Figure 5-4. The pipelines carrying solids will be extended from blind flanges now present at the pipe ends and routed down the east pond road to the sedimentation basins. All other pipes will continue to discharge into the north end of Pond A. The sedimentation basin overflow and decant will enter Ash Pond A at the northeast end.

Basin access for cleaning will be from a truck loading area to the east of the basins. A new haul road will be constructed from the basin running between the intake structure and the ash water complex, intercepting the existing haul road east of the ash handling complex.

A simplified flow diagram for Alternate NE is shown on Figure 5-5.

5.4.2 Alternate SW


For this plan, the sedimentation basin will be located adjacent to the southwest corner of Ash Pond C as shown in Figures 5-1. Sectional views are shown on Figure 5-6. The pipelines carrying solids will be picked up at the pipe bridge at the northwest corner of Ash Pond C and routed overhead south along the west pond road to the sedimentation basins. All other pipes will discharge into the north end of Ash Pond B. The sedimentation basin overflow and decant will enter Ash Pond C at the southwest end.

Basin access for cleaning will be from a truck loading area to the west of the basins. Truck travel will be along the existing haul road located to the west of Ash Pond C.


A simplified flow diagram of Alternate SW is shown on Figure 5-7.

5.4.3 Alternate PC

For this plan, the sedimentation basins will be located within the confines of Ash Pond C, at the north end, as shown on Figures 5-1. Sectional views are shown on Figure 5-8. The pipelines carrying solids will be picked up along the piperun, teed upward to cross the other pipes and routed south along the pond road between Ash Ponds B and C to the east



(C) TRANSVERSE SECTION - ALTERNATE N.E.
SCALE: 1" = 40'



(D) LONGITUDINAL SECTION THRU SEDIMENTATION BASINS - ALTERNATE N.E.
SCALE: 1" = 40'

SECTIONS
ALTERNATE N.E.

FIGURE 5-4






FIGURE 5-5
FLOW DIAGRAM - ALTERNATE NE



(A) TRANSVERSE SECTION - ALTERNATE S.W.
 SCALE: 1" = 40'



(B) LONGITUDINAL SECTION THRU SEDIMENTATION BASINS - ALTERNATE S.W.
 SCALE: 1" = 40'

SECTIONS
ALTERNATE S.W.

FIGURE 5-6






FIGURE 5-7
FLOW DIAGRAM - ALTERNATE SW



(E) LONGITUDINAL SECTION THRU SEDIMENTATION BASINS - ALTERNATE PC
Scale: 1" = 40'



(F) TRANSVERSE SECTION - ALTERNATE PC
Scale: 1" = 40'

SECTIONS
ALTERNATE PC
FIGURE 5-8

side of the sedimentation basin. The sedimentation basins overflow and decant will empty directly into Ash Pond B adjacent to the basins. All other flows will enter Ash Pond B through the existing pipes. The open portion of Ash Pond C will be joined to Ash Pond B for equalization.

Basin access for cleaning will be from a truck loading area along the northwest side of Ash Pond C. The haul road to the west and north of Ash Pond C will be extended to accommodate the trucks.

A simplified flow diagram of Alternate PC is shown on Figure 5-9.

5.4.4 Dredge Alternate

For this plan, the solids will continue to discharge into Ash Ponds A and B through the existing pipelines. When enough solids have accumulated a floating dredge will be used to sluice the solids to sedimentation basins. The basins will operate on the same principle as in the other plans.

The basins will be essentially the same as shown on Figures 5-1 and 5-9 for Alternate PC.

5.5 EVALUATION OF ALTERNATE PLANS

5.5.1 Technical Evaluation

Construction features and operational details of each alternate plan are as follows.

5.5.1.1 General Construction. The following general construction work will be required.

- o Site grading for sedimentation basin, loading area, and roads. Fill material will be obtained from onsite borrow areas selected by TMPA.
- o Subbases for concrete pavement will be prepared with lime stabilization as indicated on the figures.




FIGURE 5-9
FLOW DIAGRAM - ALTERNATE PC

- o Sedimentation basins and loading areas will be lined with a roller compacted concrete pavement constructed on a geotextile separation fabric and synthetic liner. Exterior slopes will be seeded.
- o Haul roads will have crushed stone surfaces with lime stabilized subgrade. Road embankments will be seeded.
- o Crossover channels and new drop inlets will be constructed as required and indicated on the figures.

5.5.1.2 Piping Modifications. The new pipelines to the sedimentation basins will have to be routed at an elevation about 12 feet higher than the existing pipe run along the north end of the ash ponds. Calculations show that there is sufficient pressure in the present sluice system to obtain this additional head. But the pipe will have to run on elevated supports from the tee-in point to the basins.

For Alternate NE, the tie-in will be at the existing blind flanges at the east end of the pipe runs. For Alternate SW, the tie-in will be made by inserting new tees in the downcomers after the pipe run crosses the haul road.

For Alternate PC, the tie-in will be made by inserting tees in the horizontal runs of pipe near the pond road bridge between Ash Ponds B and C.

In all plans, the new piping will terminate at a platform between the two sedimentation basins where it will tee off to two individually valved lines to each basin.

5.5.1.3 Basin Access. Figure 5-1 indicates the proposed truck access roads and ramps to the new sedimentation basins. All roads and ramps will be sized for the presently used combustion waste loading equipment and transport trucks.

Alternate NE requires the construction of about 900 feet of new haul road which must be elevated above the existing ground level. The haul trucks will have to enter and leave the basin loading area at the north.

For Alternate SW, a short access ramp is required to intercept the existing haul road to the west near the northeast corner of the sludge pond. The haul truck will have to enter and leave the basin loading area at the north.

For Alternate PC and the Dredge Alternate, ramps will be constructed both to the north and the south of the basin loading area to allow pass through traffic. The ramps will connect with the existing haul road to the west of Ash Pond C.

Alternate NE provides for truck bypassing of the existing sludge and ash handling area avoiding additional traffic in that area. All other alternates will increase the traffic in the ash handling area.

5.5.1.4 Dredge Operation. The technical advantage of the Dredge Alternate is that no modification is required to the existing piping systems. All streams will continue to discharge into the ash ponds. Flexible hose will be used between the dredges and the pond road with polyethylene pipe run along the road to the sedimentation basins. A booster pump will be required in addition to the dredge pump. The dredge can be used in either Ash Pond A or Ash Pond B with the dredge pipe being moved as required.

5.5.2 Economic Evaluation

5.5.2.1 Capital Costs. Capital costs have been estimated for the four alternate plans as presented on Tables 5-1 through 5-4.

Costs do not include any ash pond rehabilitation or repair work to any existing structures or equipment. No cost is included for plant outages which may be required to tie in the new installations.

5.5.2.2 Operating Costs. Operational requirements for cleaning of the sedimentation basins, truck loading, and hauling are considered to be the same for all alternates.

The Dredge Alternate will have operating costs which are not associated with the other alternates. These costs for labor, electrical energy, and maintenance are summarized on Table 5-5.

5.5.2.3 Cumulative Present Worth Costs. The summary of capital costs, differential operating costs and cumulative present worth for each alternate are shown on Table 5-6. The present worth costs were calculated

TABLE 5-1. CAPITAL COSTS - ALTERNATE NE

<u>Cost Item</u>	<u>Est. Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
o Excavation	1,200 cu. yds.	\$ 2.80	\$ 3,360
o Embankments	27.000 cu. yds.	\$ 5.60	\$ 151,200
o Roller Compacted Concrete Protection			
o Subgrade Preparation	143,000 sq. yds.	\$ 0.80	\$ 114,400
o Base Stabilization	1,300 cu. yds.	31.70	41,210
o 30 Mil PVC Liner	11,518 sq. yds.	3.15	36,280
o Geotextile	11,518 sq. yds.	1.80	20,730
o RCC	5,760 cu. yds.	47.00	<u>270,720</u>
			\$ 483,340
o Haul Road Construction			
o Subgrade Preparation	7,800 sq. yds.	\$ 1.30	\$ 10,140
o Compacted Fill	15,300 cu. yds.	2.50	38,250
o Lime Stabilization	6,500 cu. yds.	31.70	206,050
o Crushed Stone Base	3,900 cu. yds.	27.00	<u>105,300</u>
			\$359,740
o Runoff Control Curbs	650 lin. ft.	\$ 6.90	\$ 4,490
o Seeding	1 acre	\$750.00	\$ 750
o Decant Structures	170 cu yds.	\$250.00	\$ 42,500
o Fabri-Form	2,200 sq. ft.	\$ 4.00	\$ 8,800
o Piping Modifications		LS	\$295,000
o Piping Supports		LS	\$ 31,400
Estimated Total Costs		LS	\$1,380,580

TABLE 5-2. CAPITAL COSTS - ALTERNATE SW

<u>Cost Item</u>	<u>Est. Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
o Excavation	-	-	-
o Embankments	43,150 cu. yds.	\$ 5.60	\$ 241,640
o Roller Compacted Concrete Protection			
o Subgrade Preparation	144,200 sq. yds.	\$ 0.80	\$ 112,960
o Base Stabilization	1,300 cu. yds.	\$ 31.70	41,210
o 30 Mil PVC Liner	10,760 sq. yds.	\$ 3.15	33,890
o Geotextile	10,760 sq. yds.	\$ 1.80	19,370
o RCC	5,380 cu. yds.	\$ 47.00	<u>252,860</u>
			\$ 460,290
o Runoff Control Curbs	520 lin. ft.	\$ 6.90	\$ 3,590
o Seeding	1 Acre	\$750.00	\$ 750
o Decant Structures	170 cu. yds.	\$250.00	\$ 42,500
o Fabri-Form (Slope Protection)	2,200 sq. ft.	\$ 4.00	\$ 8,800
o Piping Modifications		LS	\$ 924,160
o Piping Supports		LS	\$ 100,000
Estimated Total Costs			\$1,781,730

TABLE 5-3. CAPITAL COST - ALTERNATE PC

<u>Cost Item</u>	<u>Est. Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
o Excavation	-	-	-
o Embankments	26,000 cu. yds.	\$ 5.60	\$145,600
o Roller Compacted Concrete Protection			
o Subgrade Preparation	-	-	-
o Base Stabilization	1,300 cu. yds.	\$ 31.70	\$ 41,210
o 30 Mil PVC Liner	13,900 sq. yds.	3.15	43,790
o Geotextile	13,900 sq. yds.	1.80	25,020
o RCC	5,950 cu. yds.	47.00	<u>279,650</u>
			\$389,670
o Runoff Control Curbs	500 lin. ft.	\$ 6.90	\$ 3,450
o Seeding	1 Acre	\$750.00	\$ 750
o Decant Structures	170 cu. yds.	\$250.00	\$ 42,500
o Fabri-Form	2,200 sq. ft.	\$ 4.00	\$ 8,800
o Piping Modifications		LS	\$365,000
o Piping Supports		LS	\$ 35,600
Estimated Total Costs			\$991,370

TABLE 5-4. CAPITAL COSTS - DREDGE ALTERNATE

<u>Cost Item</u>	<u>Est. Quantity</u>	<u>Unit Cost</u>	<u>Total Cost</u>
o Excavation	-	-	-
o Embankments	26,000 cu. yds.	\$ 5.60	\$145,600
o Roller Compacted Concrete Protection			
o Subgrade Preparation	-	-	-
o Base Stabilization	1,300 cu. yds.	\$ 31.70	\$ 41,210
o 30 Mil PVC Liner	13,900 sq. yds.	3.15	43,790
o Geotextile	13,900 sq. yds.	1.80	25,020
o RCC	5,950 cu. yds.	47.00	<u>279,650</u>
			\$389,670
o Runoff Control Curbs	500 lin. ft.	\$ 6.90	\$ 3,450
o Seeding	1 Acre	\$750.00	\$ 750
o Decant Structures	-	LS	\$ 42,500
o Fabri-Form	2,200 sq. ft.	\$ 4.00	\$ 8,800
o Dredge	-	LS	\$ 76,000
o Booster Pump	-	LS	\$ 43,500
o Cable and Harness	-	LS	\$ 4,950
o 8" Polyethylene Pipe	1,300 ft.	\$ 7.75	\$ 10,050
o 8" Flexible Hose	300 ft.	\$ 37.00	\$ 11,100
o Floats	15	\$110.00	\$ 1,650
Electrical	-	LS	\$ <u>25,000</u>
Estimated Total Cost			\$763,020

TABLE 5-5. OPERATING COSTS - DREDGE ALTERNATE

	<u>Item</u>	<u>1987 \$/Yr.</u>
Labor	2 Men @ \$20/Hr. Each	\$44,000
Energy	500 kW x 1100 Hr. x 0.017 \$/kwh	\$ 9,350
Maintenance	15% of Capital/Yr.	<u>\$22,180</u>
	Total Operating Cost	\$75,530

Based on: 1100 hour per year operation using a dredge with a capacity of
 1000 gpm.
 500 kW power requirement

TABLE 5-6. COST SUMMARY

<u>Plan</u>	<u>Capital Cost 1987 \$</u>	<u>Differential Operating Costs 1987 \$</u>	<u>Cumulative Present Worth* 1987 \$</u>
Alternate NE	1,380,580	-	2,208,900
Alternate SW	1,781,730	-	2,850,800
Alternate PC	991,370	-	1,556,200
Dredge Alternate	763,020	75,530	2,939,100

based on a fixed charge rate of 13 percent, a discount rate of 8.6 percent, escalation of 6 percent per year, indirect costs of 15 percent of direct capital costs, and a 35-year evaluation period.

Due to the higher operating costs, the Dredge Alternate will become more costly than Alternate PC approximately 3 years after initial operation.

5.6 SCHEDULE

Any of the alternate plans can be implemented in less than twelve months. A bar chart of the estimated engineering and construction schedule is shown on Figure 5-10. The schedule does not include rehabilitation work required for the ash ponds.





FIGURE 5-10
PROJECT SCHEDULE



TOP OF DIKE IS
PARALLEL TO R.R. NO. 2,
S 2°-1'-53" W


SEDIMENTATION BASINS
ALTERNATE ARRANGEMENT
PLAN

SCALE: 1"=100' 9-28-87

FIGURE 5-1

**Aerial Survey, CDS/Muery Services, Inc.
September 15, 2003.**

Environmental Resources Management
206 East 9th Street, Suite 1700
Austin, Texas 78701
(512) 459-4700




- NOTES:**
1. SWMUs ARE REFERENCED PER TMPA'S NOR #32271 DATED JULY 25, 2003.
 2. SAL POND #1 THROUGH #12 COMPRISE SWMU 007

TMPA DWG #: 15-C-238

- BASE MAP NOTES:**
1. TOPOGRAPHY: SURFACE CONTOURS ARE BASED ON AN AERIAL SURVEY OBTAINED BY THE TMPA FROM CDS/MUERY SERVICES, INC., BIBBONS, DWG., 09/15/03.
 2. AERIAL SURVEY REFERENCE MARKERS: REFERENCE MARKERS USED FOR SITE A LANDFILL SURVEYS ARE AS FOLLOWS:

MARK	DESCRIPTION	NORTH	EAST	ELEV.
TMPA 1	1/2" IRON ROD W/RED CAP	10,221,597.53	3,628,876.61	339.19
TMPA 2	1/2" IRON ROD W/RED CAP	10,213,545.19	3,642,123.31	255.55
TMPA 3	1/2" IRON ROD W/RED CAP	10,237,953.03	3,659,938.58	308.38
TMPA 4	1/2" IRON ROD W/RED CAP	10,230,743.48	3,669,915.83	353.37



ERM-Southwest, Inc.
 HOUSTON · NEW ORLEANS · AUSTIN · MOBILE · BEAUMONT · BATON ROUGE · CORPUS CHRISTI


FIGURE 1-2
 SITE PLAN
 Texas Municipal Power Agency
 Gibbons Creek Steam Electric Station
 Carlos, Texas

ERM.

DESIGN: JPL	DRAWN: CAK	CHKD: CRL	SHEET NO.
DATE: 02/01/06	SCALE: AS SHOWN	REV:	1 of 1
W:\O\NO - H:\dwg\K09\002413\204.dwg, 2/1/2006 10:56:31 AM			

**Industrial Wastewater Permit and Major Amendment
Application, ERM, TPDES Permit No. 02120,
ERM Project No. 0115940, Report No. 15387H,
September 2010.**

Environmental Resources Management
206 East 9th Street, Suite 1700
Austin, Texas 78701
(512) 459-4700



ERM

Industrial Wastewater Permit Renewal and Major Amendment Application

TPDES Permit No. 02120

**Texas Municipal Power Agency
Gibbons Creek Steam Electric Station
Carlos, Texas
September 2010**

Prepared by:
Environmental Resources Management
15810 Park Ten Place, Suite 300
Houston, Texas 77084

Application for Renewal and Amendment of
TPDES Permit No. 02120

Gibbons Creek Steam Electric Station
Texas Municipal Power Agency

September 2010

INTRODUCTION

Texas Municipal Power Agency (TMPA) requests to renew and amend Texas Pollutant Discharge Elimination System (TPDES) Permit No. 02120 (herein referred to as the "permit") for the Gibbons Creek Steam Electric Station (GCSES) facility.

Currently, six outfalls are authorized under the permit: four external outfalls (No. 001, 002, 003, and 004), and 2 internal outfalls (No. 101 and 201). The outfalls discharge as follow:

- Outfall 001 from Ash ponds to unnamed ditch; thence to Gibbons Creek Reservoir; thence to Gibbons Creek; then to the Navasota River;
- Outfall 002 from the plant collection pond; thence to Big Branch Creek; thence to Carlos Lake; thence to Big Branch Creek; thence to Gibbons Creek; thence to the Navasota River;
- Outfall 003 from the SAL treatment wetlands; thence to Gibbons Creek Reservoir; thence to Gibbons Creek; thence to the Navasota River; and
- Outfall 004 from the once through cooling water discharge structure; thence to Gibbons Creek Reservoir; thence to Gibbons Creek; thence to the Navasota River.

TMPA would like to renew the permit for continued authorization to discharge through five of these six outfalls, with the following amendments:

A. Remove Outfall 003 from TPDES Permit No. 02120

Outfall 003 has never been utilized for discharge from the GCSES facility. Currently, it remains inactive, and TMPA has no future plans to utilize the outfall. Therefore, TMPA requests to remove the authorization and associated references to discharge via Outfall 003 from the permit.

B. Reactivate Wet Scrubber Operation and Continue Authorized Discharge of Low-Volume Wastewater Through Outfall 001 and 002

TMPA is currently authorized to discharge low-volume wastewater through Outfalls 001 and 002. As defined in the Other Requirements section, Provision 1, of TMPA's existing TPDES Permit No. 02120, low volume wastewater includes wastewater generated by processes such as the boiler blowdown, water purifying and sewage treatment system, and wet scrubber system.

TMPA's wet scrubber system operations have been inactive since 1996. The status of the wet scrubber system was documented in TMPA's TPDES 2004- and 2007-dated permit applications. TMPA is currently in the process of reactivating the wet scrubber system, and estimates that the process will be back online by April 2011. Therefore, the currently authorized low volume wastewater that is discharged through Outfalls 001 and 002 will continue to be discharged and once again include wastewater from the wet scrubber system.

C. Authorization to Route Water from Ash Ponds as Emergency Cooling Water

On an emergency basis, TMPA is currently authorized to route water from the plant collection pond for use as cooling water in the auxiliary cooling system that discharges through Outfall 004.

To support flexibility to maintain process operations during potential drought conditions, TMPA is requesting to also have authorization on an emergency basis to route water from the ash ponds (that currently discharges through Outfall 001) for use as cooling water in the auxiliary cooling system that discharges through Outfall 004. Although routing of water from the plant collection pond would be TMPA's first option to maintain auxiliary cooling water requirements, TMPA would appreciate the flexibility to have another option available when the plant collection pond volume is low due to drought and other seasonal site conditions.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

INDUSTRIAL WASTEWATER PERMIT APPLICATION

SUBMISSION CHECKLIST - SUBMIT THIS WITH THE APPLICATION

DO NOT SUBMIT THE INSTRUCTIONS WITH THE APPLICATION

INDICATE IF THE FOLLOWING ARE INCLUDED IN THE APPLICATION. ADDITIONAL BLANK SPACES PROVIDED FOR REFERENCING APPLICANT'S ATTACHMENTS TO THE APPLICATION.

WORKSHEET	Y	N	WORKSHEET	Y	N	
ADMINISTRATIVE REPORT 1.0	✓		WORKSHEET 7.0		✓	
ADMINISTRATIVE REPORT 1.1	✓		WORKSHEET 8.0		✓	
SPIF	✓		WORKSHEET 9.0		✓	
TECHNICAL REPORT 1.0	✓		WORKSHEET 10.0		✓	
WORKSHEET 1.0	✓		ORIGINAL USGS MAP	✓		Attachment 2
WORKSHEET 2.0	✓		AFFECTED LANDOWNER MAP	✓		Attachment 4
WORKSHEET 3.0		✓	LANDOWNER DISK OR LABELS	✓		Attachment 5
WORKSHEET 3.1		✓	COPY OF APPLICATION FEE CHECK	✓		Attachment 1
WORKSHEET 3.2		✓	ALL FEES OWED TCEQ ARE PAID	✓		
WORKSHEET 3.3		✓	FLOW DIAGRAM	✓		
WORKSHEET 4.0	✓		SITE DRAWING	✓		Attachment 3
WORKSHEET 4.1		✓	ORIGINAL PHOTOGRAPHS	✓		Attachment 6
WORKSHEET 5.0		✓	SOLIDS MANAGEMENT PLAN		✓	
WORKSHEET 6.0		✓	WATER BALANCE	✓		Attachment 7

Please indicate by a check mark the amount submitted for the application fee:

EPA Classification	New	Major Amend.	Renewal	Minor Amend./Mod.
Minor facility not subject to categorical standards promulgated by the EPA (40 CFR Part 400-471)	___ \$350	___ \$350	___ \$315	___ \$150
Minor facility subject to categorical standards promulgated by the EPA (40 CFR Part 400-471)	___ \$1,250	___ \$1,250	___ \$1,215	___ \$150
Major facility	N/A *	✓ ___ \$2,050	___ \$2,015	___ \$450

* All facilities are designated as minors until formerly classified as a major by EPA.

A COPY OF THE CHECK MUST BE SUBMITTED AS PART OF THE APPLICATION

For Commission Use Only:	
Segment Number _____	County _____
Expiration Date _____	Region _____
Proposed/Current Permit Number _____	

ADMINISTRATIVE REPORT 1.0 - INDUSTRIAL

THE FOLLOWING IS REQUIRED FOR ALL APPLICATIONS, RENEWAL, NEW AND AMENDMENT.

The instructions MUST BE FOLLOWED while completing the application. Failure to do so will result in significant delays in the processing of the application.

Type of application: (check all that apply)

- | | | | |
|-------------------------------------|------------------------------------|--------------------------|------------------------------|
| <input type="checkbox"/> | New TPDES | <input type="checkbox"/> | New TLAP |
| <input checked="" type="checkbox"/> | Major amendment to existing permit | <input type="checkbox"/> | Minor modification to permit |
| <input checked="" type="checkbox"/> | Renewal of existing permit | <input type="checkbox"/> | Minor amendment to permit |
| <input type="checkbox"/> | Storm water only discharges | | |

If applying for an amendment/modification to a permit, briefly describe the reason for the proposed amendment.

Texas Municipal Power Agency (TMPA) is submitting this permit application for the Gibbons Creek Steam Electric Station (GCSES) to 1) renew existing Texas Pollutant Discharge Elimination System (TPDES) Permit No. 02120; 2) remove Outfall 003 from TPDES Permit No. 02120; 3) reactivate Wet Scrubber Operation and continue authorized discharge of low-volume wastewater through Outfall 001 and 002; and 4) request authorization to route water from Ash Ponds as emergency cooling water.

1. APPLICANT INFORMATION (Instructions, Page 14)

a. Facility owner*:

Texas Municipal Power Agency

* Owner of the facility must apply for the permit

Charter Number (issued by the Texas Secretary of State): N/A

Mailing address for use on the permit and permit correspondence:

Street No. _____ Street Name: _____ Street Type: _____

P.O. Box: 7000 City: Bryan State: TX ZIP Code: 77805

Telephone Number: 936-873-2013

Tax Identification Number issued by the State Comptroller: 74-1881816

Check one: The TCEQ has issued this Customer Reference Number to the owner. CN: 60012757

The owner has not yet received a Customer Reference Number. A completed Core Data Form (TCEQ-10400) listing the owner as a customer and this facility as the regulated entity is attached to this application.

b. Co-Permittee information (complete only if the operator must be a co-permittee)

Facility operator: N/A

Charter Number (issued by the Texas Secretary of State): _____

Mailing address for use on the permit and permit correspondence:

Street No. _____ Street Name: _____ Street Type: _____

P.O. Box: _____ City: _____ State: _____ ZIP Code: _____

Telephone Number: _____ Date of Birth: _____

Tax Identification Number issued by the State Comptroller: _____

Check one: The TCEQ has issued this Customer Reference Number to the owner. CN: _____

The owner has not yet received a Customer Reference Number. A completed Core Data Form (TCEQ-10400) listing the owner as a customer and this facility as the regulated entity is attached to this application.

Provide a brief description as to the need for a co-permittee.

[Empty box for description]

c. Individual information (complete only if the facility owner or co-permittee is an individual)

Name: N/A Check one: Male Female

State Identification Number: _____

Date of Birth: _____

Assumed business or professional name: _____

Home Address:

Street No. _____ Street Name: _____ Street Type: _____

P.O. Box: _____ City: _____ State: _____ ZIP Code: _____

Telephone Number: _____

Business name: _____

Check one: The TCEQ has issued this Customer Reference Number to this person. CN: _____
 This person has not yet received a Customer Reference Number. A completed Core Data Form (TCEQ-10400) listing this person as a customer and this facility as the regulated entity is attached to this application.

2. CONTACT INFORMATION (Instructions, Pages 15)

Name: H. Morriss Barney IV Company: Texas Municipal Power Agency
Telephone number: 936-873-1145 Fax number: 936-873-1345 E-Mail: mbarney@texasmpa.org

Street No. _____ Street name: _____ Street type: _____

P.O. Box: 7000 City: Bryan State: TX ZIP code: 77805

Check one or more: Administrative contact Technical contact

Name: Jan Horbaczewski Company: Texas Municipal Power Agency
Telephone number: 936-873-1147 Fax number: 936-873-1184 E-Mail: janh@texasmpa.org

Street No. _____ Street name: _____ Street type: _____

P.O. Box: 7000 City: Bryan State: TX ZIP code: 77805

Check one or more: Administrative contact Technical contact

3. NOTICE INFORMATION (Instructions, Page 15)

a. Individual publishing the notices

Name: H. Morriss Barney IV Telephone number: 936-873-1145
Company: Texas Municipal Power Agency Fax number: 936-873-1345

Street No: _____ Street name: _____ Street type: _____

P.O. Box: 7000 City: Bryan State: TX ZIP code: 77805

b. Method of receiving Notice of Receipt and Intent to Obtain a Water Quality Permit Package and Instructions
(Check one)

E-mail: E-mail address: mbarney@texasmpa.org
 Fax: Fax number: 936-873-1345
 Overnight/Priority mail: (self addressed, prepaid envelope required)
 Regular Mail: Street No. _____ Street name: _____
Street type: _____ P.O. Box: _____ City: _____ State: _____ ZIP code: _____

c. Contact in the notice

Name: H. Morriss Barney IV Telephone number: 936-873-1145
Company: Texas Municipal Power Agency Fax number 936-873-1345
Street No. _____ Street name: _____ Street type: _____
P.O. Box: 7000 City: Bryan State: TX ZIP code: 77805

d. Public place information

(If the facility and/or outfall is located in more than one county, a public viewing place for each county must be provided.)

Location of public building: Anderson, Texas, approximately 10 miles southeast of TMPA's facility
Public building name: Grimes County Courthouse
Street No. 100 Street name: East Buffington Street type: _____
City: Anderson County: Grimes State: TX ZIP code: 77830

*If the facility and/or outfalls are located in more than one county, a public viewing place in each county is required.

e. Bilingual Notice Requirements:

FOR NEW PERMIT APPLICATIONS, MAJOR AMENDMENT AND RENEWAL APPLICATIONS

(Not applicable for minor amendment or minor modification applications.)

Please call the bilingual/ESL coordinator for the nearest elementary and middle schools and obtain the following information to determine if an alternative language notice is required:

1. Is a bilingual education program required by the Texas Education Code at the nearest elementary or middle school to the facility or proposed facility?

Yes No (If No, alternative language notice publication is not required; skip to item 4.
FACILITY INFORMATION.)

2. Are the students who attend either the elementary school or the middle school enrolled in a bilingual education program at that school?

Yes No

3. Do the students at these schools attend a bilingual education program at another location?

Yes No

4. Would the school be required to provide a bilingual education program but the school has waived out of this requirement under 19 TAC Section 89.1205(g)?

Yes No

5. If the answer is yes to either 2, 3, or 4, public notice in an alternative language is required.
Which language is required by the bilingual program?

Name of language: Spanish

(Complete instructions on publishing the alternative language notice will be available in your full public notice package.
This section of the application is only used to determine if alternative language notice will be needed.)

4. FACILITY INFORMATION (Instructions, Page 16)

a. State/TPDES Permit No. 02120 Expiration date: 5/1/2011

EPA ID. No. TX0074438 Expiration date: 5/1/2011

Check one: The TCEQ has issued this Regulated Entity Reference Number for this facility. RN: 100214550

No Regulatory Entity Reference Number has been received for this facility. One or more completed Core
Data Forms (TCEQ-10400) listing this facility as the regulated entity is attached to this application.

b. Plant Name: Gibbons Creek Steam Electric Station

County in which the facility is located: Grimes County

County in which the outfall is located: Grimes County

c. Owner of treatment plant: Texas Municipal Power Agency

Street No. P.O. Box 7000 Street name: _____ Street type: _____

City: Bryan State: TX ZIP code: 77805

d. Owner of land where treatment plant is/will be: N/A

(If not the same as the facility owner, there must be a long term lease agreement in effect for at least six years. In some cases, a lease may not suffice - see instructions.)

Street No. _____ Street name: _____ Street type: _____

City: _____ State: _____ ZIP code: _____

e. Ownership of effluent disposal site: Texas Municipal Power Agency

(If not the same as the facility owner, there must be a long term lease agreement in effect for at least six years.)

Street No. P.O. Box 7000 Street name: _____ Street type: _____

City: Bryan State: TX ZIP code: 77805

f. Owner of sewage sludge disposal site: N/A

(Required only if authorization is being sought in the permit for sludge disposal on property owned/controlled by the applicant.)

Street No. _____ Street name: _____ Street type: _____

City _____ State: _____ ZIP code: _____ Provide an address for the facility, if a

5. LOCATION INFORMATION (Instructions, Pages 17-18)

a. Is the location of the facility used in the existing permit correct: Yes No

Provide an address for the facility, if available (address must be validated through the US Postal Service or your local
police (911 service) as a valid address. If the location description is not accurate or this is a new permit application,
please provide an accurate description.

If no, or a new permit application, please give an accurate description:

b. Is the point of discharge and discharge route in the existing permit correct: Yes No

If no, or a new or amendment permit application, please give an accurate description:

c. If a TLAP, is the location of the effluent disposal in the existing permit accurate: Yes No

If no, or a new or amendment permit application, please give an accurate description:

N/A

d. If a TLAP, provide the flow of effluent from the treatment facility to the effluent disposal site.

N/A

e. For TLAP applications, please identify the nearest watercourse to the disposal site to which rainfall runoff might flow if not contained: _____

f. Is the location of the sewage sludge disposal site in the existing permit accurate: Yes No

If no, or a new permit application, please give an accurate description:

N/A

g. Provide an **original** USGS Map with all required information. Indicate by a check mark that the information is provided.

- | | |
|--|--|
| <input checked="" type="checkbox"/> Applicant's property boundary | <input checked="" type="checkbox"/> Treatment plant boundaries See Attachment 2 |
| <input checked="" type="checkbox"/> Point of discharge and highlighted discharge route | <input checked="" type="checkbox"/> Effluent disposal site boundaries |
| <input checked="" type="checkbox"/> All ponds | <input type="checkbox"/> Sewage sludge disposal site (Offsite) |
| <input checked="" type="checkbox"/> 1 mile radius and 3 miles downstream information | <input type="checkbox"/> New and future construction |

h. Is the facility located in Bexar, Comal, Hays, Kinney, Medina, Travis, Uvalde, or Williamson County?
_____ Yes No

If yes, additional information concerning protection of the Edwards Aquifer may be required.

i. Identify the name and distance to the nearest city from the facility: Iola, Texas, approximately 10 miles north of TMPA site.

j. Is/will the treated wastewater discharge to a city, county, or state highway right-of-way, or a flood control district drainage ditch? _____ Yes No

If yes, indicate by a check mark if: _____ Authorization granted _____ Authorization pending
For new and amendment permit applications, provide copies of letters that show proof of contact and upon receipt, the approval letter.

k. Is the facility located on or does the treated effluent cross Indian Land? _____ Yes No

6. MISCELLANEOUS INFORMATION (Instructions, Page 19)

a. Provide two names of individuals that can be contacted during the permit term.

Name: H. Morriss Barney IV Telephone number: 936-873-1145
Company: Texas Municipal Power Agency Fax number: 936-873-1345
Street No. _____ Street name: _____ Street type: _____
P.O. Box: 7000 City: Bryan State: TX ZIP code: 77805

Name: Jan Horbaczewski Telephone number: 936-873-1147
Company: Texas Municipal Power Agency Fax number: 936-873-1184
Street No. _____ Street name: _____ Street type: _____
P.O. Box: 7000 City: Bryan State: TX ZIP code: 77805

b. List each person formerly employed by the TCEQ who represented your company and was paid for service regarding the application. N/A

c. For all applications involving an average daily discharge of 5 million gallons per day or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge.

Grimes, Brazos, Fort Bend, Waller, Austin, Washington, Brazoria

d. Please provide the address for receiving self-reporting/DMR forms:

Company: Texas Municipal Power Agency Department: Environmental

Name: H. Morriss Barney IV

Street No. _____ Street Name: _____ Street Type: _____

P.O. Box: 7000 City: Bryan State: TX ZIP code: 77805

Please provide the address for receiving Annual Billing Invoices:

Company: Texas Municipal Power Agency Department: Environmental

Name: H. Morriss Barney IV

Street No. _____ Street Name: _____ Street Type: _____

P.O. Box: 7000 City: Bryan State: TX ZIP code: 77805

e. Do you owe fees to the TCEQ?

Yes No

If yes, please provide the amount past due, the type of fee, and an identifying number.

Do you owe any penalties to the TCEQ?

Yes No

If yes, please provide the amount past due, the type of penalty, and an identifying number.

7. SIGNATURE PAGE (Instructions, Page 20)

I, Gary T. Parsons General Manager
Typed or printed name *Title*

certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for known violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign this document and can provide documentation in proof of such authorization upon request.

Signature: _____ Date: _____

Subscribed and Sworn to before me by the said _____ on this _____ day of _____, 20_____

My commission expires on the _____ day of _____, 20_____ [SEAL]

Notary Public

County, Texas

NOTE: If co-permittees are necessary, both entities must submit separate Signature Pages.

TCEQ USE ONLY:			
Application type:	_____ Renewal	_____ Major Amendment	_____ Minor Amendment _____ New
County:	_____ Admin Complete Date: _____		
Agency Receiving SPIF:	_____ Texas Historical Commission	_____ U.S. Fish and Wildlife	
	_____ Texas Parks and Wildlife	_____ Army Corps of Engineers	

8. SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF) (Instructions, Page 20)

This form applies to TPDES permit applications only. The SPIF must be completed as a separate document. The TCEQ will mail a copy of the SPIF to each agency as required by the TCEQ agreement with EPA. If any of the items are not completely addressed and/or further information is needed, you will be contacted to provide the information before the permit is issued. Each item must be completely addressed. **DO NOT REFER TO A RESPONSE OF ANY ITEM IN THE PERMIT APPLICATION FORM.** Each attachment must be provided with this form, separately from the administrative report of the application. The application will not be declared administratively complete without this form being completed in its entirety including all attachments

The following applies to all applications:

1. Permittee: Texas Municipal Power Agency
2. Permit No. 02120 (NPDES Permit No./EPA ID No.) TX0074438
3. Address of the project (location description that includes street/highway, city/vicinity, county):
2.5 miles North (via FM 244) of the intersection of State Hwy. 30 and FM 244, in the town of Carlos, Grimes County, TX.
4. Provide the name, address, telephone and fax number of an individual that can be contacted to answer specific questions about the property:
Name: H. Morriss Barney IV Telephone number: 936-873-1145
Company: Texas Municipal Power Agency Fax number: 936-873-1345
Street No.: _____ Street name: P.O. Box 7000 Street type: _____
City: Bryan State: TX ZIP code: 77805
5. List the county in which the facility is located: Grimes
6. If the property is publicly owned and the owner is different that the permittee/applicant, please identify the owner of the property: N/A
7. Identify the name of the water body (receiving waters) or TCEQ segment number that will receive the discharge:
See Note 1 below.

Note
1. Outfall 001 discharges to an un-named ditch, thence to Gibbons Creek Reservoir. Outfall 003 and 004 discharge to Gibbons Creek Reservoir. Gibbons Creek Reservoir discharges to Gibbons Creek, thence to the Navasota River below Lake Limestone in Segment 1209 of the Brazos River Basin. Outfall 002 discharges to Big Branch Creek, a tributary of Gibbons Creek, then to Carlos Lake; thence to Gibbons Creek; thence to the Navasota River below Lake Limestone in Segment 1209 of the Brazos River Basin.

8. Please provide a separate 7.5 minute USGS quadrangle map with the project boundaries plotted and a general location map showing the project area. (This map is required in addition to the map in the administrative report)

See Appendix A - 7.5 minute USGS Map and Attachment 3 - Facility Site Map

9. Please provide original photographs of any structures 50 years or older on the property.

10. Does your project involve any of the following? If yes, circle the appropriate letter. **No**

- a. Proposed access roads, utility lines, construction easements
- b. Visual effects that could damage or detract from a historic property's integrity
- c. Vibration effects during construction, or as a result of project design
- d. Additional phases of development that are planned for the future
- e. Sealing caves, fractures, sinkholes, other karst features
- f. Disturbance of vegetation or wetlands

11. List proposed construction impact (surface acres to be impacted, depth of excavation, sealing of caves or other karst features):

Not Applicable

12. Describe existing disturbances, vegetation & land use:

See Note 2 below.

The following applies only to applications for New TPDES permits and Major Amendments to TPDES Permits

12. List construction dates of any buildings or structures on the property:

The majority of buildings/structures located at the Gibbons Creek Steam Electric Station (GCSES) were constructed between 1977 and 1983.

13. Provide a brief history of the property, and name of the architect/builder, if known:

The property where the Gibbons Creek Steam Electric Station (GCSES) is located was purchased by Texas Municipal Power Agency in 1975. The GCSES was designed by Tippet and Gee Engineering. Texas Municipal Power Agency authorized construction of the GCSES in 1977. The GCSES began generating power in 1982.

Note:

2. Land use at the Gibbons Creek Steam Electric Station consists of production and maintenance areas, coal pile storage, stormwater collection ponds, wastewater treatment and collection ponds, and two coal combustion by-product landfills. Type of vegetation at the GCSES may include native grasses, such as bluestem and weedy forbs, and common shrubs, such as yaupon and American beauty.

ADMINISTRATIVE REPORT 1.1 - INDUSTRIAL

THE FOLLOWING IS REQUIRED FOR NEW AND AMENDMENT APPLICATIONS

1. AFFECTED LANDOWNER INFORMATION (Instructions, Pages 21-22) **See Attachment 4**

a. Indicate by a check mark that the landowners map or drawing, with scale, includes the following, as applicable.

- The applicant's property boundaries
- The plant site boundaries within the applicant's property boundaries
- N/A The distance the buffer zone falls into adjacent properties and the property boundaries of the landowners located within the buffer zone
- The property boundaries of all landowners surrounding the applicant's property
- The point(s) of discharge and highlighted discharge route clearly shown for one mile downstream
- The property boundaries of the landowners located on both sides of the discharge route for one full stream mile downstream of the point of discharge
- The property boundaries of the landowners along the watercourse for a 1/2 mile radius from the point of discharge if the point of discharge is into a lake, bay estuary, or effected by tides
- The boundaries of the effluent disposal site, all evaporation/holding ponds within the applicant's property
- The property boundaries of all landowners surrounding the applicant's property boundaries where the effluent disposal site is located
- N/A The boundaries of the sludge use/disposal/incineration site and the property boundaries of landowners surrounding the applicant's property boundaries where the sewage sludge beneficial site is located
- N/A The property boundaries of landowners within 1/2 mile in all directions from the applicant's property boundaries where the sewage sludge disposal incineration site is located

b. Indicate by a check mark which format the landowners list is submitted: Disk 4 sets of labels
(See Attachment 5 for disk with landowner list)

c. Indicate by a check mark that the list of landowners is cross-referenced to the landowners map:
Provide the source of the landowner's names and mailing addresses: Grimes County Appraisal District

d. As required by Texas Water Code 5.115, is any permanent school fund land affected by this application?
 Yes No

If yes, provide the location and foreseeable impacts and effects this application has on the land(s):

N/A

2. ORIGINAL PHOTOGRAPHS (Instructions, Page 23)


Provide original ground level photographs. Indicate by checking that the following information is provided:

- N/A At least one original photograph of the new and/or expanded treatment unit location.
- At least one original photograph showing the proposed/existing point of discharge and as much area downstream as can be captured on film. If the discharge is to an open waterbody, show as much area on both sides of the point of discharge as can be captured on film. **See Attachment 6**
- N/A At least one photograph of the existing/proposed effluent disposal site.
- A plot plan or map showing the location and direction of each photograph.
See Attachment 3 - Facility Site Map

Appendix A
U.S.G.S. Map


October 2007
Project No. 0071225

Environmental Resources Management
15810 Park Ten Place, Suite 300
Houston, Texas 77084
(281) 600-1000



LEGEND

- TMPA PROPERTY BOUNDARY
- DISCHARGE POINTS



SOURCE: U.S.G.S. 7.5' QUADRANGLES, KEITH, TX, 1962, PHOTOREVISED 1988 (o30096F1) & CARLOS, TX, 1960, PHOTOREVISED 1989 (o30096E1).

Environmental Resources Management

DESIGN: RMA	DRAWN: CAK	CHKD.:
DATE: 10/16/2007	SCALE: AS SHOWN	REV.:
PROJ. NO.: H:\DWG\J07\0071225a202.dwg, 10/16/2007 12:56:06 PM		

APPENDIX A
U.S.G.S. MAP
Texas Municipal Power Agency
Gibbons Creek Steam Electric Station
Carlos, Texas



TECHNICAL REPORT 1.0 - INDUSTRIAL

THE FOLLOWING IS REQUIRED FOR ALL APPLICATIONS, RENEWAL, NEW, AND AMENDMENT

1. FACILITY/SITE INFORMATION (Instructions, page 24)

a. Describe the type of activity and general nature of your business.

The Gibbons Creek Steam Electric Station is a coal-fired electric generating power plant located along the Gibbons Creek Reservoir in Grimes County, Texas. The plant began generating commercial power in 1982, and is owned and operated by Texas Municipal Power Agency, for the four member cities Greenville, Denton, Garland, and Bryan.

b. SIC Code(s) 4911 , _____ , _____ , _____
 NAICS Code(s) 221112 , _____ , _____ , _____

c. Describe the wastewater generating processes.

The process systems and associated wastewater that is generated at the Gibbons Creek Steam Electric Station include:

- Low volume wastewater (as defined in the Other Requirements section, Provision 1, of TMPA's existing TPDES Permit No. 02120), generated by processes such as the boiler blowdown, water purifying and sewage treatment system, and wet scrubber system;
- Ash transport system generates ash transport water;
- Periodic high pressure washing of air preheater baskets and boiler tube cleaning generates metal cleaning wastewater;
- Coal combustion by-product landfill cells "A" and "F" generate ash landfill leachate;
- Coal dust suppression system and storm water runoff from coal piles generate coal pile runoff;
- Precipitation onto plant drainage areas generates storm water runoff;
- Cooling water system generates once through cooling water; and
- Non-contact auxiliary cooling system generates non-contact cooling water.

d. Provide a list of raw materials, major intermediates, and products handled at your facility.

Raw Materials	Intermediate Products	Final Products
sub-bituminous coal	steam	ash (bottom and fly ash)
caustic soda		electrical power
sulfuric acid		

e. Indicate by a check mark that an attached facility map with the following information was provided with the application:

- Production areas, maintenance areas, materials handling areas, and waste disposal areas.
- The location of each unit of the wastewater treatment plant including the location of wastewater collection sumps and impoundments.

Attachment: See Attachment 3 - Facility Site Map

f. Is this a new permit application for an existing facility? Yes No

If yes, provide background discussion below.

Not Applicable

g. Is the treatment facility/disposal site located above the 100-year frequency flood level?

Yes No

List source(s) used to determine 100-year frequency flood plain:

1999 Federal Emergency Management Agency's (FEMA) 100-year flood zone map

If **no**, provide the elevation of the 100-year frequency flood plain and describe what protective measures are in use or planned to be used to prevent flooding of the treatment facility/disposal area.

Not Applicable

h. For **new or amendment** permit applications, will there be discharge of fill material into a water in the state for construction of the proposed outfall structure? Yes No

If **no**, proceed to Item No. 2. If **yes**, has the applicant applied for a U.S. Corps of Engineers 404 Dredge and Fill permit? Yes No

If **yes**, provide the permit number: N/A

If **no**, provide the approximate date you anticipate submitting your application to the Corps. N/A

2. TREATMENT SYSTEM (Instructions, page 25)

- a. List any physical, chemical, and/or biological treatment process that you use for the treatment of wastewater at your facility. Include a description of each treatment process starting with initial treatment and finishing with the discharge point.

See page 3a-1 (next page) for description.

- b. Indicate by a check mark that an attached flow schematic with a water balance was provided with the application showing each treatment unit and all sources of wastewater flow into the treatment plant and to each outfall/point of disposal. **Attachment: 7 - Water Balance**

3. IMPOUNDMENTS (Instructions, pages 25-27)

Do you use or plan to use any wastewater lagoons, ponds, or impoundments? Yes No

If **yes**, complete item **3(a)** for **existing** impoundments and items **3(a)-3(f)** for **new or proposed** impoundments. If **no**, proceed to Item No. 4.

- a. Provide the following information in the table provided:

Designation: Indicate the appropriate use designation for each pond [Treatment (T), Disposal (D), Containment (C), or Evaporation (E)]

Discharge Point: If a discharge occurs from the impoundments, designate the outfall associated with the impoundment.

Liner Information: If the impoundments are lined to comply with specifications outlined for **1) a compacted clay liner (C), 2) an in-situ clay liner (I), or 3) a synthetic/plastic/rubber liner (S)**, indicate the liner type with the appropriate letter designation (**see instructions for further detail on liner specifications**). If not, provide a reference to the attachment that provides a description of the alternate liner and any additional technical information necessary for an evaluation. **See Attachment 8**

Dimensions: Provide the dimensions(s), freeboard, surface area, and storage volume capacity of the impoundments. For impoundments with irregular shapes, submit surface area (instead of length and width), the average depth, and the maximum depth below natural ground level.

Outfall 001

Wastestreams currently authorized for discharge through Outfall 001 include: low volume wastewater, ash transport water, coal pile runoff, previously monitored effluents and stormwater. Processes that are used for treatment of each wastestream discharged through Outfall 001 are described below.

- Low volume wastewater (as defined in the Other Requirements section, Provision 1, of TMPA's existing TPDES Permit No. 02120) is treated by the following:
 - Scrubber purge from the wet scrubber system is forwarded to the scrubber purge treatment system where it is treated by chemical precipitation, settling, stabilization, and neutralization. The wastestream is then sent to the ash ponds for additional treatment by settling and neutralization. The wastewater is then discharged through Outfall 001.
 - Other authorized low-volume wastewater is treated via settling and neutralization in the ash ponds. The wastewater is then discharged to Outfall 001.
- Ash transport water is generated in the bottom ash transport system and is treated by settling and neutralization in the ash ponds. The wastewater is then discharged through Outfall 001.
- Coal pile and stormwater runoff is collected in the Plant Collection Pond. Per the Other Requirements section, Provision 7, of TMPA's existing TPDES Permit No. 02120, "stormwater runoff caused by rainfall events less than a 10-year, 24-hr rainfall shall be routed to the plant collection pond prior to discharge via Outfall 002 and/or the ash ponds prior to discharge via Outfall 001." Coal pile and stormwater runoff is treated by settling in the plant collection pond. The collected wastewater may then be transferred to the ash ponds, where additional treatment by settling and neutralization is performed. The wastewater is then discharged through Outfall 001.
- Previously monitored effluents include the domestic treated wastewater and the metal cleaning wastewater. The domestic wastewater is treated via stabilization, settling, chlorination, and neutralization in the on-site domestic sewage treatment system. The domestic wastewater is discharged through the internal Outfall 101 to the ash ponds. The metal cleaning wastewater is treated via settling and neutralization and discharged through internal Outfall 201 to the ash ponds. Additional treatment, such as settling and neutralization, is performed in the ash ponds. The wastestream is then discharged through Outfall 001.
- A mixture of stormwater and landfill leachate is generated by the coal combustion by-product landfill cells "A" and "F" (SAL and SFL) and treated by settling in the SAL and SFL collection ponds, and the scrubber sludge pond. TMPA periodically uses a mixture of stormwater and ash landfill leachate, as ash transport water. This reduces raw water needs for the GCSSES bottom ash transport system make-up water.

2. TREATMENT SYSTEM (Instructions, page 23) **Continued**

- a. List any physical, chemical, and/or biological treatment process that you use for the treatment of wastewater at your facility. Include a description of each treatment process starting with initial treatment and finishing with the discharge point.

See page 3b-1 (next page) for description.

- b. Indicate by a check mark that an attached flow schematic with a water balance was provided with the application showing each treatment unit and all sources of wastewater flow into the treatment plant and to each outfall/point of disposal. **Attachment: 7 - Water Balance**

3. IMPOUNDMENTS (Instructions, page 23)

Do you use or plan to use any wastewater lagoons, ponds, or impoundments? Yes No
 If **yes**, complete item 3(a) for **existing** impoundments and items 3(a)-3(f) for **new or proposed** impoundments.
 If **no**, proceed to Item No. 4.

- a. Provide the following information in the table provided:

Designation: Indicate the appropriate use designation for each pond [Treatment (T), Disposal (D), Containment (C), or Evaporation (E)]

Discharge Point: If a discharge occurs from the impoundments, designate the outfall associated with the impoundment.

Liner Information: If the impoundments are lined to comply with specifications outlined for 1) a compacted clay liner (C), 2) an in-situ clay liner (I), or 3) a synthetic/plastic/rubber liner (S), indicate the liner type with the appropriate letter designation (see instructions for further detail on liner specifications). If not, provide a reference to the attachment that provides a description of the alternate liner and any additional technical information necessary for an evaluation. **See Attachment 8**

Dimensions: Provide the dimensions(s), freeboard, surface area, and storage volume capacity of the impoundments. For impoundments with irregular shapes, submit surface area (instead of length and width), the average depth, and the maximum depth below natural ground level.

Outfall 002

Wastestreams currently authorized for discharge through Outfall 002 include: low volume wastewater, ash transport water, coal pile runoff, and stormwater. Per the Other Requirements Section, Provision 7, of TMPA's existing TPDES Permit No. 02120, "Stormwater runoff caused by rainfall events less than a 10-year, 24-hr rainfall shall be routed to the plant collection pond prior to discharge via Outfall 002 and/or the ash ponds prior too discharge via Outfall 001." Processes that are used for treatment of each wastestream discharged through Outfall 002 (or if routed to Outfall 001) are described below.

- Low volume wastewater (as defined in the Other Requirements section, Provision 1, of TMPA's existing TPDES Permit No. 02120) is treated by the following:
 - Scrubber purge from the wet scrubber system is forwarded to the scrubber purge treatment system where it is treated by chemical precipitation, settling, stabilization, and neutralization. The wastestream is typically sent to the ash ponds for additional treatment and discharged through Outfall 001. However, the wastestream may also (if necessary) be sent to the plant collection pond for additional treatment by settling. The wastewater is then discharged through Outfall 002, or to the ash ponds for discharge through Outfall 001.
 - Other authorized low-volume wastewater is treated via settling in the plant collection pond. The wastewater is then discharged through Outfall 002, or to the ash ponds for discharge through Outfall 001.
- Coal pile and stormwater runoff are treated in the plant collection pond via settling. The wastewater is then discharged through Outfall 002, or sent to the ash ponds for discharge through Outfall 001.

2. TREATMENT SYSTEM (Instructions, page 23) Continued

- a. List any physical, chemical, and/or biological treatment process that you use for the treatment of wastewater at your facility. Include a description of each treatment process starting with initial treatment and finishing with the discharge point.

Outfall 004

Once through cooling water and auxiliary non-contact cooling water is not treated and is directly discharged through Outfall 004 into the western portion of Gibbons Creek Reservoir. On an emergency basis, TMPA is authorized to route water from the plant collection pond for use as cooling water in the auxiliary cooling system that discharges through Outfall 004.

To support flexibility to maintain process operations during potential drought conditions, TMPA is requesting to also have authorization on an emergency basis to route water from the ash ponds (that currently discharges through Outfall 001) for use as cooling water in the auxiliary cooling system that discharges through Outfall 004. Although routing of water from the plant collection pond would be TMPA's first option to maintain auxiliary cooling water requirements, TMPA would appreciate the flexibility to have another option available when the plant collection pond volume is low due to drought and other seasonal site conditions.

- b. Indicate by a check mark that an attached flow schematic with a water balance was provided with the application showing each treatment unit and all sources of wastewater flow into the treatment plant and to each outfall/point of disposal. **Attachment: 7 - Water Balance**

3. IMPOUNDMENTS (Instructions, page 23)

Do you use or plan to use any wastewater lagoons, ponds, or impoundments? Yes No
 If **yes**, complete item 3(a) for **existing** impoundments and items 3(a)-3(f) for **new or proposed** impoundments.
 If **no**, proceed to Item No. 4.

- a. Provide the following information in the table provided:

Designation: Indicate the appropriate use designation for each pond [Treatment (T), Disposal (D), Containment (C), or Evaporation (E)]

Discharge Point: If a discharge occurs from the impoundments, designate the outfall associated with the impoundment.

Liner Information: If the impoundments are lined to comply with specifications outlined for 1) a compacted clay liner (C), 2) an in-situ clay liner (I), or 3) a synthetic/plastic/rubber liner (S), indicate the liner type with the appropriate letter designation (see instructions for further detail on liner specifications). If not, provide a reference to the attachment that provides a description of the alternate liner and any additional technical information necessary for an evaluation. **See Attachment 8**

Dimensions: Provide the dimensions(s), freeboard, surface area, and storage volume capacity of the impoundments. For impoundments with irregular shapes, submit surface area (instead of length and width), the average depth, and the maximum depth below natural ground level.

Impoundment Information Table

	Pond # <u>SAL 1</u>	Pond # <u>SAL 2</u>	Pond # <u>SAL 3</u>	Pond # <u>SAL 4</u>	Pond # <u>SAL 5</u>
Designation					
(T) (D) (C) or (E)	C, E, T	C, E, T	C, E, T	C, E, T	C, E, T
Discharge Point					
Outfall Number	001	001	001	001	001
Liner Information					
Liner Type (C) (I) or (S)					
Alt. Liner Attachment Reference	Attachment 8	Attachment 8	Attachment 8	Attachment 8	Attachment 8
Dimensions					
Length (feet)	<u>770</u> ft	<u>680</u> ft	<u>300</u> ft	<u>440</u> ft	<u>285</u> ft
Width (feet)	<u>230</u> ft	<u>260</u> ft	<u>230</u> ft	<u>430</u> ft	<u>60</u> ft
Depth from Water Surface	<u>9.8</u> ft	<u>5.6</u> ft	<u>6</u> ft	<u>6</u> ft	<u>3.2</u> ft
Depth from Nat. Ground Level	<u>13</u> avg - max	<u>4</u> avg - max	<u>8</u> avg - max	<u>-5</u> avg - max	<u>6</u> avg - max
Freeboard (feet)	<u>2</u> ft	<u>2</u> ft	<u>2</u> ft	<u>2</u> ft	<u>2</u> ft
Surface Area (acres)	<u>2.1</u> acres	<u>3.5</u> acres	<u>1.2</u> acres	<u>24</u> acres	<u>0.18</u> acres
Storage Capacity (gallons)	<u>5,565,000</u> gal.	<u>6,504,000</u> gal.	<u>2,054,000</u> gal.	<u>2,079,000</u> gal.	<u>104,800</u> gal.

	Pond # <u>SAL 6</u>	Pond # <u>SAL 7</u>	Pond # <u>SAL 9</u>	Pond # <u>SAL 10</u>	Pond # <u>SAL 11</u>
Designation					
(T) (D) (C) or (E)	C,E,T	C,E,T	C,E,T	C,E,T	C,E,T
Discharge Point					
Outfall Number	001	001	001	001	001
Liner Information					
Liner Type (C) (I) or (S)					
Alt. Liner Attachment Reference	Attachment 8	Attachment 8	Attachment 8	Attachment 8	Attachment 8
Dimensions					
Length (feet)	<u>305</u> ft	<u>310</u> ft	<u>310</u> ft	<u>300</u> ft	<u>295</u> ft
Width (feet)	<u>50</u> ft	<u>65</u> ft	<u>65</u> ft	<u>55</u> ft	<u>60</u> ft
Depth from Water Surface	<u>5</u> ft	<u>5.2</u> ft	<u>4.3</u> ft	<u>4.7</u> ft	<u>2.1</u> ft
Depth from Nat. Ground Level	<u>7</u> avg - max	<u>9</u> avg - max	<u>-2</u> avg - max	<u>7</u> avg - max	<u>3</u> avg - max
Freeboard (feet)	<u>2</u> ft	<u>2</u> ft	<u>2</u> ft	<u>2</u> ft	<u>2</u> ft
Surface Area (acres)	<u>0.23</u> acres	<u>0.2</u> acres	<u>0.25</u> acres	<u>0.20</u> acres	<u>0.23</u> acres
Storage Capacity (gallons)	<u>234,000</u> gal.	<u>350,400</u> gal.	<u>239,100</u> gal.	<u>162,400</u> gal.	<u>196,700</u> gal.

Impoundment Information Table

	Pond # <u>SAL 11</u>	Pond # <u>SAL 12</u>	Pond # _____	Pond # _____	Pond # <u>SFL 3</u>
Designation					
(T) (D) (C) or (E)	C,E,T	C,E,T			C,E,T
Discharge Point					
Outfall Number	001	001			001
Liner Information					
Liner Type (C) (I) or (S)					C
Alt. Liner Attachment Reference	Attachment 8	Attachment 8			Attachment 8
Dimensions					
Length (feet) ⁽¹⁾	550 ft	190 ft	_____ ft	_____ ft	1,000 _____ ft
Width (feet) ⁽¹⁾	75 ft	55 ft	_____ ft	_____ ft	650 ft
Depth from Water Surface	3.7 ft	3.1 ft	_____ ft	_____ ft	15 ft
Depth from Nat. Ground Level	7 avg - max	5 avg - max	__ avg - max	avg - max	6 avg - max
Freeboard (feet)	2 ft	2 ft	_____ ft	_____ ft	2 ft
Surface Area (acres) ⁽²⁾	0.65 acres	0.15 acres	_____ acres	_____ acres	14.5 acres
Storage Capacity (gallons)	601,700 gal.	123,200 gal.	_____ gal.	_____ gal.	163,000 gal.

	Pond # <u>AP 1</u>	Pond # <u>AP 2</u>	Pond # <u>AP 3</u>	Pond # <u>PCP</u>	Pond # <u>SSP</u>
Designation					
(T) (D) (C) or (E)	C,E,T	C,E,T	C,E,T	C,E,T	C,E,T
Discharge Point					
Outfall Number	001	001	001	002	001
Liner Information					
Liner Type (C) (I) or (S)	C	C	C	C	S
Alt. Liner Attachment Reference					
Dimensions					
Length (feet) ⁽¹⁾	1750 ft	1750 ft	1750 ft	1800 ft	780 ft
Width (feet) ⁽¹⁾	250 ft	250 ft	250 ft	650 ft	400 ft
Depth from Water Surface	20 ft	20 ft	20 ft	7 ft	20 ft
Depth from Nat. Ground Level	22 avg - max	22 avg - max	22 avg - max	19 avg - max	22 avg - max
Freeboard (feet)	2 ft	2 ft	2 ft	2 ft	2 ft
Surface Area (acres) ⁽²⁾	10 acres	10 acres	10 acres	26 acres	7.16 acres
Storage Capacity (gallons)	49 million gal.	49million gal.	49million gal.	89 million gal.	46 million gal.

Impoundment Information Table

Notes:

- 1. SAL Pond 1, SFL Pond 3, and the Plant Collection Pond are considered irregularly shaped.**
- 2. Surface area is calculated based upon the maximum water surface elevation.**

AP = Ash Pond

PCP = Plant Collection Pond

SSP = Scrubber Sludge Pond

THE FOLLOWING ITEMS ARE REQUIRED ONLY FOR NEW OR PROPOSED IMPOUNDMENTS.

b. Indicate by a check mark if any of the following data was provided with the application:

- (1) N/A Synthetic/plastic/rubber liner data
(2) N/A In-situ clay liner data

Attachment: Not Applicable

c. Are there any leak detection systems or ground water monitoring wells in place or planned? Yes No **N/A**

 N/A If **yes**, indicate by a check mark that a separate attachment was provided with the leak detection system information for each pond and/or ground water monitoring well data.

Attachment: Not Applicable

d. Is the bottom of the pond above the seasonal high water table in the most shallow water bearing zone?

 Yes ✓ No **N/A**

 N/A If **no**, indicate by a check mark that additional information was provided describing the depth of the seasonal high water table in the most shallow water bearing zone in relation to the depth of the bottom of the new or proposed impoundment and how this may or may not impact groundwater.

e. Indicate by a check mark that the following information was provided:

 N/A A USGS quadrangle map or a color copy of original quality and scale which accurately locates and identifies water supply wells and/or monitor wells within ½ mile radius of the impoundments.

 N/A Copies of State Water Well Reports (driller's logs, completion data), and data on depths to ground water for water supply wells including a description of how the depths to ground water were obtained.

For TLAP permit applications: N/A Indicate by a check mark that the new or proposed impoundment(s) and the land application disposal area are located in the same general area and the information for this item is provided in Worksheet 3.0 (item 8).

f. N/A Indicate by a check mark if any data was provided with the application pertaining to the ground water, soils, geology, etc. used to assess the potential for migration of wastes from the impoundments and/or the potential for contamination of ground water or surface water.

4. OUTFALL/DISPOSAL METHOD INFORMATION (Instructions, pages 27-28)

Complete the following tables to describe the location and wastewater discharge or disposal operations for each outfall for discharge operations and for each point of disposal for TLAP operations.

For TLAP permit applications: Indicate the disposal method and each individual **irrigation area (I)**, **evaporation pond (E)**, or **subsurface drainage system (S)** by providing the appropriate letter designation for the disposal method followed by a numerical designation for each disposal area (e.g. evaporation pond, application area) in the space provided for "Outfall" designation (e.g. "E1" for evaporation pond 1, "I2" for irrigation area No. 2, etc.).

OUTFALL: 001

Latitude			Longitude			Location Description		
30	36	57	96	04	30	Outfall 001 is located on the northeast corner of the Ash Ponds		
Permitted Flow (MGD)			Proposed Flow (MGD)					
Dly Avg	Dly Max	Dly Avg	Dly Max	Discharge Duration				
Report (a)	Report (a)			0-24 (hrs./day) 30 (days/mo.) 12 (mo./year)				
<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Gravity		Measurement Device: <u>Flow meter</u>			<input checked="" type="checkbox"/> Intermittent <input type="checkbox"/> Seasonal <input type="checkbox"/> Continuous			
Contributing Wastestreams:					Volume (MGD)	% of Total Flow		
Low Volume Wastewater					0.319	40.9%		
Previously Monitored Effluents (Outfalls 101 and 201)					0.002	0.3%		
Ash Transport Water (Recycled ash pond water and SAL/SFL stormwater/leachate mixture)					0.090	11.5%		
Coal Pile Runoff					0.085	10.9%		
Stormwater					0.284	36.4%		
Note: Ash transport water is recycled.								

OUTFALL: 002

Latitude			Longitude			Location Description		
30	36	50	96	05	00	Plant Collection Pond Spillway located south of Gibbons Creek Steam Electric Station		
Permitted Flow (MGD)			Proposed Flow (MGD)					
Dly Avg	Dly Max	Dly Avg	Dly Max	Discharge Duration				
Report (b)	Report (b)			0-24 (hrs./day) 30 (days/mo.) 12 (mo./year)				
<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Gravity		Measurement Device: <u>estimate</u>			<input checked="" type="checkbox"/> Intermittent <input type="checkbox"/> Seasonal <input type="checkbox"/> Continuous			
Contributing Wastestreams:					Volume (MGD)	% of Total Flow		
Low Volume Wastewater					0.0001	0.1%		
Coal Pile Runoff					0.085	46.4%		
Stormwater					0.098	53.5%		

Notes:

- (a) Permit No. 02120 requires TMPA to report flow. Daily average flow was 0.546 MGD and daily maximum flow was 3.44 MGD based on discharge monitoring reports dated 2007-2009.
- (b) Per the Other Requirements section, Provision 7 of TMPA's existing TPDES Permit No. 02120, "Stormwater runoff caused by rainfall events less than a 10-year, 24-hr rainfall shall be routed to the plant collection pond prior to discharge via Outfall 002 and/or the ash ponds prior to discharge via Outfall 001".

OUTFALL: 004

Latitude			Longitude			Location Description	
30	37	32	96	04	90		Outfall 004 is located north of the Gibbons Creek Stream Electric Station at the western portion of the Gibbons Creek Reservoir Hot Pond.
Permitted Flow (MGD)			Proposed Flow (MGD)				
Dly Avg	Dly Max		Dly Avg	Dly Max		Discharge Duration	
Report (b)	Report (b)					0-24 (hrs./day) 30 (days/mo.) 12 (mo./year)	
<input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Gravity		Measurement Device: _____			<input type="checkbox"/> Intermittent <input type="checkbox"/> Seasonal <input checked="" type="checkbox"/> Continuous		
Contributing Wastestreams:						Volume (MGD)	% of Total Flow
Auxiliary Non-contact Cooling Water						0.012	0.0%
Once through Cooling Water System						307	100%

Note: (b) Permit No. 02120 requires TMPA to report flow. The daily average flow was 412 MGD and the daily maximum flow was 523 MGD for June 2006 - July 2009 as reported in TMPA's discharge monitoring records.

OUTFALL: _____

Latitude			Longitude			Location Description	
Permitted Flow (MGD)			Proposed Flow (MGD)				
Dly Avg	Dly Max		Dly Avg	Dly Max		Discharge Duration	
						_____ (hrs./day) _____ (days/mo.) _____ (mo./year)	
<input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Gravity		Measurement Device: _____			<input type="checkbox"/> Intermittent <input type="checkbox"/> Seasonal <input checked="" type="checkbox"/> Continuous		
Contributing Wastestreams:						Volume (MGD)	% of Total Flow

5. BLOWDOWN AND ONCE-THROUGH COOLING WATER DISCHARGES (Instructions, page 28)

- a. Does your facility use any cooling towers or boilers that discharge blowdown or other wastestreams to the outfall(s)? Yes No
- b. Does your facility discharge once-through cooling water to the outfall(s)? Yes No
- c. If **yes** to either item **a** or **b**, indicate with a check mark that the appropriate MSDS with the following information for each chemical additive was submitted with the application. **See Attachment 9**

- Manufacturers Product Identification Number.
- Product use. (e.g., biocide, fungicide, corrosion inhibitor, etc.)
- Chemical Composition including Chemical Abstracts System (CAS) number for each ingredient.
- Classify product as non-persistent, persistent, or bioaccumulative.
- Product or active ingredient half-life.
- Frequency of product use (e.g., 2 hr/day once every two weeks).
- Product toxicity data specific to fish and aquatic invertebrate organisms.
- Concentration of whole product in wastestream (if above item is for whole product)
- Concentration of active ingredient in wastestream (if above item is for active ingredient)

Please provide a summary of this information in addition to the submittal of the MSDS for each specific wastestream and the associated chemical additives and specify which outfalls are affected.

Attachment: Not Applicable

d. Cooling Towers and Boilers

	Number of Units	Daily Avg. Blowdown	Daily Max Blowdown
Cooling Towers	<u>0</u> cooling towers	Daily Avg: <u>N/A</u> gallons/day	Daily Max: <u>N/A</u> gallons/day
Boilers	<u>1</u> boilers	Daily Avg: <u>59,400</u> gallons/day ^(a)	Daily Max: <u>290,000</u> gallons/day ^(b)

Notes:
 (a) Based on flow meter readings taken 2002-2003
 (b) Process knowledge.

6. STORM WATER MANAGEMENT (Instructions, pages 28-29)

Are there any existing or proposed outfalls which discharge storm water runoff commingled with other wastestreams? Yes No. If **yes**, provide the following information. If **no**, proceed to Item No. 7.

- a. Provide a brief narrative description of the industrial processes and activities that occur outdoors or in some manner that may result in exposure of the materials to precipitation or runoff in areas where runoff is generated.

Industrial processes and/or activities at the Gibbons Creek Steam Electric Station (GCSES) that may potentially result in exposure of materials to surface water runoff include:

- Maintenance activities that occur in the Maintenance Area may result in runoff that contains residual oil and grease, fuels, and lubricants;
- The power production process located in the Power Island Area may result in runoff that contains residual oil and grease, ash material, or coal;
- Oil storage and equipment laydown yard in the Oil Storage Area may result in runoff that contains residual oil and grease, fuels and lubricants;
- Coal piles that are stockpiled and managed at the GCSES may result in coal pile runoff; and
- Coal combustion by-products disposal at the Landfill Cells "A" and "F" may result in runoff that contains residual bottom ash or fly ash material.

7. DOMESTIC SEWAGE, SEWAGE SLUDGE, AND/OR SEPTAGE MANAGEMENT AND DISPOSAL
(Instructions, page 29)

a. Please check the appropriate method(s) of domestic sewage and domestic sewage sludge treatment/disposal and complete Attachment F if directed.

Domestic sewage is not generated on-site. **PROCEED TO ITEM NO. 8.**

Both domestic and industrial treatment sludge **ARE commingled** prior to use or disposal. **PROCEED TO ITEM NO. 8.**

Industrial wastewater and domestic sewage are treated separately and the respective sludge **IS NOT commingled** prior to sludge use or disposal. **COMPLETE WORKSHEET 5.0 OF THIS APPLICATION.**

If your facility is a POTW, **COMPLETE WORKSHEET 5.0 OF THIS APPLICATION.**

Facility is connected to a wastewater treatment plant permitted to receive domestic sewage, or the domestic sewage is transported off-site to a permitted facility for treatment and/or disposal. **COMPLETE ITEM NO. 7.B.**

Domestic sewage is disposed of by an on-site septic tank. **COMPLETE ITEM 7.B.**

Other. Please provide a detailed description below.

The sludge from the on-site wastewater treatment plant is sent to the plant via the hauler as described in 7.B.

b. Provide the name and TCEQ, NPDES, and/or TPDES Permit No. of the waste disposal facility which receives the domestic sewage/septage. If hauled by motorized vehicle, provide the name and TCEQ Registration No. of the hauler.

Plant/Hauler Name	Permit/Registration No.
Waste Disposal Facility: City of Bryan Solid Waste Facility	TX10426-002
Hauler: Chenault Plumbing	20576

8. IMPROVEMENTS OR COMPLIANCE/ENFORCEMENT REQUIREMENTS (Instructions, page 29)

Is the permittee currently required to meet any implementation schedule for compliance or enforcement?

Yes No

If yes, provide a brief summary of the requirements and a status update.

Not Applicable

9. TOXICITY TESTING (Instructions, page 30)

Have any biological tests for acute or chronic toxicity been made on any of your discharges or on a receiving water in relation to your discharge within the last three (3) years?

Yes No

If **yes**, identify the tests and describe their purposes below. Please attach a copy of all tests performed that have not been previously sent to the TCEQ and/or EPA.

See page 10a (next page) for description.

10. OFF-SITE/THIRD PARTY WASTES (Instructions, page 30)

Do you receive wastes from off-site sources for treatment in your facility, disposal on-site via land application, and/or discharge via a permitted outfall? Yes No

If **no**, proceed to Item No. 11. If **yes**, proceed as directed.

a. Indicate with a check mark that a detailed attachment with the following information was provided with the application: **Attachment: Not Applicable**

- | | |
|---|--|
| <input type="checkbox"/> List of wastes received | <input type="checkbox"/> Identified sources of wastes received |
| <input type="checkbox"/> Characterization of wastes received | <input type="checkbox"/> Name and addresses of generators |
| <input type="checkbox"/> Volumes of each waste received | <input type="checkbox"/> Description of the relationship of waste source(s) with your facility's activities. |
| <input type="checkbox"/> Info. on compatibility with on-site wastes | |

b. Is wastewater from a TCEQ, NPDES, and/or TPDES permitted facility commingled with your wastewater after your final treatment and prior to discharge via your final outfall/point of disposal? Yes No
Not Applicable

If **yes**, provide the name, address, and TCEQ, NPDES, and/or TPDES permit number of the contributing facility and a copy of any agreements and/or contracts relating to this activity. **Not Applicable**

c. Is your facility a Publicly Owned Treatment Works (POTW) that accepts process wastewater from any Significant Industrial User (SIU) and has or is required to have an approved pretreatment program under the NPDES/TPDES program? Yes No If **yes**, complete **Worksheet 6.0** of this application.
Not Applicable

11. RADIOACTIVE MATERIALS (Instructions, page 30)

Are radioactive materials mined, used, stored, or processed at this facility? Yes No

If **yes**, Provide a list of the materials and the results of one analysis of your effluent in picocuries per liter (pCi/L) for all radioactive parameters which may be present.

Radioactive Materials	Conc. (pCi/L)
Not Applicable	Not Applicable

Per TMPA's TPDES Permit No. 02120, the following toxicity tests (biomonitoring) are required for Outfall 001 and 004:

- Chronic Biomonitoring Requirements: Freshwater Section, Provision 1b---(1) Chronic static renewal survival and reproduction test for toxicity using the water flea; and (2) Chronic static renewal 7-day larval survival and growth test for toxicity using the fathead minnow.
- 24-hour Acute Biomonitoring Requirements: Freshwater Section, Provision 1b--(1) Acute 24-hr static toxicity test for lethality using the water flea; and (2) Acute 24-hr static toxicity test for lethality using the fathead minnow.

THE FOLLOWING ITEMS ARE ONLY REQUIRED FOR EXISTING PERMITTED FACILITIES.

12. MAJOR AMENDMENT REQUESTS (Instructions, pages 30-31)

Are you requesting a major amendment of an existing permit? Yes No

If yes, list each specific request and provide discussion on the scope of any requested permit changes.

Authorization to Route Water from Ash Ponds as Emergency Cooling Water

On an emergency basis, TMPA is currently authorized to route water from the plant collection pond for use as cooling water in the auxiliary cooling system that discharges through Outfall 004.

To support flexibility to maintain process operations during potential drought conditions, TMPA is requesting to also have authorization on an emergency basis to route water from the ash ponds (that currently discharges through Outfall 001) for use as cooling water in the auxiliary cooling system that discharges through Outfall 004. Although routing of water from the plant collection pond would be TMPA's first option to maintain auxiliary cooling water requirements, TMPA would appreciate the flexibility to have another option available when the plant collection pond volume is low due to drought and other seasonal site conditions.

If necessary, provide supplemental information or additional data that will support the request.

13. MINOR MODIFICATION REQUESTS (Instructions, page 31)

Are you requesting any minor modifications to the permit? Yes No **Note:** see the instructions for an exclusive list of changes considered as minor modifications.

If yes, list and discuss the requested changes.

Remove Outfall 003 from TPDES Permit No. 02120

Outfall 003 has never been utilized for discharge from the GCSES facility. Currently, it remains inactive, and TMPA has no future plans to utilize the outfall. Therefore, TMPA requests to remove the authorization and associated references to discharge via Outfall 003 from the permit.

14. MINOR AMENDMENT REQUESTS (Instructions, page 31)

Are you requesting any minor amendments to the permit? Yes No

If yes, list and discuss the requested changes.

Reactivate Wet Scrubber Operation and Continue Authorized Discharge of Low-Volume Wastewater Through Outfall 001 and 002. TMPA is currently authorized to discharge low-volume wastewater through Outfalls 001 and 002. As defined in the Other Requirements section, Provision 1, of TMPA's existing TPDES Permit No. 02120, low volume wastewater includes wastewater generated by processes such as the boiler blowdown, water purifying and sewage treatment system, and wet scrubber system. TMPA's wet scrubber system operations have been inactive since 1996. The status of the wet scrubber system was documented in TMPA's TPDES 2004- and 2007-dated permit applications. TMPA is currently in the process of reactivating the wet scrubber system, and estimates that the process will be back online by April 2011. Therefore, the currently authorized low volume wastewater that is discharged through Outfalls 001 and 002 will continue to be discharged and once again include wastewater from the wet scrubber system.

**WORKSHEETS
TO THE INDUSTRIAL WASTEWATER PERMIT APPLICATION TECHNICAL REPORT**

Please review the worksheet requirements in the instructions and indicate by checking either yes or no which worksheets are required, completed, and submitted with the technical report. Worksheets that are not applicable do not need to be submitted with the technical report.

WORKSHEET	COMPLETED AND SUBMITTED WITH THE TECHNICAL REPORT:	
	YES	NO
1.0: EPA EFFLUENT CATEGORICAL GUIDELINES	✓	
2.0: POLLUTANT ANALYSES REQUIREMENTS	✓	
3.0: LAND DISPOSAL OF EFFLUENT		✓
3.1: SURFACE LAND DISPOSAL OF EFFLUENT		✓
3.2: SUBSURFACE LAND DISPOSAL OF EFFLUENT		✓
3.3: SUBSURFACE AREA DRIP DISPERSAL SYSTEM LAND DISPOSAL OF EFFLUENT		✓
4.0: RECEIVING WATERS	✓	
4.1: STREAM PHYSICAL CHARACTERISTICS WORKSHEET		✓
5.0: SEWAGE SLUDGE MANAGEMENT AND DISPOSAL		✓
6.0: INDUSTRIAL WASTE CONTRIBUTION		✓
7.0: STORM WATER RUNOFF		✓
8.0: AQUACULTURE		✓
9.0: CLASS V INJECTION WELL		✓
10.0: QUARRIES IN THE JOHN GRAVES SCENIC RIVERWAY		✓

WORKSHEET 1.0 - EPA EFFLUENT CATEGORICAL GUIDELINES

REQUIRED FOR ALL APPLICATIONS FOR TPDES PERMITS FOR DISCHARGES OF WASTEWATERS SUBJECT TO EPA EFFLUENT LIMITATION GUIDELINES.

1. CATEGORICAL INDUSTRIES (Instructions, pages 34-35)

Is your facility subject to any of the 40 CFR effluent guidelines outlined in Table 1? ____ Yes ____ No

If **yes**, provide the appropriate information in the table below. If **no**, this worksheet is not required.

Industry	CFR

2. PRODUCTION/PROCESS DATA (Instructions, page 35)

a. Production data: Provide the appropriate data for effluent guidelines with production based effluent limitations.

Subcategory	Actual Quantity/Day	Design Quantity/Day	Units
Not Applicable - Limitations are not expressed in terms of production.			

b. Organic Chemicals, Plastics, and Synthetic Fibers Manufacturing Data (40 CFR Part 414): Provide each appropriate subpart and the percent of total production. Also provide the appropriate data for metal bearing wastestreams as required in 40 CFR Part 414, Appendices A and B.

Subcategory	% of total production	Appendix A and B	
		Metal	Process

c. **Refineries (40 CFR Part 419):** Provide the applicable subcategory and a brief justification for each.

3. **PROCESS/NON-PROCESS WASTEWATER FLOWS:** Provide a breakdown of process wastewater flow(s) and non-process wastewater flow(s) as directed. (Instructions, page 35)

4. **NEW SOURCE DETERMINATION:** Provide a list of wastewater generating processes subject to effluent guidelines and the appropriate information. (Instructions, page 35)

Process	EPA Guideline		Date Process/Construction Commenced
	Part	Subpart	
*First generated in 2002 from maintenance of units built in 1982.			

WORKSHEET 2.0 - POLLUTANT ANALYSES REQUIREMENTS

REQUIRED FOR APPLICATIONS SUBMITTED FOR A TPDES PERMIT. NOT REQUIRED FOR APPLICATIONS FOR A PERMIT TO DISPOSE OF ALL WASTEWATER BY LAND DISPOSAL OR FOR DISCHARGES SOLELY OF STORM WATER RUNOFF. (General Requirements: Instructions, Pages 36-37)

1. **TABLE 1:** Complete table required for all external outfalls. (Instructions, Page 37)

Outfall No.: 001	<input type="checkbox"/> C <input checked="" type="checkbox"/> G	Effluent Concentration (mg/l)				
		Samp.	Samp.	Samp.	Samp.	Average
BOD (5-day)		Estimated Concentration Following Reactivation of Scrubber System				1.4
CBOD (5-day)						2.1
Chemical Oxygen Demand						15.8
Total Organic Carbon						3.3
Dissolved Oxygen						6.5
Ammonia Nitrogen						<0.1
Total Suspended Solids						9
Nitrate Nitrogen						20
Total Organic Nitrogen						0.7
Total Phosphorus						<0.5
Oil and Grease						<5
Total Residual Chlorine						<0.1
Total Dissolved Solids						3,000
Sulfate						600
Chloride						900
Fluoride		800				
Fecal Coliform		2				
Temperature (°F)		86.8				
pH (Standard Units; min/max)		7				

	Effluent Concentration (µg/l)		MAL (µg/l)
Total Aluminum	Estimated Concentration Following Reactivation of Scrubber System		1405
Total Antimony			<60
Total Arsenic			10
Total Barium			170
Total Beryllium			<5
Total Cadmium			<1
Total Chromium			<10
Trivalent Chromium			<10
Hexavalent Chromium			<10
Total Copper			<10
Cyanide			<20
Total Lead			10
Total Mercury			<0.2
Total Nickel			<10
Total Selenium			10
Total Silver			2
Total Thallium			<10
Total Zinc			<5

2. **TABLE 2:** Complete table required for all external outfalls which discharge process wastewater. Partial table required for all external outfalls with nonprocess wastewater discharges. Storm water runoff discharges commingled with other wastestreams shall complete the table as instructed (Instructions, Page 37).

Outfall No.: 001	C <input type="checkbox"/> G <input checked="" type="checkbox"/>		Effluent Concentration (µg/l) (*1)				
Pollutants	Samp. 1	Samp. 2	Samp. 3.	Samp. 4	Average	MAL (µg/l)	
Benzene	Estimated Concentration Following Reactivation of Scrubber System				<1	10	
Benzidine					<21	50	
Benzo(a)anthracene					6.5	10	
Benzo(a)pyrene					6.5	10	
Carbon Tetrachloride					<1	10	
Chlorobenzene					<1	10	
Chloroform					<1	10	
Chrysene					6.5	10	
Cresols					6.5	(*2)	
Dibromochloromethane					<10	10	
1,2-Dibromoethane					<1	2	
1,4-Dichlorobenzene					<1	10	
1,2-Dichloroethane					<1	10	
1,1-Dichloroethylene					<1	10	
Fluoride					800	500	
Hexachlorobenzene					6.5	10	
Hexachlorobutadiene					6.5	10	
Hexachloroethane					6.5	20	
Methyl Ethyl Ketone					<20	50	
Nitrobenzene					6.5	10	
n-Nitrosodiethylamine					6.5	20	
n-Nitroso-di-n-Butylamine					6.5	20	
PCB's, Total (*3)					<1	1	
Pentachlorobenzene					6.5	20	
Pentachlorophenol					45.3	50	
Phenanthrene					6.5	10	
Pyridine					12.8	20	
1,2,4,5-Tetrachlorobenzene					12.8	20	
Tetrachloroethylene					<1	10	
Trichloroethylene					<1	10	
1,1,1-Trichloroethane					<1	10	
2,4,5-Trichlorophenol					6.5	50	
TTHM (Total Trihalomethanes)					20.2	10	
Vinyl Chloride					<1	10	

(*1) Indicates units if different from µg/l.

(*2) MAL's for Cresols: p-Chloro-m-Creso 10 µg/l; 4,6-Dinitro-o-Cresol 50 µg/l; p-Cresol 10 µg/l.

(*3) Total PCB-1242, PCB-1254, PCB-1221, PCB-1232, PCB-1248, PCB-1260, PCB-1016.

a. LABORATORY ACCREDITATION:

Effective July 1, 2008, all laboratory tests performed must meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification with the following general exemptions:

- i. The laboratory is an in-house laboratory and is:
 - 1. periodically inspected by the TCEQ; or
 - 2. located in another state and is accredited or inspected by that state; or
 - 3. performing work for another company with a unit located in the same site; or
 - 4. performing pro bono work for a governmental agency or charitable organization.
- ii. The laboratory is accredited under federal law.
- iii. The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- iv. The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements. The following certification statement shall be signed and submitted with every application. See Instructions, Page 20, for a list of designated representatives who may sign the certification.

I, _____ Certify that all laboratory tests submitted with this application meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

3. TABLE 3: Partial table (only those pollutants which are required by the conditions specified) required for each external outfall. Not required for internal outfalls. (Instructions, Page 38)

a. TRIBUTYLTIN:

Is your facility or will your proposed facility be an industrial/commercial facilities which directly disposes of wastewater from the types of operations listed below or a domestic facilities which receive wastewater from the types of industrial/commercial operations listed below? _____ Yes No

If yes, indicate with a check mark all of the following criteria which apply and provide the appropriate testing results in the table below.

- _____ Manufacturers and formulators of tributyltin or related compounds.
- _____ Painting of ships, boats and marine structures.
- _____ Ship and boat building and repairing.
- _____ Ship and boat cleaning, salvage, wrecking and scaling.
- _____ Operation and maintenance of marine cargo handling facilities and marinas
- _____ Facilities engaged in wood preserving
- _____ Any other industrial/commercial facility for which tributyltin is known to be present, or for which there is any reason to believe that tributyltin may be present in the effluent.

b. ENTEROCOCCI

Does your facility or will your proposed facility discharge directly into saltwater receiving waters? _____ Yes No

If yes, provide the appropriate testing results in the table below.

TABLE 3

Outfall No.:	<input type="checkbox"/> C <input type="checkbox"/> G	Effluent Concentration (µg/l)					MAL (µg/l)
		Samp. 1	Samp. 2	Samp. 3	Samp. 4	Average	
Pollutants		Not Applicable					
Tributyltin							0.010
Enterococci							N/A

4. **TABLE 4:** Complete table required for all external outfalls which discharge process wastewater and other wastewaters, which may contain pesticides or herbicides, from a facility which manufactures or formulates pesticides or herbicides. Not required for internal outfalls. (Instructions, Page 38)

Does your facility manufacture or formulate pesticides or herbicides? ____ Yes No
 If yes, provide the appropriate testing results.

TABLE 4

Outfall No.: 001	<input type="checkbox"/> C <input type="checkbox"/> G	Effluent Concentration (µg/l) (*1)					MAL (µg/l)
		Samp. 1	Samp. 2	Samp. 3	Samp. 4	Avg.	
Beta-hexachlorocyclohexane		Not Applicable					0.05
Carbaryl							5
Chlordane							0.15
Chlorpyrifos							0.05
2,4-D							10
Danitol							----
4,4'-DDD							0.1
4,4'-DDE							0.1
4,4'-DDT							0.1
Demeton							0.2
Diazinon							0.5
Dicofol							20
Dieldrin							0.1
Diuron							0.09
Endosulfan I (alpha)							0.1
Endosulfan II (beta)							0.1
Endosulfan Sulfate							0.1
Endrin							0.1
Gamma - Hexachlorocyclohexane (Lindane)							0.05
Guthion							0.10
Heptachlor							0.05
Heptachlor Epoxide							1.0
Hexachlorophene							10
Malathion							0.10
Methoxychlor							2.0
Mirex							0.2
Parathion							0.1
Toxaphene							5
2,4,5-TP (Silvex)		2					

* Indicate units if different from mg/L.

5. **TABLE 5:** Complete table required for all external outfalls. Not required for internal outfalls.
(Instructions, Page 38)

TABLE 5

Outfall No.: 001	<input type="checkbox"/> C <input type="checkbox"/> G	Believed Present	Believed Absent	Effluent Concentration (mg/l)		No. of Samples
				Average	Maximum	
Bromide	x		1.27	1.3	Estimated	
Color(PCU)	x		10.6	15		
Nitrate-Nitrite(as N)	x		<0.09	0.2		
Sulfide(as S)	x		0.75	1		
Sulfite(as SO ₃)	x		<2	<2		
Surfactants	x		0.060	0.090		
Total Antimony	x		<0.06	<0.06		
Total Beryllium	x		<0.005	<0.005		
Total Boron	x		5.93	6.04		
Total Cobalt	x		<0.02	<0.02		
Total Iron	x		<0.05	<0.05		
Total Magnesium	x		13	13		
Total Molybdenum	x		<0.05	<0.05		
Total Manganese	x		0.045	0.06		
Total Thallium	x		<0.01	<0.01		
Total Tin	x		<0.02	<0.02		
Total Titanium	x		<0.01	<0.01		

6. **TABLE 6:** Indicate with a check mark any of the industrial categories applicable to your facility. If testing is required, indicate with a check mark in the box provided that the testing results for the appropriate parameters in Table B-7 are provided with the application. (Instructions, Page 39)

N/A	GC/MS Testing Required			
	<u>Volatile</u>	<u>Acid</u>	<u>Base/Neutral</u>	<u>Pesticides</u>
_____ Adhesives and Sealants	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Aluminum Forming	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Auto and Other Laundries	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Battery Manufacturing	Yes <input type="checkbox"/>	No	Yes <input type="checkbox"/>	No
_____ Coal Mining	No	No	No	No
_____ Coil Coating	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Copper Forming	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Electric and Electronic Components	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Electroplating	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Explosives Manufacturing	No	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Foundries	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Gum and Wood Chemicals				
_____ Subparts A,B,C,E	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No	No
_____ Subparts D,F	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Inorganic Chemicals	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Iron and Steel Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Leather Tanning/Finishing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Mechanical Products Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Nonferrous Metals Mfg.	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Ore Mining(Subpart B)	No	Yes <input type="checkbox"/>	No	No
_____ Organic Chemicals, Plastics, and Synthetic Fibers	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Paint and Ink Formulation	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Pesticides	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Petroleum Refining	Yes <input type="checkbox"/>	No	No	No
_____ Pharmaceutical Preparations	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Photographic Equipment and Supplies	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Plastic and Synthetic Materials Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Plastic Processing	Yes <input type="checkbox"/>	No	No	No
_____ Porcelain Enameling	No	No	No	No
_____ Printing and Publishing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Pulp and Paperboard Mills				
_____ Subparts A	* <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Subparts B,C,D,R	* <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	* <input type="checkbox"/>
_____ Subparts F,G,H,I,K,L,M,N,O,P	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	* <input type="checkbox"/>
_____ Subparts E,Q,S,T	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Subparts J,U	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>
_____ Rubber Processing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Soap and Detergent Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
✓ _____ Steam Electric Power Plants	Yes <input checked="" type="checkbox"/>	Yes <input checked="" type="checkbox"/>	No	No
_____ Textile Mills (Not Subpart C)	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Timber Products Processing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>

* Test if "believed present"

TABLE 7: Please complete as directed and only for those parameters specified in Table 6. Required for all external outfalls which contain process wastewater. Not required for internal outfalls. Testing may be required for types of industry not specified in Table 6 for specific parameters if believed present (Instructions, Page 39).

TABLE 7

Outfall No.: 001 <input type="checkbox"/> C <input checked="" type="checkbox"/> G		Effluent Concentration (µg/l)*		
Pollutants	Average	Maximum	No. of Samples	MAL (µg/l)
VOLATILE COMPOUNDS				
Acrolein	<20	<20	Estimated	50
Acrylonitrile	<20	<20		50
Benzene	<1	<1		10
Bromoform	<0.5	<1		10
Carbon Tetrachloride	<1	<1		10
Chlorobenzene	<1	<1		10
Chlorodibromomethane	<0.5	<1		10
Chloroethane	<1	<1		50
2-Chloroethylvinyl Ether	<1	<1		10
Chloroform	<1	<1		10
Dichlorobromomethane	<1	<1		10
1,1-Dichloroethane	<1	<1		10
1,2-Dichloroethane	<1	<1		10
1,1-Dichloroethylene	<1	<1		10
1,2-Dichloropropane	<1	<1		10
1,3-Dichloropropylene	<1	<1		10
Ethylbenzene	<1	<1		10
Methyl Bromide	<1	<1		50
Methyl Chloride	<1	<1		50
Methylene Chloride	<1	<1		20
1,1,2,2-Tetrachloroethane	<1	<1		10
Tetrachloroethylene	<1	<1		10
Toluene	<1	<1		10
1,2-Trans-Dichloroethylene	<1	<1		10
1,1,1-Trichloroethane	<1	<1		10
1,1,2-Trichloroethane	<1	<1	10	
Trichloroethylene	<1	<1	10	
Vinyl Chloride	<1	<1	10	

Outfall No.: 001	Effluent Concentration (µg/l)*			MAL (µg/l)	
	Pollutants	Average	Maximum		No. of Samples
ACID COMPOUNDS					
2-Chlorophenol	6.5	<11	Estimated	10	
2,4-Dichlorophenol	6.5	<11		10	
2,4-Dimethylphenol	<10	<10		10	
4,6-Dinitro-o-Cresol	45	<53		50	
2,4-Dinitrophenol	45	<53		50	
2-Nitrophenol	6.5	<11		20	
4-Nitrophenol	45	<53		50	
P-Chloro-m-Cresol	6.5	<11		10	
Pentalchlorophenol	45	<53		50	
Phenol	6.5	<11		10	
2,4,6-Trichlorophenol	6.5	<11		10	
BASE/NEUTRAL COMPOUNDS					
Acenaphthene	Not Applicable			10	
Acenaphthylene				10	
Anthracene				10	
Benzidine				50	
Benzo(a)Anthracene				10	
Benzo(a)Pyrene				10	
3,4-Benzofluoranthene				10	
Benzo(ghi)Perylene				20	
Benzo(k)Fluoranthene				10	
Bis(2-Chloroethoxy)Methane				10	
Bis(2-Chloroethyl)Ether				10	
Bis(2-Chloroisopropyl)Ether				10	
Bis(2-Ethylhexyl)Phthalate				10	
4-Bromophenyl Phenyl Ether				10	
Butylbenzyl Phthalate				10	
2-chloronaphthalene				10	
4-chlorophenyl phenyl ether				10	
Chrysene				10	
Dibenzo(a,h)Anthracene				20	
1,2-Dichlorobenzene				10	
1,3-Dichlorobenzene				10	
1,4-Dichlorobenzene				10	
3,3-Dichlorobenzidine				50	
Diethyl Phthalate				10	
Dimethyl Phthalate				10	
Di-n-Butyl Phthalate				10	
2,4-Dinitrotoluene				10	

Pollutants	Effluent Concentration (µg/l)*			MAL (µg/l)
	Average	Maximum	No. of Samples	
BASE/NEUTRAL COMPOUNDS (cont.)				
2,6-Dinitrofluorene	Not Applicable			10
Di-n-Octyl Phthalate				10
1,2-Diphenyl Hydrazine (as Azobenzene)				20
Fluoranthene				10
Fluorene				10
Hexachlorobenzene				10
Hexachlorobutadiene				10
Hexachlorocyclopentadiene				10
Hexachloroethane				20
Indeno(1,2,3-cd)pyrene				20
Isophorone				10
Naphthalene				10
Nitrobenzene				10
N-Nitrosodimethylamine				50
N-Nitrosodi-n-Propylamine				20
N-Nitrosodiphenylamine				20
Phenanthrene				10
Pyrene				10
1,2,4-Trichlorobenzene				10
PESTICIDES				
Aldrin	Not Applicable			0.05
alpha-BHC				0.05
beta-BHC				0.05
gamma-BHC				0.05
delta-BHC				0.05
Chlordane				0.15
4,4-DDT				0.1
4,4-DDE				0.1
Dieldrin				0.1
alpha-Endosulfan				0.1
beta-Endosulfan				0.1
Endosulfan Sulfate				0.1
Endrin				0.1
Endrin Aldehyde				0.1
Heptachlor				0.05

Pollutants	Effluent Concentration (µg/l)*			MAL (µg/l)
	Average	Maximum	No. of Samples	
PESTICIDES (cont.)				
Heptachlor Epoxide	Not Applicable			
PCB-1254				1.0
PCB-1221				1.0
PCB-1242				
PCB-1232				1.0
PCB-1248				1.0
PCB-1260				1.0
PCB-1016				1.0
Toxaphene				5.0

* Indicate units if different from µg/l

8. TABLE 8 (DIOXINS/FURAN COMPOUNDS): Please complete as directed. Not required for internal outfalls. (Instructions, Pages 39-40)

a. Are any of the following compounds manufactured and/or used in a process at the facility? Yes No

If **yes**, indicate with a check mark the compound(s) which apply and provide a brief description of the conditions of its/their presence at the facility.

- 2,4,5-trichlorophenoxy acetic acid (2,4,5-T) CAS #93-76-5
- 2-(2,4,5-trichlorophenoxy) propanoic acid (Silvex, 2,4,5-TP) CAS #93-72-1
- 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate (Erbon) CAS #136-25-4
- 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothioate (Ronnel) CAS #299-84-3
- 2,4,5-trichlorophenol (TCP) CAS #95-95-4
- Hexachlorophene (HCP) CAS #70-30-4

Not Applicable

b. Do you know or have any reason to believe that 2,3,7,8 Tetrachlorodibenzo-P-Dioxin (TCDD) or any congeners of TCDD may be present in your effluent? Yes No

If **yes**, provide a brief description of the conditions for its presence.

Not Applicable

c. If your responded **yes** to either item a or b, complete **Table 8** as instructed.

TABLE 8

Outfall	<input type="checkbox"/> C <input type="checkbox"/> G	Wastewater		Sludge		MAL (ppq)
	Equivalent Factors	Concentration (ppq)	Equivalents (ppq)	Concentration (ppt)	Equivalents (ppt)	
2,3,7,8-TCDD	1	Not Applicable				10.0
1,2,3,7,8-PeCDD	0.5			50.0		
2,3,7,8-HxCDDs	0.1			50.0		
2,3,7,8-TCDF	0.1			10.0		
1,2,3,7,8-PeCDF	0.05			50.0		
2,3,4,7,8-PeCDF	0.5			50.0		
2,3,7,8-HxCDFs	0.1			50.0		
Total						

9. **TABLE 9 (HAZARDOUS SUBSTANCES):** Proceed complete as directed. Not required for internal outfalls. (Instructions, Pages 41)

a. Are there any pollutants listed in the instructions (page 41) believed present in the discharge?
 _____ Yes No

b. Are there pollutants listed in Item No. 1.d. on Page No. 1 of this technical report which are believed present in the discharge and have not been analytically quantified elsewhere in this application? _____ Yes No

If your responded **yes** to either item, complete **Table 9** as instructed.

TABLE 9

Pollutant & CAS Number	Average (µg/l)	Maximum (µg/l)	No. of Samples	Analytical Method
Not Applicable				

WORKSHEET 2.0 - POLLUTANT ANALYSES REQUIREMENTS

REQUIRED FOR APPLICATIONS SUBMITTED FOR A TPDES PERMIT. NOT REQUIRED FOR APPLICATIONS FOR A PERMIT TO DISPOSE OF ALL WASTEWATER BY LAND DISPOSAL OR FOR DISCHARGES SOLELY OF STORM WATER RUNOFF. (General Requirements: Instructions, Pages 36-37)

1. TABLE 1: Complete table required for all external outfalls. (Instructions, Page 37)

Outfall No.: 001	<input type="checkbox"/> C <input checked="" type="checkbox"/> G	Effluent Concentration (mg/l)				
Pollutants	Samp.	Samp.	Samp.	Samp.	Average	
BOD (5-day)	<2	2	2	<1	1.4	
CBOD (5-day)	<2	<1	2	<1	1	
Chemical Oxygen Demand	10	18	22	13	15.8	
Total Organic Carbon	3.3	3.1	3.3	3.3	3.3	
Dissolved Oxygen	7.2	8.1	4.8	6.0	6.5	
Ammonia Nitrogen	<0.1	<0.1	<0.1	<0.1	<0.1	
Total Suspended Solids	8	10	11	7	9	
Nitrate Nitrogen	0.2	<0.1	0.1	<0.1	0.1	
Total Organic Nitrogen	0.6	0.7	0.7	0.6	0.7	
Total Phosphorus	<0.5	<0.5	<0.5	<0.5	<0.5	
Oil and Grease	<5	<5	<5	<5	<5	
Total Residual Chlorine	<0.1	<0.1	<0.1	<0.1	<0.1	
Total Dissolved Solids	1040	1040	1060	1070	1053	
Sulfate	485	485	453	484	477	
Chloride	153	150	142	149	149	
Fluoride	0.8	0.8	0.8	0.8	0.8	
Fecal Coliform	5	<1	<1	2	2	
Temperature (°F)	89.8	86.7	87.1	83.7	86.8	
pH (Standard Units; min/max)	8.5	8.6	8.6	8.8	8.6	

	Effluent Concentration (µg/l)					MAL (µg/l)
Total Aluminum	1160	1400	1220	1840	1405	30
Total Antimony	<60	<60	<60	<60	<60	30
Total Arsenic	<10	<10	<10	<10	<10	10
Total Barium	160	170	170	180	170	10
Total Beryllium	<5	<5	<5	<5	<5	5
Total Cadmium	<1	<1	<1	<1	<1	1
Total Chromium	<10	<10	<10	<10	<10	10
Trivalent Chromium	<10	<10	<10	<10	<10	N/A
Hexavalent Chromium	<10	<10	<10	<10	<10	10
Total Copper	<10	<10	<10	<10	<10	10
Cyanide	<20	<20	<20	<20	<20	20
Total Lead	<5	<5	<5	<5	<5	5
Total Mercury	<0.2	<0.2	<0.2	<0.2	<0.2	0.2
Total Nickel	<10	<10	<10	<10	<10	10
Total Selenium	<10	<10	<10	<10	<10	10
Total Silver	<2	<2	3	3	2	2.0
Total Thallium	<10	<10	<10	<10	<10	10
Total Zinc	<5	<5	<5	<5	<5	5

2. **TABLE 2:** Complete table required for all external outfalls which discharge process wastewater. Partial table required for all external outfalls with nonprocess wastewater discharges. Storm water runoff discharges commingled with other wastestreams shall complete the table as instructed (Instructions, Page 37).

Outfall No.: 001	C <input type="checkbox"/> G <input checked="" type="checkbox"/>		Effluent Concentration (µg/l) (*1)				
Pollutants	Samp. 1	Samp. 2	Samp 3.	Samp. 4	Average	MAL (µg/l)	
Benzene	<1	<1	<1	<1	<1	10	
Benzidine	<21	<20	<21	<20	<21	50	
Benzo(a)anthracene	<10	<10	<11	<10	6.5	10	
Benzo(a)pyrene	<10	<10	<11	<10	6.5	10	
Carbon Tetrachloride	<1	<1	<1	<1	<1	10	
Chlorobenzene	<1	<1	<1	<1	<1	10	
Chloroform	<1	<0.5	<1	<1	<1	10	
Chrysene	<10	<10	<11	<10	6.5	10	
Cresols	<10	<10	<11	<10	6.5	(*2)	
Dibromochloromethane	<1	<0.5	<1	<10	<10	10	
1,2-Dibromoethane	<1	<1	<1	<1	<1	2	
1,4-Dichlorobenzene	<1	<1	<1	<1	<1	10	
1,2-Dichloroethane	<1	<1	<1	<1	<1	10	
1,1-Dichloroethylene	<1	<1	<1	<1	<1	10	
Fluoride	800	800	800	800	800	500	
Hexachlorobenzene	<10	<10	<11	<10	6.5	10	
Hexachlorobutadiene	<10	<10	<11	<10	6.5	10	
Hexachloroethane	<10	<10	<11	<10	6.5	20	
Methyl Ethyl Ketone	<20	<20	<20	<20	<20	50	
Nitrobenzene	<10	<10	<11	<10	6.5	10	
n-Nitrosodiethylamine	<10	<10	<11	<10	6.5	20	
n-Nitroso-di-n-Butylamine	<10	<10	<11	<10	6.5	20	
PCB's, Total (*3)	<1	<1	<1	<1	<1	1	
Pentachlorobenzene	<10	<11	<10	<10	6.5	20	
Pentachlorophenol	<52	<51	<53	<50	45.3	50	
Phenanthrene	<10	<10	<11	<10	6.5	10	
Pyridine	<21	<20	<21	<20	12.8	20	
1,2,4,5-Tetrachlorobenzene	<21	<20	<21	<20	12.8	20	
Tetrachloroethylene	<1	<1	<1	<1	<1	10	
Trichloroethylene	<1	<1	<1	<1	<1	10	
1,1,1-Trichloroethane	<1	<1	<1	<1	<1	10	
2,4,5-Trichlorophenol	<10	<10	<11	<10	6.5	50	
TTHM (Total Trihalmethanes)	<80	0.2	0.3	0.3	20.2	10	
Vinyl Chloride	<1	<1	<1	<1	<1	10	

(*1) Indicates units if different from µg/l.

(*2) MAL's for Cresols: p-Chloro-m-Creso 10 µg/l; 4,6-Dinitro-o-Cresol 50 µg/l; p-Cresol 10 µg/l.

(*3) Total PCB-1242, PCB-1254, PCB-1221, PCB-1232, PCB-1248, PCB-1260, PCB-1016.

a. LABORATORY ACCREDITATION:

Effective July 1, 2008, all laboratory tests performed must meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification with the following general exemptions:

- i. The laboratory is an in-house laboratory and is:
 - 1. periodically inspected by the TCEQ; or
 - 2. located in another state and is accredited or inspected by that state; or
 - 3. performing work for another company with a unit located in the same site; or
 - 4. performing pro bono work for a governmental agency or charitable organization.
- ii. The laboratory is accredited under federal law.
- iii. The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- iv. The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements. The following certification statement shall be signed and submitted with every application. See Instructions, Page 20, for a list of designated representatives who may sign the certification.

I, _____ Certify that all laboratory tests submitted with this application meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

3. TABLE 3: Partial table (only those pollutants which are required by the conditions specified) required for each external outfall. Not required for internal outfalls. (Instructions, Page 38)

a. TRIBUTYLTIN:

Is your facility or will your proposed facility be an industrial/commercial facilities which directly disposes of wastewater from the types of operations listed below or a domestic facilities which receive wastewater from the types of industrial/commercial operations listed below? _____ Yes No

If yes, indicate with a check mark all of the following criteria which apply and provide the appropriate testing results in the table below.

- _____ Manufacturers and formulators of tributyltin or related compounds.
- _____ Painting of ships, boats and marine structures.
- _____ Ship and boat building and repairing.
- _____ Ship and boat cleaning, salvage, wrecking and scaling.
- _____ Operation and maintenance of marine cargo handling facilities and marinas
- _____ Facilities engaged in wood preserving
- _____ Any other industrial/commercial facility for which tributyltin is known to be present, or for which there is any reason to believe that tributyltin may be present in the effluent.

b. ENTEROCOCCI

Does your facility or will your proposed facility discharge directly into saltwater receiving waters? _____ Yes No

If yes, provide the appropriate testing results in the table below.

TABLE 3

Outfall No.:	<input type="checkbox"/> C <input type="checkbox"/> G	Effluent Concentration (µg/l)					MAL (µg/l)
		Samp. 1	Samp. 2	Samp. 3	Samp. 4	Average	
Pollutants		Not Applicable					
Tributyltin							0.010
Enterococci							N/A

4. **TABLE 4:** Complete table required for all external outfalls which discharge process wastewater and other wastewaters, which may contain pesticides or herbicides, from a facility which manufactures or formulates pesticides or herbicides. Not required for internal outfalls. (Instructions, Page 38)

Does your facility manufacture or formulate pesticides or herbicides? ____ Yes No
 If yes, provide the appropriate testing results.

TABLE 4

Outfall No.: 001	<input type="checkbox"/> C <input type="checkbox"/> G	Effluent Concentration (µg/l) (*1)					MAL (µg/l)
		Samp. 1	Samp. 2	Samp. 3	Samp. 4	Avg.	
Beta-hexachlorocyclohexane		Not Applicable					0.05
Carbaryl							5
Chlordane							0.15
Chlorpyrifos							0.05
2,4-D							10
Danitol							----
4,4'-DDD							0.1
4,4'-DDE							0.1
4,4'-DDT							0.1
Demeton							0.2
Diazinon							0.5
Dicofol							20
Dieldrin							0.1
Diuron							0.09
Endosulfan I (alpha)							0.1
Endosulfan II (beta)							0.1
Endosulfan Sulfate							0.1
Endrin							0.1
Gamma - Hexachlorocyclohexane (Lindane)							0.05
Guthion							0.10
Heptachlor							0.05
Heptachlor Epoxide							1.0
Hexachlorophene							10
Malathion							0.10
Methoxychlor							2.0
Mirex							0.2
Parathion							0.1
Toxaphene							5
2,4,5-TP (Silvex)		2					

* Indicate units if different from mg/L.

5. **TABLE 5:** Complete table required for all external outfalls. Not required for internal outfalls.
(Instructions, Page 38)

TABLE 5

Outfall No.: 001	<input type="checkbox"/> C <input type="checkbox"/> G	Believed Present	Believed Absent	Effluent Concentration (mg/l)		No. of Samples
				Average	Maximum	
Pollutants						
Bromide		x		1.27	1.3	4
Color(PCU)		x		10.6	15	4
Nitrate-Nitrite(as N)		x		0.09	0.2	4
Sulfide(as S)		x		0.75	1	4
Sulfite(as SO ₃)		x		<2	<2	4
Surfactants		x		0.060	0.090	4
Total Antimony		x		<0.06	<0.06	4
Total Beryllium		x		<0.005	<0.005	4
Total Boron		x		5.93	6.04	4
Total Cobalt		x		<0.02	<0.02	4
Total Iron		x		<0.05	<0.05	4
Total Magnesium		x		13	13	4
Total Molybdenum		x		<0.05	<0.05	4
Total Manganese		x		0.045	.06	4
Total Thallium		x		<0.01	<0.01	4
Total Tin		x		<0.02	<0.02	4
Total Titanium		x		<0.01	<0.01	4

6. **TABLE 6:** Indicate with a check mark any of the industrial categories applicable to your facility. If testing is required, indicate with a check mark in the box provided that the testing results for the appropriate parameters in Table B-7 are provided with the application. (Instructions, Page 39)

	<u>GC/MS Testing Required</u>			
	<u>Volatile</u>	<u>Acid</u>	<u>Base/Neutral</u>	<u>Pesticides</u>
____ N/A				
____ Adhesives and Sealants	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Aluminum Forming	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Auto and Other Laundries	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
____ Battery Manufacturing	Yes <input type="checkbox"/>	No	Yes <input type="checkbox"/>	No
____ Coal Mining	No	No	No	No
____ Coil Coating	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Copper Forming	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Electric and Electronic Components	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
____ Electroplating	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Explosives Manufacturing	No	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Foundries	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Gum and Wood Chemicals				
____ Subparts A,B,C,E	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No	No
____ Subparts D,F	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Inorganic Chemicals	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Iron and Steel Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Leather Tanning/Finishing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Mechanical Products Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Nonferrous Metals Mfg.	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
____ Ore Mining(Subpart B)	No	Yes <input type="checkbox"/>	No	No
____ Organic Chemicals, Plastics, and Synthetic Fibers	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
____ Paint and Ink Formulation	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Pesticides	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
____ Petroleum Refining	Yes <input type="checkbox"/>	No	No	No
____ Pharmaceutical Preparations	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Photographic Equipment and Supplies	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Plastic and Synthetic Materials Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
____ Plastic Processing	Yes <input type="checkbox"/>	No	No	No
____ Porcelain Enameling	No	No	No	No
____ Printing and Publishing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
____ Pulp and Paperboard Mills				
____ Subparts A	* <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	Yes <input type="checkbox"/>
____ Subparts B,C,D,R	* <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	* <input type="checkbox"/>
____ Subparts F,G,H,I,K,L,M,N,O,P	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	* <input type="checkbox"/>
____ Subparts E,Q,S,T	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	Yes <input type="checkbox"/>
____ Subparts J,U	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>
____ Rubber Processing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Soap and Detergent Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
✓ Steam Electric Power Plants	Yes <input checked="" type="checkbox"/>	Yes <input checked="" type="checkbox"/>	No	No
____ Textile Mills (Not Subpart C)	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
____ Timber Products Processing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>

* Test if "believed present"

TABLE 7: Please complete as directed and only for those parameters specified in Table 6. Required for all external outfalls which contain process wastewater. Not required for internal outfalls. Testing may be required for types of industry not specified in Table 6 for specific parameters if believed present (Instructions, Page 39).

TABLE 7

Outfall No.: <u>001</u> <input type="checkbox"/> C <input checked="" type="checkbox"/> G		Effluent Concentration (µg/l)*		
Pollutants	Average	Maximum	No. of Samples	MAL (µg/l)
VOLATILE COMPOUNDS				
Acrolein	<20	<20	4	50
Acrylonitrile	<20	<20	4	50
Benzene	<1	<1	4	10
Bromoform	<0.5	<1	4	10
Carbon Tetrachloride	<1	<1	4	10
Chlorobenzene	<1	<1	4	10
Chlorodibromomethane	<0.5	<1	4	10
Chloroethane	<1	<1	4	50
2-Chloroethylvinyl Ether	<1	<1	4	10
Chloroform	<1	<1	4	10
Dichlorobromomethane	<1	<1	4	10
1,1-Dichloroethane	<1	<1	4	10
1,2-Dichloroethane	<1	<1	4	10
1,1-Dichloroethylene	<1	<1	4	10
1,2-Dichloropropane	<1	<1	4	10
1,3-Dichloropropylene	<1	<1	4	10
Ethylbenzene	<1	<1	4	10
Methyl Bromide	<1	<1	4	50
Methyl Chloride	<1	<1	4	50
Methylene Chloride	<1	<1	4	20
1,1,2,2-Tetrachloroethane	<1	<1	4	10
Tetrachloroethylene	<1	<1	4	10
Toluene	<1	<1	4	10
1,2-Trans-Dichloroethylene	<1	<1	4	10
1,1,1-Trichloroethane	<1	<1	4	10
1,1,2-Trichloroethane	<1	<1	4	10
Trichloroethylene	<1	<1	4	10
Vinyl Chloride	<1	<1	4	10

Outfall No.: 001	Effluent Concentration (µg/l)*			MAL (µg/l)
	Pollutants	Average	Maximum	
ACID COMPOUNDS				
2-Chlorophenol	6.5	<11	4	10
2,4-Dichlorophenol	6.5	<11	4	10
2,4-Dimethylphenol	<10	<10	4	10
4,6-Dinitro-o-Cresol	45	<53	4	50
2,4-Dinitrophenol	45	<53	4	50
2-Nitrophenol	6.5	<11	4	20
4-Nitrophenol	45	<53	4	50
P-Chloro-m-Cresol	6.5	<11	4	10
Pentalchlorophenol	45	<53	4	50
Phenol	6.5	<11	4	10
2,4,6-Trichlorophenol	6.5	<11	4	10
BASE/NEUTRAL COMPOUNDS				
Acenaphthene	Not Applicable			10
Acenaphthylene				10
Anthracene				10
Benzidine				50
Benzo(a)Anthracene				10
Benzo(a)Pyrene				10
3,4-Benzofluoranthene				10
Benzo(ghi)Perylene				20
Benzo(k)Fluoranthene				10
Bis(2-Chloroethoxy)Methane				10
Bis(2-Chloroethyl)Ether				10
Bis(2-Chloroisopropyl)Ether				10
Bis(2-Ethylhexyl)Phthalate				10
4-Bromophenyl Phenyl Ether				10
Butylbenzyl Phthalate				10
2-chloronaphthalene				10
4-chlorophenyl phenyl ether				10
Chrysene				10
Dibenzo(a,h)Anthracene				20
1,2-Dichlorobenzene				10
1,3-Dichlorobenzene				10
1,4-Dichlorobenzene				10
3,3-Dichlorobenzidine				50
Diethyl Phthalate				10
Dimethyl Phthalate				10
Di-n-Butyl Phthalate				10
2,4-Dinitrotoluene				10

Pollutants	Effluent Concentration (µg/l)*			MAL (µg/l)
	Average	Maximum	No. of Samples	
BASE/NEUTRAL COMPOUNDS (cont.)				
2,6-Dinitroluene	Not Applicable			10
Di-n-Octyl Phthalate				10
1,2-Diphenyl Hydrazine (as Azobenzene)				20
Fluoranthene				10
Fluorene				10
Hexachlorobenzene				10
Hexachlorobutadiene				10
Hexachlorocyclopentadiene				10
Hexachloroethane				20
Indeno(1,2,3-cd)pyrene				20
Isophorone				10
Naphthalene				10
Nitrobenzene				10
N-Nitrosodimethylamine				50
N-Nitrosodi-n-Propylamine				20
N-Nitrosodiphenylamine				20
Phenanthrene				10
Pyrene				10
1,2,4-Trichlorobenzene				10
PESTICIDES				
Aldrin	Not Applicable			0.05
alpha-BHC				0.05
beta-BHC				0.05
gamma-BHC				0.05
delta-BHC				0.05
Chlordane				0.15
4,4-DDT				0.1
4,4-DDE				0.1
Dieldrin				0.1
alpha-Endosulfan				0.1
beta-Endosulfan				0.1
Endosulfan Sulfate				0.1
Endrin				0.1
Endrin Aldehyde				0.1
Heptachlor				0.05

Pollutants	Effluent Concentration (µg/l)*			MAL (µg/l)
	Average	Maximum	No. of Samples	
PESTICIDES (cont.)				
Heptachlor Epoxide	Not Applicable			
PCB-1254				1.0
PCB-1221				1.0
PCB-1242				
PCB-1232				1.0
PCB-1248				1.0
PCB-1260				1.0
PCB-1016				1.0
Toxaphene				5.0

* Indicate units if different from µg/l

8. **TABLE 8 (DIOXINS/FURAN COMPOUNDS):** Please complete as directed. Not required for internal outfalls. (Instructions, Pages 39-40)

a. Are any of the following compounds manufactured and/or used in a process at the facility? ___ Yes No

If yes, indicate with a check mark the compound(s) which apply and provide a brief description of the conditions of its/their presence at the facility.

- ___ 2,4,5-trichlorophenoxy acetic acid (2,4,5-T) CAS #93-76-5
- ___ 2-(2,4,5-trichlorophenoxy) propanoic acid (Silvex, 2,4,5-TP) CAS #93-72-1
- ___ 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate (Erbon) CAS #136-25-4
- ___ 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothioate (Ronnel) CAS #299-84-3
- ___ 2,4,5-trichlorophenol (TCP) CAS #95-95-4
- ___ Hexachlorophene (HCP) CAS #70-30-4

Not Applicable

b. Do you know or have any reason to believe that 2,3,7,8 Tetrachlorodibenzo-P-Dioxin (TCDD) or any congeners of TCDD may be present in your effluent? ___ Yes ___ No

If yes, provide a brief description of the conditions for its presence.

Not Applicable

c. If your responded yes to either item a or b, complete **Table 8** as instructed.

TABLE 8

Outfall	<input type="checkbox"/> C <input type="checkbox"/> G	Wastewater		Sludge		MAL (ppq)
	Equivalent Factors	Concentration (ppq)	Equivalents (ppq)	Concentration (ppt)	Equivalents (ppt)	
2,3,7,8-TCDD	1	Not Applicable				10.0
1,2,3,7,8-PeCDD	0.5			50.0		
2,3,7,8-HxCDDs	0.1			50.0		
2,3,7,8-TCDF	0.1			10.0		
1,2,3,7,8-PeCDF	0.05			50.0		
2,3,4,7,8-PeCDF	0.5			50.0		
2,3,7,8-HxCDFs	0.1			50.0		
Total						

9. **TABLE 9 (HAZARDOUS SUBSTANCES):** Proceed complete as directed. Not required for internal outfalls. (Instructions, Pages 41)

a. Are there any pollutants listed in the instructions (page 41) believed present in the discharge?
 _____ Yes No

b. Are there pollutants listed in Item No. 1.d. on Page No. 1 of this technical report which are believed present in the discharge and have not been analytically quantified elsewhere in this application? _____ Yes No

If your responded yes to either item, complete **Table 9** as instructed.

TABLE 9

Pollutant & CAS Number	Average (µg/l)	Maximum (µg/l)	No. of Samples	Analytical Method
Not Applicable				

WORKSHEET 2.0 - POLLUTANT ANALYSES REQUIREMENTS

REQUIRED FOR APPLICATIONS SUBMITTED FOR A TPDES PERMIT. NOT REQUIRED FOR APPLICATIONS FOR A PERMIT TO DISPOSE OF ALL WASTEWATER BY LAND DISPOSAL OR FOR DISCHARGES SOLELY OF STORM WATER RUNOFF. (General Requirements: Instructions, Pages 36-37)

1. TABLE 1: Complete table required for all external outfalls. (Instructions, Page 37)

Outfall No.: 002	<input type="checkbox"/> C	<input checked="" type="checkbox"/> G	Effluent Concentration (mg/l)				
Pollutants	Samp.	Samp.	Samp.	Samp.	Average		
BOD (5-day)	<2	1	2	<1	1.1		
CBOD (5-day)	<2	<1	2	<1	1		
Chemical Oxygen Demand	8	40	45	18	27.8		
Total Organic Carbon	4.2	5.3	5.5	4.4	4.9		
Dissolved Oxygen	8.9	8.3	4.3	6.4	7.0		
Ammonia Nitrogen	<0.1	3	2.6	<0.1	1.4		
Total Suspended Solids	<4	10	22	<4	9		
Nitrate Nitrogen	<0.1	<0.1	<0.1	<0.1	0.05		
Total Organic Nitrogen	<0.5	6.5	6.8	<0.5	3.5		
Total Phosphorus	<.05	<0.5	<0.5	<0.5	<0.5		
Oil and Grease	<5	<5	<5	<5	<5		
Total Residual Chlorine	<0.1	<0.1	<0.1	<0.1	<0.1		
Total Dissolved Solids	993	4470	4530	1060	2763		
Sulfate	443	1820	1620	446	1082		
Chloride	200	678	603	198	420		
Fluoride	500	550	460	500	502		
Fecal Coliform	1	1	1	<1	0.88		
Temperature (°F)	94.4	88.7	85.7	82.4	87.8		
pH (Standard Units; min/max)	9.0	4.5	4.7	8.8	6.8		

	Effluent Concentration (µg/l)					MAL (µg/l)
Total Aluminum	70	1050	1070	400	648	30
Total Antimony	<60	<60	<60	<60	60	30
Total Arsenic	<10	<10	<10	<10	<10	10
Total Barium	80	70	70	90	77.5	10
Total Beryllium	<5	<5	<5	<5	<5	5
Total Cadmium	<1	<1	<1	<1	<1	1
Total Chromium	<10	<10	<10	<10	<10	10
Trivalent Chromium	<10	<10	<10	<10	<10	N/A
Hexavalent Chromium	<10	<10	<10	<10	<10	10
Total Copper	<10	<10	<10	<10	<10	10
Cyanide	<20	<20	<20	<20	<20	20
Total Lead	<5	6	<5	<5	3.4	5
Total Mercury	<0.2	<0.2	<0.2	<0.2	<0.2	0.2
Total Nickel	<10	<10	<10	<10	<10	10
Total Selenium	<10	15	14	<10	9.8	10
Total Silver	<2	5	4	2	3	2.0
Total Thallium	<10	<10	<10	<10	<10	10
Total Zinc	<5	10	12	<5	6.8	5

2. **TABLE 2:** Complete table required for all external outfalls which discharge process wastewater. Partial table required for all external outfalls with nonprocess wastewater discharges. Storm water runoff discharges commingled with other wastestreams shall complete the table as instructed (Instructions, Page 37).

Outfall No.: 002	C <input type="checkbox"/> G <input checked="" type="checkbox"/>		Effluent Concentration (µg/l) (*1)				
Pollutants	Samp. 1	Samp. 2	Samp 3.	Samp. 4	Average	MAL (µg/l)	
Benzene	<1	<1	<1	<1	<1	10	
Benzidine	<20	<20	<20	<20	<20	50	
Benzo(a)anthracene	<10	<10	<10	<10	<10	10	
Benzo(a)pyrene	<10	<10	<10	<10	<10	10	
Carbon Tetrachloride	<1	<1	<1	<1	<1	10	
Chlorobenzene	<1	<1	<1	<1	<1	10	
Chloroform	<1	<1	<1	<1	<1	10	
Chrysene	<10	<10	<10	<10	<10	10	
Cresols	<10	<10	<10	<10	<10	(*2)	
Dibromochloromethane	<1	<1	<1	<1	<1	10	
1,2-Dibromoethane	<1	<1	<1	<1	<1	2	
1,4-Dichlorobenzene	<1	<1	<1	<1	<1	10	
1,2-Dichloroethane	<1	<1	<1	<1	<1	10	
1,1-Dichloroethylene	<1	<1	<1	<1	<1	10	
Fluoride	500	550	460	500	502	500	
Hexachlorobenzene	<10	<10	<10	<10	<10	10	
Hexachlorobutadiene	<10	<10	<10	<10	<10	10	
Hexachloroethane	<10	<10	<10	<10	<10	20	
Methyl Ethyl Ketone	<20	<20	<20	<20	<20	50	
Nitrobenzene	<10	<10	<10	<10	<10	10	
n-Nitrosodiethylamine	<10	<10	<10	<10	<10	20	
n-Nitroso-di-n-Butylamine	<10	<10	<10	<10	<10	20	
PCB's, Total (*3)	<1	<1	<1	<1	<1	1	
Pentachlorobenzene	<10	<10	<10	<10	<10	20	
Pentachlorophenol	<51	<51	<51	<51	51	50	
Phenanthrene	<10	<10	<10	<10	<10	10	
Pyridine	<20	<20	<20	<20	<20	20	
1,2,4,5-Tetrachlorobenzene	<20	<20	<20	<20	<20	20	
Tetrachloroethylene	<1	<1	<1	<1	<1	10	
Trichloroethylene	<1	<1	<1	<1	<1	10	
1,1,1-Trichloroethane	<1	<1	<1	<1	<1	10	
2,4,5-Trichlorophenol	<10	<10	<10	<10	<10	50	
TTHM (Total Trihalmethanes)	<80	<80	<80	<80	80	10	
Vinyl Chloride	<1	<1	<1	<1	<1	10	

(*1) Indicates units if different from µg/l.

(*2) MAL's for Cresols: p-Chloro-m-Creso 10 µg/l; 4,6-Dinitro-o-Cresol 50 µg/l; p-Cresol 10 µg/l.

(*3) Total PCB-1242, PCB-1254, PCB-1221, PCB-1232, PCB-1248, PCB-1260, PCB-1016.

a. LABORATORY ACCREDITATION:

Effective July 1, 2008, all laboratory tests performed must meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification with the following general exemptions:

- i. The laboratory is an in-house laboratory and is:
 - 1. periodically inspected by the TCEQ; or
 - 2. located in another state and is accredited or inspected by that state; or
 - 3. performing work for another company with a unit located in the same site; or
 - 4. performing pro bono work for a governmental agency or charitable organization.
- ii. The laboratory is accredited under federal law.
- iii. The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- iv. The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements. The following certification statement shall be signed and submitted with every application. See Instructions, Page 20, for a list of designated representatives who may sign the certification.

I, _____ Certify that all laboratory tests submitted with this application meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

3. TABLE 3: Partial table (only those pollutants which are required by the conditions specified) required for each external outfall. Not required for internal outfalls. (Instructions, Page 38)

a. TRIBUTYLTIN:

Is your facility or will your proposed facility be an industrial/commercial facilities which directly disposes of wastewater from the types of operations listed below or a domestic facilities which receive wastewater from the types of industrial/commercial operations listed below? _____ Yes No

If **yes**, indicate with a check mark all of the following criteria which apply and provide the appropriate testing results in the table below.

- _____ Manufacturers and formulators of tributyltin or related compounds.
- _____ Painting of ships, boats and marine structures.
- _____ Ship and boat building and repairing.
- _____ Ship and boat cleaning, salvage, wrecking and scaling.
- _____ Operation and maintenance of marine cargo handling facilities and marinas
- _____ Facilities engaged in wood preserving
- _____ Any other industrial/commercial facility for which tributyltin is known to be present, or for which there is any reason to believe that tributyltin may be present in the effluent.

b. ENTEROCOCCI

Does your facility or will your proposed facility discharge directly into saltwater receiving waters? _____ Yes No

If **yes**, provide the appropriate testing results in the table below.

TABLE 3

Outfall No.:	<input type="checkbox"/> C <input type="checkbox"/> G	Effluent Concentration (µg/l)					MAL (µg/l)
		Samp. 1	Samp. 2	Samp. 3	Samp. 4	Average	
Pollutants							
Tributyltin		Not Applicable					0.010
Enterococci							N/A

4. **TABLE 4:** Complete table required for all external outfalls which discharge process wastewater and other wastewaters, which may contain pesticides or herbicides, from a facility which manufactures or formulates pesticides or herbicides. Not required for internal outfalls. (Instructions, Page 38)

Does your facility manufacture or formulate pesticides or herbicides? ___ Yes No
 If yes, provide the appropriate testing results.

TABLE 4

Outfall No.: 002	<input type="checkbox"/> C <input type="checkbox"/> G	Effluent Concentration (µg/l) (*1)					MAL (µg/l)
		Samp. 1	Samp. 2	Samp. 3	Samp. 4	Avg.	
Beta-hexachlorocyclohexane		Not Applicable					0.05
Carbaryl							5
Chlordane							0.15
Chlorpyrifos							0.05
2,4-D							10
Danitol							----
4,4'-DDD							0.1
4,4'-DDE							0.1
4,4'-DDT							0.1
Demeton							0.2
Diazinon							0.5
Dicofol							20
Dieldrin							0.1
Diuron							0.09
Endosulfan I (alpha)							0.1
Endosulfan II (beta)							0.1
Endosulfan Sulfate							0.1
Endrin							0.1
Gamma - Hexachlorocyclohexane (Lindane)							0.05
Guthion							0.10
Heptachlor							0.05
Heptachlor Epoxide							1.0
Hexachlorophene							10
Malathion							0.10
Methoxychlor							2.0
Mirex							0.2
Parathion							0.1
Toxaphene							5
2,4,5-TP (Silvex)							2

* Indicate units if different from mg/L.

5. **TABLE 5:** Complete table required for all external outfalls. Not required for internal outfalls.
(Instructions, Page 38)

TABLE 5

Outfall No.: 002	<input type="checkbox"/> C <input checked="" type="checkbox"/> G	Believed Present	Believed Absent	Effluent Concentration (mg/l)		No. of Samples
				Average	Maximum	
Bromide		x		9.2	18.5	4
Color(PCU)		x		7.56	10	4
Nitrate-Nitrite(as N)		x		<0.1	<0.1	4
Sulfide(as S)		x		<1	1	4
Sulfite(as SO ₃)		x		<2	<2	4
Surfactants		x		0.065	0.086	4
Total Antimony		x		<0.06	<0.06	4
Total Beryllium		x		<0.005	<0.005	4
Total Boron		x		19.77	40.2	4
Total Cobalt		x		<0.02	<0.02	4
Total Iron		x		<.25	0.52	4
Total Magnesium		x		54	87	3
Total Molybdenum		x		<0.05	<0.05	4
Total Manganese		x		0.15	0.28	4
Total Thallium		x		<0.01	<0.01	4
Total Tin		x		<0.02	<0.02	4
Total Titanium		x		<0.01	<0.01	4

6. **TABLE 6:** Indicate with a check mark any of the industrial categories applicable to your facility. If testing is required, indicate with a check mark in the box provided that the testing results for the appropriate parameters in Table B-7 are provided with the application. (Instructions, Page 39)

N/A	GC/MS Testing Required			
	Volatile	Acid	Base/Neutral	Pesticides
_____ Adhesives and Sealants	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Aluminum Forming	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Auto and Other Laundries	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Battery Manufacturing	Yes <input type="checkbox"/>	No	Yes <input type="checkbox"/>	No
_____ Coal Mining	No	No	No	No
_____ Coil Coating	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Copper Forming	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Electric and Electronic Components	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Electroplating	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Explosives Manufacturing	No	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Foundries	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Gum and Wood Chemicals				
_____ Subparts A,B,C,E	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No	No
_____ Subparts D,F	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Inorganic Chemicals	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Iron and Steel Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Leather Tanning/Finishing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Mechanical Products Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Nonferrous Metals Mfg.	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Ore Mining(Subpart B)	No	Yes <input type="checkbox"/>	No	No
_____ Organic Chemicals, Plastics, and Synthetic Fibers	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Paint and Ink Formulation	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Pesticides	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Petroleum Refining	Yes <input type="checkbox"/>	No	No	No
_____ Pharmaceutical Preparations	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Photographic Equipment and Supplies	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Plastic and Synthetic Materials Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Plastic Processing	Yes <input type="checkbox"/>	No	No	No
_____ Porcelain Enameling	No	No	No	No
_____ Printing and Publishing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Pulp and Paperboard Mills				
_____ Subparts A	* <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Subparts B,C,D,R	* <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	* <input type="checkbox"/>
_____ Subparts F,G,H,I,K,L,M,N,O,P	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	* <input type="checkbox"/>
_____ Subparts E,Q,S,T	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Subparts J,U	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>
_____ Rubber Processing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Soap and Detergent Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
✓ _____ Steam Electric Power Plants	Yes <input checked="" type="checkbox"/>	Yes <input checked="" type="checkbox"/>	No	No
_____ Textile Mills (Not Subpart C)	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Timber Products Processing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>

* Test if "believed present"

TABLE 7: Please complete as directed and only for those parameters specified in Table 6. Required for all external outfalls which contain process wastewater. Not required for internal outfalls. Testing may be required for types of industry not specified in Table 6 for specific parameters if believed present (Instructions, Page 39).

TABLE 7

Outfall No.: <u>002</u> <input type="checkbox"/> C <input checked="" type="checkbox"/> G		Effluent Concentration (µg/l)*		
Pollutants	Average	Maximum	No. of Samples	MAL (µg/l)
VOLATILE COMPOUNDS				
Acrolein	<20	<20	4	50
Acrylonitrile	<20	<20	4	50
Benzene	<1	<1	4	10
Bromoform	<1	<1	4	10
Carbon Tetrachloride	<1	<1	4	10
Chlorobenzene	<1	<1	4	10
Chlorodibromomethane	<1	<1	4	10
Chloroethane	<1	<1	4	50
2-Chloroethylvinyl Ether	<1	<1	4	10
Chloroform	<1	<1	4	10
Dichlorobromomethane	<1	<1	4	10
1,1-Dichloroethane	<1	<1	4	10
1,2-Dichloroethane	<1	<1	4	10
1,1-Dichloroethylene	<1	<1	4	10
1,2-Dichloropropane	<1	<1	4	10
1,3-Dichloropropylene	<1	<1	4	10
Ethylbenzene	<1	<1	4	10
Methyl Bromide	<1	<1	4	50
Methyl Chloride	<1	<1	4	50
Methylene Chloride	<1	<1	4	20
1,1,2,2-Tetrachloroethane	<1	<1	4	10
Tetrachloroethylene	<1	<1	4	10
Toluene	<1	<1	4	10
1,2-Trans-Dichloroethylene	<1	<1	4	10
1,1,1-Trichloroethane	<1	<1	4	10
1,1,2-Trichloroethane	<1	<1	4	10
Trichloroethylene	<1	<1	4	10
Vinyl Chloride	<1	<1	4	10

Pollutants	Effluent Concentration (µg/l)*			MAL (µg/l)
	Average	Maximum	No. of Samples	
ACID COMPOUNDS				
2-Chlorophenol	<10	<10	4	10
2,4-Dichlorophenol	<10	<10	4	10
2,4-Dimethylphenol	<10	<10	4	10
4,6-Dinitro-o-Cresol	38	<51	4	50
2,4-Dinitrophenol	51	<51	4	50
2-Nitrophenol	<10	<10	4	20
4-Nitrophenol	51	<51	4	50
P-Chloro-m-Cresol	<10	<10	4	10
Pentalchlorophenol	51	<51	4	50
Phenol	<10	<10	4	10
2,4,6-Trichlorophenol	<10	<10	4	10
BASE/NEUTRAL COMPOUNDS				
Acenaphthene	Not Applicable			10
Acenaphthylene	Not Applicable			10
Anthracene	Not Applicable			10
Benzidine	Not Applicable			50
Benzo(a)Anthracene	Not Applicable			10
Benzo(a)Pyrene	Not Applicable			10
3,4-Benzofluoranthene	Not Applicable			10
Benzo(ghi)Perylene	Not Applicable			20
Benzo(k)Fluoranthene	Not Applicable			10
Bis(2-Chloroethoxy)Methane	Not Applicable			10
Bis(2-Chloroethyl)Ether	Not Applicable			10
Bis(2-Chloroisopropyl)Ether	Not Applicable			10
Bis(2-Ethylhexyl)Phthalate	Not Applicable			10
4-Bromophenyl Phenyl Ether	Not Applicable			10
Butylbenzyl Phthalate	Not Applicable			10
2-chloronaphthalene	Not Applicable			10
4-chlorophenyl phenyl ether	Not Applicable			10
Chrysene	Not Applicable			10
Dibenzo(a,h)Anthracene	Not Applicable			20
1,2-Dichlorobenzene	Not Applicable			10
1,3-Dichlorobenzene	Not Applicable			10
1,4-Dichlorobenzene	Not Applicable			10
3,3-Dichlorobenzidine	Not Applicable			50
Diethyl Phthalate	Not Applicable			10
Dimethyl Phthalate	Not Applicable			10
Di-n-Butyl Phthalate	Not Applicable			10
2,4-Dinitrotoluene	Not Applicable			10

Pollutants	Effluent Concentration (µg/l)*			MAL (µg/l)
	Average	Maximum	No. of Samples	
BASE/NEUTRAL COMPOUNDS (cont.)				
2,6-Dinitroluene	Not Applicable			10
Di-n-Octyl Phthalate				10
1,2-Diphenyl Hydrazine (as Azobenzene)				20
Fluoranthene				10
Fluorene				10
Hexachlorobenzene				10
Hexachlorobutadiene				10
Hexachlorocyclopentadiene				10
Hexachloroethane				20
Indeno(1,2,3-cd)pyrene				20
Isophorone				10
Naphthalene				10
Nitrobenzene				10
N-Nitrosodimethylamine				50
N-Nitrosodi-n-Propylamine				20
N-Nitrosodiphenylamine				20
Phenanthrene				10
Pyrene				10
1,2,4-Trichlorobenzene				10
PESTICIDES				
Aldrin	Not Applicable			0.05
alpha-BHC				0.05
beta-BHC				0.05
gamma-BHC				0.05
delta-BHC				0.05
Chlordane				0.15
4,4-DDT				0.1
4,4-DDE				0.1
Dieldrin				0.1
alpha-Endosulfan				0.1
beta-Endosulfan				0.1
Endosulfan Sulfate				0.1
Endrin				0.1
Endrin Aldehyde				0.1
Heptachlor				0.05

Pollutants	Effluent Concentration (µg/l)*			MAL (µg/l)
	Average	Maximum	No. of Samples	
PESTICIDES (cont.)				
Heptachlor Epoxide	Not Applicable			
PCB-1254				1.0
PCB-1221				1.0
PCB-1242				
PCB-1232				1.0
PCB-1248				1.0
PCB-1260				1.0
PCB-1016				1.0
Toxaphene				5.0

* Indicate units if different from µg/l

8. **TABLE 8 (DIOXINS/FURAN COMPOUNDS):** Please complete as directed. Not required for internal outfalls. (Instructions, Pages 39-40)

a. Are any of the following compounds manufactured and/or used in a process at the facility? ___ Yes No

If yes, indicate with a check mark the compound(s) which apply and provide a brief description of the conditions of its/their presence at the facility.

- ___ 2,4,5-trichlorophenoxy acetic acid (2,4,5-T) CAS #93-76-5
- ___ 2-(2,4,5-trichlorophenoxy) propanoic acid (Silvex, 2,4,5-TP) CAS #93-72-1
- ___ 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate (Erbon) CAS #136-25-4
- ___ 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothioate (Ronnel) CAS #299-84-3
- ___ 2,4,5-trichlorophenol (TCP) CAS #95-95-4
- ___ Hexachlorophene (HCP) CAS #70-30-4

Not Applicable

b. Do you know or have any reason to believe that 2,3,7,8 Tetrachlorodibenzo-P-Dioxin (TCDD) or any congeners of TCDD may be present in your effluent? ___ Yes No

If yes, provide a brief description of the conditions for its presence.

Not Applicable

c. If your responded yes to either item a or b, complete **Table 8** as instructed.

TABLE 8

Outfall	<input type="checkbox"/> C <input type="checkbox"/> G	Wastewater		Sludge		MAL (ppq)
		Concentration (ppq)	Equivalents (ppq)	Concentration (ppt)	Equivalents (ppt)	
2,3,7,8-TCDD	1	Not Applicable				10.0
1,2,3,7,8-PeCDD	0.5			50.0		
2,3,7,8-HxCDDs	0.1			50.0		
2,3,7,8-TCDF	0.1			10.0		
1,2,3,7,8-PeCDF	0.05			50.0		
2,3,4,7,8-PeCDF	0.5			50.0		
2,3,7,8-HxCDFs	0.1			50.0		
Total						

9. **TABLE 9 (HAZARDOUS SUBSTANCES):** Proceed complete as directed. Not required for internal outfalls. (Instructions, Pages 41)

a. Are there any pollutants listed in the instructions (page 41) believed present in the discharge?
 _____ Yes No

b. Are there pollutants listed in Item No. 1.d. on Page No. 1 of this technical report which are believed present in the discharge and have not been analytically quantified elsewhere in this application? _____ Yes No

If your responded **yes** to either item, complete **Table 9** as instructed.

TABLE 9

Pollutant & CAS Number	Average (µg/l)	Maximum (µg/l)	No. of Samples	Analytical Method
Not Applicable				

WORKSHEET 2.0 - POLLUTANT ANALYSES REQUIREMENTS

REQUIRED FOR APPLICATIONS SUBMITTED FOR A TPDES PERMIT. NOT REQUIRED FOR APPLICATIONS FOR A PERMIT TO DISPOSE OF ALL WASTEWATER BY LAND DISPOSAL OR FOR DISCHARGES SOLELY OF STORM WATER RUNOFF. (General Requirements: Instructions, Pages 36-37)

1. **TABLE 1:** Complete table required for all external outfalls. (Instructions, Page 37)

Pollutants	Effluent Concentration (mg/l)				
	Samp.	Samp.	Samp.	Samp.	Average
BOD (5-day)	2	3	3	3	2.7
CBOD (5-day)	2	3	3	2	2.5
Chemical Oxygen Demand	12	28	31	27	24.5
Total Organic Carbon	6.2	6.2	6.2	6.2	6.2
Dissolved Oxygen	4.3	7.9	4.9	6.3	5.9
Ammonia Nitrogen	<0.1	<0.1	<0.1	<0.1	<0.1
Total Suspended Solids	19	12	15	13	14.7
Nitrate Nitrogen	<0.1	<0.1	<0.1	<0.1	<0.1
Total Organic Nitrogen	0.7	0.7	0.8	0.8	0.75
Total Phosphorus	<0.5	<0.5	<0.5	<0.5	<0.5
Oil and Grease	<5	<5	<5	<5	<5
Total Residual Chlorine	0.1	0.2	0.3	0.6	0.3
Total Dissolved Solids	231	250	253	277	253
Sulfate	65	63	61	64	63
Chloride	47	48	46	48	47
Fluoride	200	100	200	200	175
Fecal Coliform	6	2	2	2	3
Temperature (°F)	102.8	101.8	98.3	99.7	100.6
pH (Standard Units; min/max)	8	8.1	8.1	7.9	8

	Effluent Concentration (µg/l)					MAL (µg/l)
	Samp.	Samp.	Samp.	Samp.	Average	
Total Aluminum	520	160	200	190	268	30
Total Antimony	<60	<60	<60	<60	60	30
Total Arsenic	<10	<10	<10	<10	<10	10
Total Barium	120	110	120	120	118	10
Total Beryllium	<5	<5	<5	<5	<5	5
Total Cadmium	<1	<1	<1	<1	<1	1
Total Chromium	<10	<10	<10	<10	<10	10
Trivalent Chromium	<10	<10	<10	<10	<10	N/A
Hexavalent Chromium	<10	<10	<10	<10	<10	10
Total Copper	<10	<10	<10	<10	<10	10
Cyanide	<20	<20	<20	<20	<20	20
Total Lead	<5	<5	<5	<5	<5	5
Total Mercury	<0.2	<0.2	<0.2	<0.2	<0.2	0.2
Total Nickel	<10	<10	<10	<10	<10	10
Total Selenium	<10	<10	<10	<10	<10	10
Total Silver	<2	<2	<2	<2	<2	2.0
Total Thallium	<10	<10	<10	<10	<10	10
Total Zinc	<5	<5	<5	<5	<5	5

2. **TABLE 2:** Complete table required for all external outfalls which discharge process wastewater. Partial table required for all external outfalls with nonprocess wastewater discharges. Storm water runoff discharges commingled with other wastestreams shall complete the table as instructed (Instructions, Page 37).

Outfall No.: 004	C <input type="checkbox"/> G <input checked="" type="checkbox"/>		Effluent Concentration (µg/l) (*1)				MAL (µg/l)
Pollutants	Samp. 1	Samp. 2	Samp 3.	Samp. 4	Average		
Benzene	<1	<1	<1	<1	<1	10	
Benzidine	<20	<21	<21	<20	<21	50	
Benzo(a)anthracene	<10	<11	<10	<10	6.5	10	
Benzo(a)pyrene	<10	<11	<10	<10	6.5	10	
Carbon Tetrachloride	<1	<1	<1	<1	<1	10	
Chlorobenzene	<1	<1	<1	<1	<1	10	
Chloroform	<1	<1	<1	<1	<1	10	
Chrysene	<10	<11	<10	<10	6.5	10	
Cresols	<10	<11	<10	<10	6.5	(*2)	
Dibromochloromethane	<1	<1	<0.5	<1	<1	10	
1,2-Dibromoethane	<1	<1	<1	<1	<1	2	
1,4-Dichlorobenzene	<1	<1	<1	<1	<1	10	
1,2-Dichloroethane	<1	<1	<1	<1	<1	10	
1,1-Dichloroethylene	<1	<1	<1	<1	<1	10	
Fluoride	200	100	200	200	175	500	
Hexachlorobenzene	<10	<11	<10	<10	6.5	10	
Hexachlorobutadiene	<10	<11	<10	<10	6.5	10	
Hexachloroethane	<10	<11	<10	<10	6.5	20	
Methyl Ethyl Ketone	<20	<20	<20	<20	<20	50	
Nitrobenzene	<10	<11	<10	<10	6.5	10	
n-Nitrosodiethylamine	<10	<11	<10	<10	6.5	20	
n-Nitroso-di-n-Butylamine	<10	<11	<10	<10	6.5	20	
PCB's, Total (*3)	<1	<1	<1	<1	<1	1	
Pentachlorobenzene	<10	<10	<11	<10	6.5	20	
Pentachlorophenol	<51	<53	<52	<51	52	50	
Phenanthrene	<10	<11	<10	<10	6.5	10	
Pyridine	<20	<21	<21	<20	20.5	20	
1,2,4,5-Tetrachlorobenzene	<20	<21	<21	<20	20.5	20	
Tetrachloroethylene	<1	<1	<1	<1	<1	10	
Trichloroethylene	<1	<1	<1	<1	<1	10	
1,1,1-Trichloroethane	<1	<1	<1	<1	<1	10	
2,4,5-Trichlorophenol	<10	<11	<10	<10	6.5	50	
TTHM (Total Trihalmethanes)	<80	<80	<80	<80	80	10	
Vinyl Chloride	<1	<1	<1	<1	<1	10	

(*1) Indicates units if different from µg/l.

(*2) MAL's for Cresols: p-Chloro-m-Creso 10 µg/l; 4,6-Dinitro-o-Cresol 50 µg/l; p-Cresol 10 µg/l.

(*3) Total PCB-1242, PCB-1254, PCB-1221, PCB-1232, PCB-1248, PCB-1260, PCB-1016.

a. LABORATORY ACCREDITATION:

Effective July 1, 2008, all laboratory tests performed must meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification with the following general exemptions:

- i. The laboratory is an in-house laboratory and is:
 - 1. periodically inspected by the TCEQ; or
 - 2. located in another state and is accredited or inspected by that state; or
 - 3. performing work for another company with a unit located in the same site; or
 - 4. performing pro bono work for a governmental agency or charitable organization.
- ii. The laboratory is accredited under federal law.
- iii. The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- iv. The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements. The following certification statement shall be signed and submitted with every application. See Instructions, Page 20, for a list of designated representatives who may sign the certification.

I, _____ Certify that all laboratory tests submitted with this application meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

3. TABLE 3: Partial table (only those pollutants which are required by the conditions specified) required for each external outfall. Not required for internal outfalls. (Instructions, Page 38)

a. TRIBUTYLTIN:

Is your facility or will your proposed facility be an industrial/commercial facilities which directly disposes of wastewater from the types of operations listed below or a domestic facilities which receive wastewater from the types of industrial/commercial operations listed below? _____ Yes No

If **yes**, indicate with a check mark all of the following criteria which apply and provide the appropriate testing results in the table below.

- _____ Manufacturers and formulators of tributyltin or related compounds.
- _____ Painting of ships, boats and marine structures.
- _____ Ship and boat building and repairing.
- _____ Ship and boat cleaning, salvage, wrecking and scaling.
- _____ Operation and maintenance of marine cargo handling facilities and marinas
- _____ Facilities engaged in wood preserving
- _____ Any other industrial/commercial facility for which tributyltin is known to be present, or for which there is any reason to believe that tributyltin may be present in the effluent.

b. ENTEROCOCCI

Does your facility or will your proposed facility discharge directly into saltwater receiving waters? _____ Yes No

If **yes**, provide the appropriate testing results in the table below.

TABLE 3

Outfall No.:	<input type="checkbox"/> C <input type="checkbox"/> G	Effluent Concentration (µg/l)					MAL (µg/l)
		Samp. 1	Samp. 2	Samp. 3	Samp. 4	Average	
Pollutants							
Tributyltin							0.010
Enterococci							N/A

4. **TABLE 4:** Complete table required for all external outfalls which discharge process wastewater and other wastewaters, which may contain pesticides or herbicides, from a facility which manufactures or formulates pesticides or herbicides. Not required for internal outfalls. (Instructions, Page 38)

Does your facility manufacture or formulate pesticides or herbicides? ____ Yes No
 If yes, provide the appropriate testing results.

TABLE 4

Outfall No.: 004	<input type="checkbox"/> C <input type="checkbox"/> G	Effluent Concentration (µg/l) (*1)					MAL (µg/l)
		Samp. 1	Samp. 2	Samp. 3	Samp. 4	Avg.	
Pollutants							
Beta-hexachlorocyclohexane							0.05
Carbaryl		Not Applicable					5
Chlordane							
Chlorpyrifos							0.05
2,4-D							10
Danitol							----
4,4'-DDD							0.1
4,4'-DDE							0.1
4,4'-DDT							0.1
Demeton							0.2
Diazinon							0.5
Dicofol							20
Dieldrin							0.1
Diuron							0.09
Endosulfan I (alpha)							0.1
Endosulfan II (beta)							0.1
Endosulfan Sulfate							0.1
Endrin							0.1
Gamma - Hexachlorocyclohexane (Lindane)							0.05
Guthion							0.10
Heptachlor							0.05
Heptachlor Epoxide							1.0
Hexachlorophene							10
Malathion							0.10
Methoxychlor							2.0
Mirex							0.2
Parathion							0.1
Toxaphene							5
2,4,5-TP (Silvex)							2

* Indicate units if different from mg/L.

5. **TABLE 5:** Complete table required for all external outfalls. Not required for internal outfalls.
(Instructions, Page 38)

TABLE 5

Outfall No.: 004	<input type="checkbox"/> C <input type="checkbox"/> G	Believed Present	Believed Absent	Effluent Concentration (mg/l)		No. of Samples
				Average	Maximum	
Bromide		x		0.25	0.4	4
Color(PCU)		x		41.3	70	4
Nitrate-Nitrite(as N)		x		<0.1	<0.1	4
Sulfide(as S)		x		<1	<1	4
Sulfite(as SO ₃)		x		<2	<2	4
Surfactants		x		0.0595	0.070	4
Total Antimony		x		<0.06	<0.06	4
Total Beryllium		x		<0.005	<0.005	4
Total Boron		x		0.17	0.20	4
Total Cobalt		x		<0.02	<0.02	4
Total Iron		x		0.14	0.20	4
Total Magnesium		x		6	6	4
Total Molybdenum		x		<0.05	<0.05	4
Total Manganese		x		0.25	<.42	4
Total Thallium		x		<0.01	<0.01	4
Total Tin		x		<0.02	<0.02	4
Total Titanium		x		<0.01	<0.01	4

6. **TABLE 6:** Indicate with a check mark any of the industrial categories applicable to your facility. If testing is required, indicate with a check mark in the box provided that the testing results for the appropriate parameters in Table B-7 are provided with the application. (Instructions, Page 39)

_____ N/A	<u>GC/MS Testing Required</u>			
	<u>Volatile</u>	<u>Acid</u>	<u>Base/Neutral</u>	<u>Pesticides</u>
_____ Adhesives and Sealants	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Aluminum Forming	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Auto and Other Laundries	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Battery Manufacturing	Yes <input type="checkbox"/>	No	Yes <input type="checkbox"/>	No
_____ Coal Mining	No	No	No	No
_____ Coil Coating	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Copper Forming	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Electric and Electronic Components	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Electroplating	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Explosives Manufacturing	No	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Foundries	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Gum and Wood Chemicals				
_____ Subparts A,B,C,E	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No	No
_____ Subparts D,F	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Inorganic Chemicals	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Iron and Steel Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Leather Tanning/Finishing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Mechanical Products Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Nonferrous Metals Mfg.	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Ore Mining(Subpart B)	No	Yes <input type="checkbox"/>	No	No
_____ Organic Chemicals, Plastics, and Synthetic Fibers	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Paint and Ink Formulation	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Pesticides	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Petroleum Refining	Yes <input type="checkbox"/>	No	No	No
_____ Pharmaceutical Preparations	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Photographic Equipment and Supplies	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Plastic and Synthetic Materials Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Plastic Processing	Yes <input type="checkbox"/>	No	No	No
_____ Porcelain Enameling	No	No	No	No
_____ Printing and Publishing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Pulp and Paperboard Mills				
_____ Subparts A	* <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Subparts B,C,D,R	* <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	* <input type="checkbox"/>
_____ Subparts F,G,H,I,K,L,M,N,O,P	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	* <input type="checkbox"/>
_____ Subparts E,Q,S,T	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>	Yes <input type="checkbox"/>
_____ Subparts J,U	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	* <input type="checkbox"/>
_____ Rubber Processing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Soap and Detergent Manufacturing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
✓ _____ Steam Electric Power Plants	Yes <input checked="" type="checkbox"/>	Yes <input checked="" type="checkbox"/>	No	No
_____ Textile Mills (Not Subpart C)	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	No
_____ Timber Products Processing	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>	Yes <input type="checkbox"/>

* Test if "believed present"

TABLE 7: Please complete as directed and only for those parameters specified in Table 6. Required for all external outfalls which contain process wastewater. Not required for internal outfalls. Testing may be required for types of industry not specified in Table 6 for specific parameters if believed present (Instructions, Page 39).

TABLE 7

Outfall No.: 004 <input type="checkbox"/> C <input checked="" type="checkbox"/> G		Effluent Concentration (µg/l)*		
Pollutants	Average	Maximum	No. of Samples	MAL (µg/l)
VOLATILE COMPOUNDS				
Acrolein	<20	<20	4	50
Acrylonitrile	<20	<20	4	50
Benzene	<1	<1	4	10
Bromoform	<1	<1	4	10
Carbon Tetrachloride	<1	<1	4	10
Chlorobenzene	<1	<1	4	10
Chlorodibromomethane	<1	<1	4	10
Chloroethane	<1	<1	4	50
2-Chloroethylvinyl Ether	<1	<1	4	10
Chloroform	<1	<1	4	10
Dichlorobromomethane	<1	<1	4	10
1,1-Dichloroethane	<1	<1	4	10
1,2-Dichloroethane	<1	<1	4	10
1,1-Dichloroethylene	<1	<1	4	10
1,2-Dichloropropane	<1	<1	4	10
1,3-Dichloropropylene	<1	<1	4	10
Ethylbenzene	<1	<1	4	10
Methyl Bromide	<1	<1	4	50
Methyl Chloride	<1	<1	4	50
Methylene Chloride	<1	<1	4	20
1,1,2,2-Tetrachloroethane	<1	<1	4	10
Tetrachloroethylene	<1	<1	4	10
Toluene	<1	<1	4	10
1,2-Trans-Dichloroethylene	<1	<1	4	10
1,1,1-Trichloroethane	<1	<1	4	10
1,1,2-Trichloroethane	<1	<1	4	10
Trichloroethylene	<1	<1	4	10
Vinyl Chloride	<1	<1	4	10

Pollutants	Effluent Concentration (µg/l)*			MAL (µg/l)
	Average	Maximum	No. of Samples	
ACID COMPOUNDS				
2-Chlorophenol	<10	<11	4	10
2,4-Dichlorophenol	<10	<11	4	10
2,4-Dimethylphenol	<10	<11	4	10
4,6-Dinitro-o-Cresol	<51	<53	4	50
2,4-Dinitrophenol	<51	<53	4	50
2-Nitrophenol	<10	<11	4	20
4-Nitrophenol	<51	<53	4	50
P-Chloro-m-Cresol	<10	<11	4	10
Pentalchlorophenol	52	<53	4	50
Phenol	<10	<11	4	10
2,4,6-Trichlorophenol	<10	<11	4	10
BASE/NEUTRAL COMPOUNDS				
Acenaphthene	Not Applicable			10
Acenaphthylene	Not Applicable			10
Anthracene	Not Applicable			10
Benzidine	Not Applicable			50
Benzo(a)Anthracene	Not Applicable			10
Benzo(a)Pyrene	Not Applicable			10
3,4-Benzofluoranthene	Not Applicable			10
Benzo(ghi)Perylene	Not Applicable			20
Benzo(k)Fluoranthene	Not Applicable			10
Bis(2-Chloroethoxy)Methane	Not Applicable			10
Bis(2-Chloroethyl)Ether	Not Applicable			10
Bis(2-Chloroisopropyl)Ether	Not Applicable			10
Bis(2-Ethylhexyl)Phthalate	Not Applicable			10
4-Bromophenyl Phenyl Ether	Not Applicable			10
Butylbenzyl Phthalate	Not Applicable			10
2-chloronaphthalene	Not Applicable			10
4-chlorophenyl phenyl ether	Not Applicable			10
Chrysene	Not Applicable			10
Dibenzo(a,h)Anthracene	Not Applicable			20
1,2-Dichlorobenzene	Not Applicable			10
1,3-Dichlorobenzene	Not Applicable			10
1,4-Dichlorobenzene	Not Applicable			10
3,3-Dichlorobenzidine	Not Applicable			50
Diethyl Phthalate	Not Applicable			10
Dimethyl Phthalate	Not Applicable			10
Di-n-Butyl Phthalate	Not Applicable			10
2,4-Dinitrotoluene	Not Applicable			10

Pollutants	Effluent Concentration (µg/l)*			MAL (µg/l)
	Average	Maximum	No. of Samples	
BASE/NEUTRAL COMPOUNDS (cont.)				
2,6-Dinitroluene	Not Applicable			10
Di-n-Octyl Phthalate				10
1,2-Diphenyl Hydrazine (as Azobenzene)				20
Fluoranthene				10
Fluorene				10
Hexachlorobenzene				10
Hexachlorobutadiene				10
Hexachlorocyclopentadiene				10
Hexachloroethane				20
Indeno(1,2,3-cd)pyrene				20
Isophorone				10
Naphthalene				10
Nitrobenzene				10
N-Nitrosodimethylamine				50
N-Nitrosodi-n-Propylamine				20
N-Nitrosodiphenylamine				20
Phenanthrene				10
Pyrene				10
1,2,4-Trichlorobenzene				10
PESTICIDES				
Aldrin	Not Applicable			0.05
alpha-BHC				0.05
beta-BHC				0.05
gamma-BHC				0.05
delta-BHC				0.05
Chlordane				0.15
4,4-DDT				0.1
4,4-DDE				0.1
Dieldrin				0.1
alpha-Endosulfan				0.1
beta-Endosulfan				0.1
Endosulfan Sulfate				0.1
Endrin				0.1
Endrin Aldehyde				0.1
Heptachlor				0.05

Pollutants	Effluent Concentration (µg/l)*			MAL (µg/l)
	Average	Maximum	No. of Samples	
PESTICIDES (cont.)				
Heptachlor Epoxide	Not Applicable			
PCB-1254				1.0
PCB-1221				1.0
PCB-1242				
PCB-1232				1.0
PCB-1248				1.0
PCB-1260				1.0
PCB-1016				1.0
Toxaphene				5.0

* Indicate units if different from µg/l

8. TABLE 8 (DIOXINS/FURAN COMPOUNDS): Please complete as directed. Not required for internal outfalls. (Instructions, Pages 39-40)

a. Are any of the following compounds manufactured and/or used in a process at the facility? Yes No

If **yes**, indicate with a check mark the compound(s) which apply and provide a brief description of the conditions of its/their presence at the facility.

- 2,4,5-trichlorophenoxy acetic acid (2,4,5-T) CAS #93-76-5
- 2-(2,4,5-trichlorophenoxy) propanoic acid (Silvex, 2,4,5-TP) CAS #93-72-1
- 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate (Erbon) CAS #136-25-4
- 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothioate (Ronnel) CAS #299-84-3
- 2,4,5-trichlorophenol (TCP) CAS #95-95-4
- Hexachlorophene (HCP) CAS #70-30-4

Not Applicable

b. Do you know or have any reason to believe that 2,3,7,8 Tetrachlorodibenzo-P-Dioxin (TCDD) or any congeners of TCDD may be present in your effluent? Yes No

If **yes**, provide a brief description of the conditions for its presence.

Not Applicable

c. If your responded **yes** to either item **a** or **b**, complete **Table 8** as instructed.

TABLE 8

Outfall	<input type="checkbox"/> C <input type="checkbox"/> G	Wastewater		Sludge		MAL (ppq)
	Equivalent Factors	Concentration (ppq)	Equivalents (ppq)	Concentration (ppt)	Equivalents (ppt)	
2,3,7,8-TCDD	1	Not Applicable				10.0
1,2,3,7,8-PeCDD	0.5					50.0
2,3,7,8-HxCDDs	0.1					50.0
2,3,7,8-TCDF	0.1					10.0
1,2,3,7,8-PeCDF	0.05					50.0
2,3,4,7,8-PeCDF	0.5					50.0
2,3,7,8-HxCDFs	0.1					50.0
Total						

9. **TABLE 9 (HAZARDOUS SUBSTANCES):** Proceed complete as directed. Not required for internal outfalls. (Instructions, Pages 41)

a. Are there any pollutants listed in the instructions (page 41) believed present in the discharge?
 _____ Yes No

b. Are there pollutants listed in Item No. 1.d. on Page No. 1 of this technical report which are believed present in the discharge and have not been analytically quantified elsewhere in this application? _____ Yes No

If your responded yes to either item, complete **Table 9** as instructed.

TABLE 9

Pollutant & CAS Number	Average (µg/l)	Maximum (µg/l)	No. of Samples	Analytical Method
Not Applicable				

WORKSHEET 4.0 - RECEIVING WATERS

THE FOLLOWING IS REQUIRED FOR ALL TPDES PERMIT APPLICATIONS

1. DOMESTIC DRINKING WATER SUPPLY (Instructions, Page 54)

Is there a surface water intake for domestic drinking water supply located within 5 (five) miles downstream from the point/proposed point of discharge? _____ Yes No

If yes, identify owner of the drinking water supply, the distance and direction to the intake, and locate and identify the intake on the USGS map. Indicate by a check mark that the requested information is provided: N/A

2. DISCHARGE INTO TIDALLY INFLUENCED WATERS (Instructions, Page 54)

a. Width of the receiving water at the outfall? _____ feet **Not Applicable (the receiving waters of the discharge are not tidally influenced)**

b. Are there oyster reefs in the vicinity of the discharge? _____ Yes _____ No

If yes, indicate approximate distance and direction from outfall(s): Not Applicable

c. Are there any sea grasses within the vicinity of the point of discharge? _____ Yes _____ No **Not Applicable**

If yes, provide the distance and direction to the grasses: Not Applicable

3. CLASSIFIED SEGMENT (Instructions, Page 54)

Is the discharge directly into (or within 300 feet of) a classified segment? _____ Yes No

If yes, stop here. It is not necessary to complete items 4 and 5 and it is not necessary to complete Worksheet 2.1. If no, complete items 4 and 5.

4. DESCRIPTION OF IMMEDIATE RECEIVING WATERS (Instructions, Page 55)

Name of the immediate receiving waters: Outfall 001 discharges to an un-named drainage ditch which flows into Gibbons Creek Reservoir.

a. Check the appropriate description of the receiving waters

- Man-made Channel or Ditch
- Stream or creek
- Lake or Pond
- Surface area _____ acres. Average depth of the entire water body _____ feet
- Average depth of water body within a 500-foot radius or the discharge point _____ feet
- Freshwater Swamp or Marsh
- Tidal Stream, Bayou, or Marsh
- Open Bay
- Other: _____

If a man-made channel, ditch or stream was checked above, provide the following:

b. Check one of the following that best characterizes the area **upstream** of the discharge. For new discharges, characterize the area **downstream** of the discharge (check one).

- Intermittent (dry for at least one week during most years)
- Intermittent with Perennial Pools (enduring pools containing sufficient habitat to maintain significant aquatic life uses)
- Perennial (normally flowing)

* **Outfall 001 is located at the mouth of the ditch.**

Check the method used to characterize the area upstream (or downstream for new dischargers): USGS flow records, personal observation, historical observation by adjacent landowner(s), others, specify:

c. List the name(s) of all perennial streams that join the receiving water within three miles downstream of the discharge point:

Gibbons Creek, Peach Creek, and Rock Lake Creek

d. Do the receiving water characteristics change within three miles downstream of the discharge? (e.g., natural or man-made dams, ponds, reservoirs, etc.) Yes No

If yes, discuss how:

The un-named drainage ditch discharges to Gibbons Creek Reservoir, then to Gibbons Creek. Perennial streams that join the receiving water within three miles downstream of the discharge point are Gibbons Creek, Peach Creek, and Rock Lake Creek.

e. Provide general observations of the water body during normal dry weather conditions:

The water in the un-named drainage ditch is slightly turbid during normal, dry weather conditions.

Date and time of observation: **May 11, 2010, approximately 10:00 am**

Was water body influenced by storm water runoff during observations? Yes No

5. GENERAL CHARACTERISTICS OF WATER BODY (Instructions, Page 55)

a. Is the receiving water upstream of the discharges or proposed discharge site influenced by (check as appropriate):

- | | |
|---|---|
| <input type="checkbox"/> oil field activities | <input type="checkbox"/> urban runoff |
| <input type="checkbox"/> agricultural runoff | <input type="checkbox"/> septic tanks |
| <input type="checkbox"/> upstream discharges | <input checked="" type="checkbox"/> others, specify below |

Outfall 001 is located at the start of the un-named drainage ditch, and there is not an upstream component of the ditch.

b. Uses of water body, observed or evidences of (check as appropriate):

- | | | |
|--|---|--|
| <input checked="" type="checkbox"/> livestock watering | <input checked="" type="checkbox"/> contact recreation | <input type="checkbox"/> irrigation withdrawal |
| <input checked="" type="checkbox"/> non contact recreation | <input checked="" type="checkbox"/> fishing | <input type="checkbox"/> navigation |
| <input type="checkbox"/> domestic water supply | <input checked="" type="checkbox"/> industrial water supply | <input checked="" type="checkbox"/> picnic park activities |
| <input type="checkbox"/> others, specify below | | |

The un-named drainage ditch discharges to Gibbons Creek Reservoir. The potential uses of the Gibbons Creek Reservoir are checked above.

c. Check one of the following to best describe the aesthetics of the receiving water and the surrounding area:

- Wilderness: outstanding natural beauty; usually wooded or ungrazed area: water clarity exceptional
- Natural Area: trees and/or native vegetation common; some development evident (from fields, pastures, dwellings); water clarity discolored
- Common Setting: not offensive, developed but uncluttered; water may be colored or turbid
- Offensive: stream does not enhance aesthetics; cluttered; highly developed; dumping areas; water discolored

WORKSHEET 4.0 - RECEIVING WATERS

THE FOLLOWING IS REQUIRED FOR ALL TPDES PERMIT APPLICATIONS

1. DOMESTIC DRINKING WATER SUPPLY (Instructions, Page 54)

Is there a surface water intake for domestic drinking water supply located within 5 (five) miles downstream from the point/proposed point of discharge? _____ Yes No

If yes, identify owner of the drinking water supply, the distance and direction to the intake, and locate and identify the intake on the USGS map. Indicate by a check mark that the requested information is provided: N/A

2. DISCHARGE INTO TIDALLY INFLUENCED WATERS (Instructions, Page 54)

a. Width of the receiving water at the outfall? _____ feet **Not Applicable (the receiving waters of the discharge are not tidally influenced)**

b. Are there oyster reefs in the vicinity of the discharge? _____ Yes _____ No

If yes, indicate approximate distance and direction from outfall(s): Not Applicable

c. Are there any sea grasses within the vicinity of the point of discharge? _____ Yes _____ No **Not Applicable**

If yes, provide the distance and direction to the grasses: Not Applicable

3. CLASSIFIED SEGMENT (Instructions, Page 54)

Is the discharge directly into (or within 300 feet of) a classified segment? _____ Yes No

If yes, stop here. It is not necessary to complete items 4 and 5 and it is not necessary to complete Worksheet 2.1. If no, complete items 4 and 5.

4. DESCRIPTION OF IMMEDIATE RECEIVING WATERS (Instructions, Page 55)

Name of the immediate receiving waters: Outfall 002 is discharged directly to Big Branch Creek, then to Carlos Lake.

a. Check the appropriate description of the receiving waters

- Man-made Channel or Ditch
- Stream or creek
- Lake or Pond
- Surface area _____ acres. Average depth of the entire water body _____ feet
- Average depth of water body within a 500-foot radius or the discharge point _____ feet
- Freshwater Swamp or Marsh
- Tidal Stream, Bayou, or Marsh
- Open Bay
- Other: _____

If a man-made channel, ditch or stream was checked above, provide the following:

b. Check one of the following that best characterizes the area **upstream** of the discharge. For new discharges, characterize the area **downstream** of the discharge (check one).

- Intermittent (dry for at least one week during most years)
- Intermittent with Perennial Pools (enduring pools containing sufficient habitat to maintain significant aquatic life uses)
- Perennial (normally flowing)

Check the method used to characterize the area upstream (or downstream for new dischargers): USGS flow records, personal observation, historical observation by adjacent landowner(s), others, specify:

c. List the name(s) of all perennial streams that join the receiving water within three miles downstream of the discharge point:

Gibbons Creek, Peach Creek, and Rock Lake Creek

d. Do the receiving water characteristics change within three miles downstream of the discharge? (e.g., natural or man-made dams, ponds, reservoirs, etc.) Yes No

If yes, discuss how:

Carlos Lake discharges to Big Branch Creek, then to Gibbons Creek.

e. Provide general observations of the water body during normal dry weather conditions:

The water in Big Branch Creek is slightly turbid during normal, dry weather.

Date and time of observation: May 11, 2010, approximately 11:00 am

Was water body influenced by storm water runoff during observations? Yes No

5. GENERAL CHARACTERISTICS OF WATER BODY (Instructions, Page 55)

a. Is the receiving water upstream of the discharges or proposed discharge site influenced by (check as appropriate):

- | | |
|--|--|
| <input checked="" type="checkbox"/> oil field activities | <input type="checkbox"/> urban runoff |
| <input checked="" type="checkbox"/> agricultural runoff | <input checked="" type="checkbox"/> septic tanks |
| <input type="checkbox"/> upstream discharges | <input type="checkbox"/> others, specify below |

b. Uses of water body, observed or evidences of (check as appropriate):

- | | | |
|--|--|--|
| <input checked="" type="checkbox"/> livestock watering | <input type="checkbox"/> contact recreation | <input type="checkbox"/> irrigation withdrawal |
| <input checked="" type="checkbox"/> non contact recreation | <input checked="" type="checkbox"/> fishing | <input type="checkbox"/> navigation |
| <input type="checkbox"/> domestic water supply | <input type="checkbox"/> industrial water supply | <input checked="" type="checkbox"/> picnic park activities |
| <input type="checkbox"/> others, specify below | | |

c. Check one of the following to best describe the aesthetics of the receiving water and the surrounding area:

- Wilderness: outstanding natural beauty; usually wooded or ungrazed area; water clarity exceptional
- Natural Area: trees and/or native vegetation common; some development evident (from fields, pastures, dwellings); water clarity discolored
- Common Setting: not offensive, developed but uncluttered; water may be colored or turbid
- Offensive: stream does not enhance aesthetics; cluttered; highly developed; dumping areas; water discolored

WORKSHEET 4.0 - RECEIVING WATERS

THE FOLLOWING IS REQUIRED FOR ALL TPDES PERMIT APPLICATIONS

1. DOMESTIC DRINKING WATER SUPPLY (Instructions, Page 54)

Is there a surface water intake for domestic drinking water supply located within 5 (five) miles downstream from the point/proposed point of discharge? _____ Yes No

If yes, identify owner of the drinking water supply, the distance and direction to the intake, and locate and identify the intake on the USGS map. Indicate by a check mark that the requested information is provided: N/A

2. DISCHARGE INTO TIDALLY INFLUENCED WATERS (Instructions, Page 54)

a. Width of the receiving water at the outfall? _____ feet **Not Applicable (the receiving waters of the discharge are not tidally influenced)**

b. Are there oyster reefs in the vicinity of the discharge? _____ Yes _____ No

If yes, indicate approximate distance and direction from outfall(s): Not Applicable

c. Are there any sea grasses within the vicinity of the point of discharge? _____ Yes _____ No **Not Applicable**

If yes, provide the distance and direction to the grasses: Not Applicable

3. CLASSIFIED SEGMENT (Instructions, Page 54)

Is the discharge directly into (or within 300 feet of) a classified segment? _____ Yes No

If yes, stop here. It is not necessary to complete items 4 and 5 and it is not necessary to complete Worksheet 2.1. If no, complete items 4 and 5.

4. DESCRIPTION OF IMMEDIATE RECEIVING WATERS (Instructions, Page 55)

Name of the immediate receiving waters: Outfall 004 discharges to Gibbons Creek Reservoir.

a. Check the appropriate description of the receiving waters

_____ Man-made Channel or Ditch

_____ Stream or creek

Lake or Pond

Surface area 2,534 acres. Average depth of the entire water body 12 feet

Average depth of water body within a 500-foot radius or the discharge point 10 feet

_____ Freshwater Swamp or Marsh

_____ Tidal Stream, Bayou, or Marsh

_____ Open Bay

_____ Other: _____

If a man-made channel, ditch or stream was checked above, provide the following: **Not Applicable**

b. Check one of the following that best characterizes the area **upstream** of the discharge. For new discharges, characterize the area **downstream** of the discharge (check one).

_____ Intermittent (dry for at least one week during most years)

_____ Intermittent with Perennial Pools (enduring pools containing sufficient habitat to maintain significant aquatic life uses)

_____ Perennial (normally flowing)

Check the method used to characterize the area upstream (or downstream for new dischargers): USGS flow records, personal observation, historical observation by adjacent landowner(s), others, specify:
Not Applicable

c. List the name(s) of all perennial streams that join the receiving water within three miles downstream of the discharge point:
Gibbons Creek

d. Do the receiving water characteristics change within three miles downstream of the discharge? (e.g., natural or man-made dams, ponds, reservoirs, etc.) Yes No
 If yes, discuss how:

Not Applicable

e. Provide general observations of the water body during normal dry weather conditions:
The water in the Gibbons Creek Reservoir is slightly turbid during normal, dry weather conditions.

Date and time of observation: May 11, 2010, approximately 12:00 pm

Was water body influenced by storm water runoff during observations? Yes No

5. GENERAL CHARACTERISTICS OF WATER BODY (Instructions, Page 55)

a. Is the receiving water upstream of the discharges or proposed discharge site influenced by (check as appropriate):

<input checked="" type="checkbox"/> oil field activities	<input type="checkbox"/> urban runoff
<input checked="" type="checkbox"/> agricultural runoff	<input checked="" type="checkbox"/> septic tanks
<input checked="" type="checkbox"/> upstream discharges	<input type="checkbox"/> others, specify below

b. Uses of water body, observed or evidences of (check as appropriate):

<input checked="" type="checkbox"/> livestock watering	<input checked="" type="checkbox"/> contact recreation	<input type="checkbox"/> irrigation withdrawal
<input checked="" type="checkbox"/> non contact recreation	<input checked="" type="checkbox"/> fishing	<input type="checkbox"/> navigation
<input type="checkbox"/> domestic water supply	<input checked="" type="checkbox"/> industrial water supply	<input checked="" type="checkbox"/> picnic park activities
<input type="checkbox"/> others, specify below		

c. Check one of the following to best describe the aesthetics of the receiving water and the surrounding area:



Wilderness: outstanding natural beauty; usually wooded or unpastured area: water clarity exceptional

Natural Area: trees and/or native vegetation common; some development evident (from fields, pastures, dwellings); water clarity discolored


Common Setting: not offensive, developed but uncluttered; water may be colored or turbid

Offensive: stream does not enhance aesthetics; cluttered; highly developed; dumping areas; water discolored

**Placeholder for Copy of the Check Submitted to TCEQ for
the TPDES Permit Application Fee**



- LEGEND**
- TMPA PROPERTY BOUNDARY
 - DISCHARGE ROUTE WITHIN 3 MILES FROM DISCHARGE PIT
 - DISCHARGE ROUTE TO SEGMENT 1209
 - DISCHARGE POINTS
 - SURFACE WATER
 - MONITORING WELLS



Environmental Resources Management



ATTACHMENT 2
U.S.G.S. MAP
Texas Municipal Power Agency
Gibbons Creek Steam Electric Station
Carlos, Texas

DESIGN: RMA	DRAWN: CAK	CHKD: _____	SHEET NO. _____
DATE: 9/14/2010	SCALE: AS SHOWN	REV: _____	of _____
W.O.NO.: H:\DWG\100115940\002.dwg , 9/14/2010 10:59:22 AM			




SOURCE: U.S.G.S. 7.5' QUADRANGLES, KEITH, TX, 1962, PHOTOREVISED 1988, CARLOS, TX, 1960, PHOTOREVISED 1989, RELIANCE, TX, 1959, PHOTOREVISED 1980, AND FERGUSON CROSSING, TX, 1959, PHOTOREVISED 1980.

TO NAVASOTA RIVER BELOW LAKE
LIMESTONE, SEGMENT 1209

ERM Environmental Resources Management, Inc. TX P.E. Firm No. 2803




LEGEND

-  DRAINAGE AREAS PERMITTED UNDER TPDES PERMIT NO. 02120
-  OUTFALL 001
-  LEACHATE COLLECTION SYSTEM PIPING


DRAINAGE AREAS

- A = COAL PILE STORAGE & CONVEYANCE & MAINTENANCE
- B = POWER ISLAND, ASH PONDS, & LARGE SWITCH YARD
- C = ADMINISTRATIVE AREAS
- D = RAIL LOOP & UNLOADING AREA
- E = WAREHOUSE & FACILITY ENTRANCE ROAD
- F = SCRUBBER SLUDGE POND AREA
- G = SITE A LANDFILL
- H = SITE F LANDFILL





Environmental Resources Management

ATTACHMENT 3
 FACILITY SITE MAP
 Texas Municipal Power Agency
 Gibbons Creek Steam Electric Station
 Carlos, Texas











DESIGN: CRL	DRAWN: CAK	CHKD: CRL	SHEET NO.
DATE: 9/14/2010	SCALE: AS SHOWN	REV:	1 of 1
W.O.NO.: H:\DWG\10\0115940\003.dwg , 9/14/2010 11:01:30 AM			

ERM Environmental, Inc. 7507 Fossil 2006



LEGEND

-  TMPA GIBBONS CREEK STEAM ELECTRIC STATION PROPERTY
-  TMPA GIBBONS CREEK LIGNITE MINE PROPERTY
-  EASEMENT
-  LAKES & PONDS
-  SURROUNDING LANDOWNERS PROPERTY
-  TMPA PROPERTY BOUNDARY
-  DISCHARGE ROUTE
-  LANDOWNER REFERENCE NUMBER

NOTES:

1. THE AFFECTED LANDOWNERS TABLE (ATTACHMENT 4 OF THE 2004 TPDES PERMIT APPLICATION) LISTS THE NAMES AND ADDRESSES OF AFFECTED LANDOWNERS.



Environmental Resources Management

ATTACHMENT 4
AFFECTED LANDOWNERS MAP
TEXAS MUNICIPAL POWER AGENCY
Gibbons Creek Steam Electric Station
Carros, Texas



DESIGN: CMS	DRAWN: LM	CHKD: CRL	SHEET NO.
DATE: 9/14/2010	SCALE: AS SHOWN	REV.:	
W.O.NO.: H:\DWG\H00115940\004.dwg, 9/14/2010 11:02:08 AM			1 of 1

ATTACHMENT 5

TMPA TPDES PERMIT NO. 02120

<u>Ref. No.</u>	<u>Landowner</u>	<u>Ref. No.</u>	<u>Landowner</u>
8.	KEN BEENE %M MITCHELL BEENE 14390 FM 244 IOLA, TX 77861-366	9.	SECRETARY OF HOUSING & URBAN DEVELOPMENT C/O FIRST PRESTON FRCLR SPEC 5040 ADDISON CIRCLE #113 ADDISON, TX 75001-3352
12.	RS BUTAUD %RUSSELL BUTAUD 7354 CR 176 BEDIAS, TX 77831-9304	14.	SPEEDMAN BEACH PROPERTIES LP 9312 LAKE FORREST ST COLLEGE STATION, TX 77845
21.	MARY S CLAY 6102 WISTER LN HOUSTON, TX 77008-6246	25.	WANDA JUNE DAVIS 5917 HWY 30 ANDERSON, TX 77830-8903
26.	KENNARD A & PEGGY RAMSEY 10962 FM 244 ANDERSON TX 77830-6423	28.	LENA L FINLEY 8588 CR 173 IOLA, TX 77861-3601
30.	TRUMAN O FLYNT 7266 CR 166 IOLA, TX 77861-3579	31.	ROY AND SHERYL GILBERT 606 GIBBS ST NAVASOTA, TX 77868-4314
35.	PATRICIA GORNEY %ANGELA M GARNEY 6635 BELDART HOUSTON, TX 77087-6509	36.	KENNETH U AND MARY HACKNEY 1209 GLADE ST COLLEGE STATION TX 77840-4436
37.	TEXANNA FRANCES HEAD C/O RICHARD HEAD 11153 FOREST DR COLLEGE STATION, TX 77845-3112	38.	HC AND WIFE HILL 6119 DUMFRIES HOUSTON, TX 77096-4646
42.	MICHAEL E PULKKINEN 8703 ADA OAKS LN ANDERSON, TX 77830-8935	43.	JC HOWARD CHILDREN 5841 CR 157 IOLA, TX 77861-4362
46.	TAMMY PULKKINEN 8703 ADA OAKS DR ANDERSON, TX 77830-8935	49.	RUSSELL E & MARGARET RITZ 24114 RAINCREEK DR TOMBALL TX 77375

ATTACHMENT 5 (Cont'd)

TMPA TPDES PERMIT NO. 02120

<u>Ref. No.</u>	<u>Landowner</u>	<u>Ref. No.</u>	<u>Landowner</u>
50.	JAMES M AND ROBIN T JOHNSON 13715 FM 244 IOLA, TX 77861-3673	55.	LELAND L & KATHY ANN SYLVA 1120 FELDER ST NAVASOTA, TX 77868
58.	ROY LEE KOLBASINSKI % DIANNE E KOLBASINSKI 9590 FM 244 ANDERSON, TX 77830-8948	59.	RUTH J KOLBASINSKI 7480 HWY 30 ANDERSON, TX 77830-8231
60.	DANIEL E & MELISSA CROSS 1368 DUBARRY HOUSTON, TX 77018	64.	RAYMOND LAVENDER 4104 OLD HEARNE RD #46 BRYAN, TX 77803-0665
69.	HERBERT E ETUX MARTIN 13585 FM 244 IOLA, TX 77861-9506	73.	EDNA E MC DONALD 13998 FM 244 IOLA, TX 77861-3672
74.	FRED W MC DONALD 13998 FM 244 IOLA, TX 77861-3672	82.	THOMAS E PERRY JR 12261 TRAILS END LN BEDIAS, TX 77831-9431
87.	SMITH FAMILY PARTNERS LP % LINDA BEENE, GENERAL PART 3703 OLD OAKS BRYAN, TX 77802	88.	BRENDA JOY SMITH 9124 STEEP HOLLOW RD BRYAN, TX 77808-6600
91.	KEVIN AND MARTI STEPHENS 8628 CR 171 ANDERSON, TX 77830-7846	94.	KENNETH WAYNE TERRY 10850 FM 244 ANDERSON, TX 77830-6421
96.	PENELOPE SUE THOMAS 14222 BUGGY LANE COLLEGE STATION, TX 77845-6882	98.	BOBBY JOE TRANT 13769 FM 244 IOLA, TX 77861-3673
100.	HAROLD TRANT 14017 FM 244 IOLA, TX 77861-4092	101.	JAMES RAY & CYNTHIA TRANT 17968 FM 244 IOLA, TX 77861-3652
104.	OMA LEE VAUGHN 14058 FM 244 IOLA, TX 77861-3670	120.	VADA C JARVIS 8317 CR 171 ANDERSON, TX 77830



Outfall 001
Texas Municipal Power Agency
Gibbons Creek Steam Electric Station
Carlos, Texas



Outfall 001
Texas Municipal Power Agency
Gibbons Creek Steam Electric Station
Carlos, Texas




Outfall 002
Texas Municipal Power Agency
Gibbons Creek Steam Electric Station
Carlos, Texas



Outfall 003
Texas Municipal Power Agency
Gibbons Creek Steam Electric Station
Carlos, Texas



Outfall 004
Texas Municipal Power Agency
Gibbons Creek Steam Electric Station
Carlos, Texas



LEGEND

- ↑↑↑ EVAPORATION
- ▒ NOT CURRENTLY ACTIVE
- STREAM
- W [127.0] WATER STREAM
- LOW VOLUME WASTEWATER STREAM AS DEFINED IN TMPA'S TPDES PERMIT NO. 02120, OTHER REQUIREMENTS SECTION
- - - ONLY ACTIVE ON EMERGENCY BASIS
- - - FORECAST RE-ACTIVATING APRIL 2011

BASIS OF FLOW DATA

- [332.0] TPDES DISCHARGE MONITORING REPORTS
- [11.0] PROCESS KNOWLEDGE
- [59.0] RO UNIT/CLARIFIER OPERATING LOG (2002-2003)
- [4,000] FLOW METER READING (2007-2009)
- [54.0] HYDROLOGIC EVALUATION OF LANDFILL PERFORMANCE (HELP) MODEL
- [NEG] FLOW IS NEGLIGIBLE
- [55.0] ESTIMATED FLOW BASED ON INCOMING/OUTGOING STREAM FLOWS

NOTES:

- ALL FLOWS ARE IN THOUSAND GALLONS PER DAY.
- STORMWATER RUNOFF FLOWS ARE BASED ON HISTORICAL RAINFALL AVERAGE FOR COLLEGE STATION, TEXAS (APPROXIMATELY 1978 TO 2009).
- STORMWATER RUNOFF FLOWS OFFSITE IS COVERED BY GENERAL PERMIT.
- STREAMS B, C, D, E AND F ARE ESTIMATED BASED ON PRESSURE MEASUREMENTS TAKEN AT THE INTAKE LINE TO THE PUMP. FLOWS REPRESENT MAXIMUM POTENTIAL USAGE. ACTUAL FLOWS VARY BASED ON PROCESS NEEDS.
- OUTFALL 003 IS NOT ACTIVE, AND IS NOT SHOWN ON THIS WATER BALANCE.
- THE SUM OF FIRE PROTECTION SYSTEM WATER (XX), SERVICE AND YARD IRRIGATION SYSTEM WATER (MM), COAL DUST SUPPRESSION WATER (P), AND EVAPORATIVE LOSSES EQUAL 4 MGD PER AVAILABLE TMPA PROCESS KNOWLEDGE. RECORDS ARE NOT AVAILABLE TO QUANTIFY FLOWS FOR THESE SERVICES.
- STEAM NOT UTILIZED EXCEPT IN THE EVENT OF SEASONABLY HEAVY RAIN EVENTS.

Environmental Resources Management

ATTACHMENT 7
FACILITY WATER BALANCE
Texas Municipal Power Agency
Carlos, Texas

ERM

DESIGN: ER	DRAWN: JMH/RLM	CHKD.: CRL	SHEET NO. 1 of 1
DATE: 9/24/2010	SCALE: AS SHOWN	REV.:	
W.O.NO.: H:\DWG\1100115940\007.dwg, 9/24/2010 2:15:55 PM			

ERM-Scanned, Inc. T1, PE Firm No. 2393

Attachment 8 - Impoundment Liner Information

Impoundment: SAL Pond 1

Date Constructed: Between 1982 and 1992

Description of Liner:

According to Conversion Systems, Inc. design drawings (DWG No:F151L-L11, and DWG No:F151L-L16), dated August of 1982, "2' LOW PERMEABILITY LINER (WHERE REQ'D)" is called out for the SAL Pond 1 liner. This suggests that an in-situ liner was utilized elsewhere.

Limited geotechnical data are available in the vicinity of SAL Pond 1. Borings are summarized in "Solid Waste Management Manual for Gibbons Creek Steam Electric Station, Carlos, Grimes County, Texas, Site A Landfill" authored by Conversion Systems, Inc. and dated September, 1982. The closest boring with geotechnical data was drilled approximately 1,900 feet east-southeast of SAL Pond 1 (B-1). Another boring was drilled approximately 800 feet east-southeast of SAL Pond 1 (B-2) and suggests similar geological information as B-1.

Soil boring B-1 was drilled on January 20, 1982 to a total depth of 25 feet. Available data indicates:

- 0 – 19 feet below grade: "stiff dark brown silty clay"
- 19 – 25 feet below grade: "hard gray clay"

Within the range of 3 to 4.5 feet below grade, the following geotechnical parameters were obtained:

- %Passing No. 200 Sieve: 69.4
- Liquid Limit: 48
- Plastic Limit: 15

Soil boring B-2 was drilled on January 26, 1982 to a total depth of 40 feet. No geotechnical data is available with this boring, however the boring log indicates the following for B-2:

- 0 – 11 feet below grade: "hard light brown silty clay"
- 11 – 40 feet below grade: "hard gray clay"

In addition to B-1 and B-2, in 1983 a monitor well (LHMW3) was installed to a depth of 26.25 feet below grade approximately 200 feet east of SAL Pond 1. Monitoring well descriptions are presented in a transmittal from the Texas A&M University Center for Engineering Geosciences to the Gibbons Creek Steam Electric Station (GCSSES) dated November 11, 1986. The lithology at this most proximate location is described as "clays of the Caddell aquitard" which suggests a continuous clay rich soil layer in the vicinity of SAL Pond 1.

Impoundment information is documented in the *Phase IIf: Engineering Summary of Pond Design and Construction*, ERM, April 18, 2005.

Impoundment: SAL Pond 2

Date Constructed: Between 1982 and 1992

Description of Liner:

According to Conversion Systems, Inc. design drawings (DWG No:F151L-L11, and DWG No:F151L-L16), dated August of 1982 "2' LOW PERMEABILITY LINER (WHERE REQ'D)" is called out for the SAL Pond 2 liner. This suggests that an in-situ liner was utilized elsewhere.

Limited geotechnical data are available in the vicinity of SAL Pond 2. Borings are summarized in "Solid Waste Management Manual for Gibbons Creek Steam Electric Station, Carlos, Grimes County, Texas, Site A Landfill" authored by Conversion Systems, Inc. and dated September, 1982. The closest boring with associated geotechnical data was drilled approximately 250 feet west of SAL Pond 2 (B-3).

Soil boring B-3 was drilled on January 20, 1982 to a total depth of 25 feet. Available data indicates:

- 0 – 8' below grade: "very stiff dark brown silty clay"
- 8 – 16' below grade: "dense tan silty fine sand"
- 16 – 25' below grade: "hard light brown clay"

Within the range of 0 to 5.5 feet below grade, three geotechnical samples were analyzed. Geotechnical data is available for samples taken from 0.5-2 feet 25' below grade, 2.5-4 feet 25' below grade, and 4-5.5 feet 25' below grade. The following geotechnical parameters were obtained (in order of increasing depth):

- %Passing No. 200 Sieve: 89.3, 76.3, and 71.1
- Liquid Limit: 53, 56, and 52
- Plastic Limit: 10, 19, and 22

A monitoring well was installed to a depth of 15.59 feet below grade approximately 200 feet east of SAL Pond 2 (LHMW13) and indicates that below an 8 inch topsoil layer, a layer approximately 9 feet thick exists consisting of clays, clayey sand, silty clay, silty sand with clay, and sandy silt with clay.

Impoundment information is documented in the *Phase II: Engineering Summary of Pond Design and Construction*, ERM, April 18, 2005.

Impoundment: SAL Ponds 3 and 4

Date Constructed: Between 1982 and 1994

Description of Liner:

According to Conversion Systems, Inc. design drawings (DWG No:F151L-L11, and DWG No:F151L-L17), dated August of 1982 "2' LOW PERMEABILITY LINER (WHERE REQ'D)" is called out for the SAL Pond 3 and 4 liner. This suggests that an in-situ liner was utilized elsewhere.

Limited geotechnical data are available in the vicinity of SAL Pond 2. Borings are summarized in "Solid Waste Management Manual for Gibbons Creek Steam Electric Station, Carlos, Grimes County, Texas, Site A Landfill" authored by Conversion Systems, Inc. and dated September, 1982. The closest borings with associated geotechnical data were drilled approximately 950 feet north-west (B-7), 800 feet south-west (B-8) and 1,300 feet south-west (B-9) of SAL Pond 3. These borings are approximately 1,900 feet north (B-7), 1,200 feet north (B-8), and 1,000 feet northwest (B-9) of SAL Pond 4.

Soil boring B-7 was drilled on January 25, 1982 to a total depth of 38.5 feet. Available data indicates:

- 0 – 13' below grade: "dense tan silty fine sand"
- 13 – 33' below grade: "dense gray clayey fine sand"
- 33 – 38.5' below grade: "hard bluish-gray siltstone"

Within the range of 3 to 4.5 feet below grade, the following geotechnical parameters were obtained:

- %Passing No. 200 Sieve: 54.2
- Liquid Limit: 53
- Plastic Limit: 56

Soil boring B-8 was drilled on January 25, 1982 to a total depth of 25 feet. Available data indicates:

- 0 – 9' below grade: "dense tan silty fine sand, w/ clay seams"
- 9 – 25' below grade: "very stiff light brown clay"

Within the range of 6 to 7 feet below grade, the following geotechnical parameters were obtained:

- %Passing No. 200 Sieve: 88.4
- Liquid Limit: 78
- Plastic Limit: 29

Soil boring B-9 was drilled on January 23, 1982 to a total depth of 40 feet. Available data indicates:

- 0 – 23' below grade: "dense light gray silty fine sand" with clay seams at 7.4' and 14.5'
- 23 – 40' below grade: "very stiff brown clay"

Within the range of 3 to 4.5 feet below grade, the following geotechnical parameters were obtained:

- %Passing No. 200 Sieve: 74.4
- Liquid Limit: 54
- Plastic Limit: 37

In addition to B-7, B-8, and B-9, three monitoring wells were installed in the vicinity of SAL Ponds 3 and 4 for which geotechnical descriptions are available. Monitoring well descriptions are presented in a transmittal from the Texas A&M University Center for Engineering Geosciences to the Gibbons Creek Steam Electric Station (GCSES) dated November 11, 1986. In 1983 a monitor well (LHMW5) was installed to a depth of 38.28 feet below grade approximately 350 feet south-east of SAL Pond 3. The well description indicates that from grade to approximately 12 feet below grade the Middle Wellborn Sand, "a very fine grained silty sandstone to sandy siltstone" was encountered. From approximately 12 feet below grade, the Middle Wellborn Shale, "a ripple-laminated gray clay which is interlaminated with varying amounts of very fine sand and silt" was encountered.

Also in 1983 a monitor well (LHMW6) was installed to a depth of 72.25 feet below grade, approximately 400 feet west of SAL Pond 4. The well description indicates that from grade to approximately 38 feet below grade, the Middle Wellborn Shale was encountered. Following the 38 feet of laminated gray clay formation is an approximately 15 foot thick Bedias Sandstone, "light gray, slightly ferruginous, very fine grained silty sandstone to sandy siltstone" Layer followed by the Caddell Formation, "a shaly unit consisting of soft, cream colored, thin bedded sandy clay which contains numerous thin lenses of light gray, fine grained sandstone."

An additional monitor well (LHMW10) was installed to a depth of 72 feet below grade, south of LHMW6, but also approximately 400 feet west of SAL Pond 4. The well description indicates that from grade to approximately 23 feet below grade, the Middle Wellborn Sand was encountered followed by approximately 28 feet of Middle Wellborn Shale. From approximately 51.5 feet below grade to approximately 61 feet below grade, the Bedias Sandstone was encountered, followed by the Caddell Formation.

In 1993/1994, several ponds at the GCSES facility were upgraded to accommodate a new leachate collection system. SAL Ponds 3 and 4 were included in this project. According to a memo authored by Cook-Joyce Inc. in combination with their report, "Technical Specifications for Texas Municipal Power Agency Gibbons Creek Steam Electric Station Site "A" Ash Landfill Drainage Collection System" dated November 16, 1992, SAL Pond 4, "will be constructed by cut and fill methods to the configurations shown on the plans." In addition, the memo stated that SAL Ponds 3 and 4 "will be lined with two feet of clay as described in the Texas Department of Water Resources Industrial Solid Waste Technical Guideline No. 4." The clay lining techniques specified in the aforementioned technical specification document and accompanying figures include:

- Clay material will be taken from an approved on-site borrow source;
- Material containing foreign material will be discarded;
- The compacted sub-grade of the pond will be shaped by cut and fill methods to two feet below the lines and grades illustrated on the design drawings, scarified two inches in depth, and approved;
- The first lift will be placed, spread in a uniform horizontal lift not to exceed nine (9) inches loose thickness;
- The material will be compacted with a sheepsfoot roller to 95 percent;
- Each lift will be scarified to a minimum depth of two inches;
- The clay will be kept moist to prevent drying; and
- A one-foot protective cover will be placed over the compacted clay following the same procedure.

Impoundment information is documented in the *Phase II: Engineering Summary of Pond Design and Construction*, ERM, April 18, 2005.

Impoundment: SAL Ponds 5-10

Approximate Date Constructed: 1993-1994

Description of Liner:

According to the "Solid Waste Management Manual for Gibbons Creek Steam Electric Station, Carlos, Grimes County, Texas" authored by Conversion Systems, Inc. revised in September 1982, there is at least 8 feet of in-situ clay along the westerly portion of the Site A Landfill in the area where SAL Ponds 5-10 are located.

According to "Technical Specifications for Texas Municipal Power Agency Gibbons Creek Steam Electric Station Site "A" Ash Landfill Drainage Collection System" authored by Cook-Joyce Inc. and dated November 16, 1992, these ponds were to be lined with geomembrane liner. Plant personnel indicate that a compacted clay liner was installed in place of the proposed geomembrane liner. The clay lining techniques specified in the aforementioned technical specification document and accompanying figures include:

- Clay material will be taken from an approved on-site borrow source;
- Material containing foreign material will be discarded;
- The compacted sub-grade of the pond will be shaped by cut and fill methods to two feet below the lines and grades illustrated on the design drawings, scarified two inches in depth, and approved;
- The first lift will be placed, spread in a uniform horizontal lift not to exceed nine (9) inches loose thickness;
- The material will be compacted with a sheepsfoot roller to 95 percent;
- Each lift will be scarified to a minimum depth of two inches;
- The clay will be kept moist to prevent drying; and
- A one-foot protective cover will be placed over the compacted clay following the same procedure.

According to geotechnical testing performed by Buchanan Soil Mechanics, Inc. from December, 1993 through October, 1995 at least 5 lifts of clay were placed in the development of the liner of SAL Ponds 5-10. The testing done on the lifts indicate that the placed clay had the following range of properties over approximately 30 samples:

- %Passing No. 200 Sieve: 67.7-98.9
- Liquid Limit: 38-82
- Plasticity Index: 23-51
- Permeability: 1.60×10^{-9} – 9.28×10^{-8}

Impoundment information is documented in the *Phase II: Engineering Summary of Pond Design and Construction*, ERM, April 18, 2005.

Impoundment: SAL Ponds 11-12

Approximate Date Constructed: 1994-1995

Description of Liner:

According to the "Solid Waste Management Manual for Gibbons Creek Steam Electric Station, Carlos, Grimes County, Texas" authored by Conversion Systems, Inc. revised in September 1982, there is at least 8 feet of in-situ clay along the westerly portion of the Site A Landfill in the area where SAL Ponds 11 and 12 are located.

According to geotechnical testing performed by Buchanan Soil Mechanics, Inc. from December, 1993 through October, 1995 at least 6 lifts of clay were placed in the development of the liner of SAL Pond 11 and at least four lifts of clay were placed in the development of the liner of SAL Pond 12. The testing done on the lifts indicate that the placed clay had the following range of properties from approximately 13 samples:

- %Passing No. 200 Sieve: 69.0-96.5
- Liquid Limit: 47-73
- Plasticity Index: 24-47
- Permeability: 1.77×10^{-9} – 3.20×10^{-8}

Impoundment information is documented in the *Phase II: Engineering Summary of Pond Design and Construction*, ERM, April 18, 2005.

Impoundment: SFL Pond 3

Approximate Date Constructed: 1995

Description of Liner:

Limited geotechnical data are available in the vicinity of SFL Pond 3. Borings are summarized in "Texas Municipal Power Agency, Bryan, Texas, Site F Landfill Construction – Phase I" authored by Black & Veatch Engineers-Architects and issued received April 4, 1989. The three most proximate borings with available geotechnical data were drilled approximately 200 feet west (B-13), in the center of (B-14), and approximately 300 feet south-east (B-15) of SFL Pond 3.

Soil boring B-13 was drilled on February 29, 1988 to a total depth of 50 feet. Available data indicates varying layers of clayey sand, and silty clay to a depth of 50 feet. Within the range of 8 to 10 feet below grade, the following geotechnical parameters were obtained:

- Liquid Limit: 60
- Plastic Limit: 26
- Plasticity Index: 34

Soil boring B-14 was drilled approximately in the middle of the current SFL Pond 3 on February 29, 1988 to a total depth of 50 feet. Available data indicates varying layers of sandy clay, clay, and silty clay to a depth of 28 feet. Within the range of 13 to 15 feet below grade, the following geotechnical parameters were obtained:

- %Passing No. 200 Sieve: 16
- Liquid Limit: 26
- Plastic Limit: 23
- Plasticity Index: 3

Soil boring B-15 was drilled on February 23, 1988 to a total depth of 35 feet. Available data indicates a 2 foot layer of undifferentiated overburden over varying layers of silty clay, sandy clay, and clayey sand to a depth of 10 feet underlain by sandstone to 38 feet. Within the range of 3 to 4 feet below grade, the following geotechnical parameters were obtained:

- %Passing No. 200 Sieve: 50
- Liquid Limit: 50
- Plastic Limit: 18
- Plasticity Index: 32

According to geotechnical testing summarized in "Site "F" Ash Landfill Expansion" authored by K.W. Brown Environmental Services and dated in segments from July through October 1995, forty-two (42) undisturbed soil samples were taken from the SFL liner for laboratory analysis. The properties of the liner tests indicate the following ranges of data:

- %Passing No. 200 Sieve: 27.4-89.2
- Liquid Limit: 33-79
- Plasticity Index: 17-56
- Permeability: 2.33×10^{-9} – 1.29×10^{-6}

Impoundment information is documented in the *Phase II: Engineering Summary of Pond Design and Construction*, ERM, April 18, 2005.

TMPA TPDES Permit No. 02120

Attachment 9

- Sodium Hypochlorite (12% solution) [Product name: *Eco San*] is added to the cooling water. The MSDS is attached.
 - Per a telephone conversation with Sue Fusco of Ecolab on July 8, 2004, tests have not been conducted on *Eco San* to determine the toxicity to fish and aquatic invertebrate or the half-life of sodium hypochlorite. Additionally, Ecolab noted that chlorine in this product is not persistent and does not bioaccumulate; however, the environmental factors will affect the rate of decomposition. The manufacture product ID is 13987.
 - TMPA adds *Eco San* to the cooling water at a total dose of approximately 6 gallons per day over a one-hour period.

- Sodium Bromide (40% solution) is added to the cooling water. The MSDS is attached.
 - Per a telephone conversation with Suren Mishra of TETRA on July 8, 2004, sodium bromide is very water-soluble, therefore, it is non-persistent and does not bioaccumulate. Since TETRA does not manufacture this product, the manufacture product identification number is not applicable.
 - TMPA adds sodium bromide to the cooling water at a total dose of approximately 1.5 gallons per day over a one-hour period.

- Eliminox is added to the boiler make-up. The MSDS is attached.
 - Per a telephone conversation with Hazal Huang of Nalco on July 8, 2004, Eliminox has a half-life of 14 days. Additionally, Nalco noted that Eliminox is non-persistent and does not bioaccumulate. Since Nalco does not manufacture this product, the manufacture product identification number is not applicable.
 - TMPA adds Eliminox to the boiler make-up at a total dose of approximately 2.75 gallons per day over a one-day period.

- Caustic is added to the make-up demineralizer and will be added to the Scrubber Purge Treatment System. The MSDS is attached.
 - Per telephone conversation with Frank Cook of Old World on July 8, 2004, caustic is non-persistent. Since Old World does not manufacture this product, the manufacture product identification number is not applicable.
 - TMPA adds caustic to the make-up demineralizer at a dose of approximately 8,300 pounds per month.
 - The amount of caustic that will be added to the Scrubber Purge Treatment System is yet to be determined.

- Sulfuric acid is added to the make-up demineralizer. The MSDS is attached.
 - Per telephone conversations with Mike Salzbrenner of DuPont on July 8, 2004, sulfuric acid is slightly to moderate toxic to aquatic life. Additionally, DuPont also noted the following: the study indicates that the 96-hour LD50 with blue gill sunfish is 10.5 ppm

and 42-hour TLM w/ flounder ranges from 100 to 200 ppm; this product reportedly does not bioaccumulate.

- TMPA adds sulfuric acid to the make-up demineralizer at a dose of approximately 8,300 pounds per month.
- Aluminum sulfate (48% solution) is added to the make-up clarifier. The MSDS is attached.
 - Per a telephone conversation with Univar, Univar has not performed any toxicity tests for aluminum sulfate. Since Univar does not manufacture this product, the manufacture product identification number is not applicable.
 - TMPA adds aluminum sulfate to the make-up demineralizer at a dose of approximately 16 gallons per day.
- Ferric chloride will be added to the Scrubber Purge Treatment System. The actual product to be used is undetermined at this time, and the MSDS will be provided when actual product to be used is determined.
 - The amount of ferric chloride that will be added to the Scrubber Purge Treatment System is yet to be determined.
- Organo Sulfide will be added to the Scrubber Purge Treatment System. The actual product to be used is undetermined at this time and the MSDS will be provided when actual product to be used is determined.
 - The amount of organo sulfide that will be added to the Scrubber Purge Treatment System is yet to be determined.

Eco San (Sodium Hypochlorite, 12% Solution)
Material Safety Data Sheet

Handwritten signature

900043

MATERIAL SAFETY DATA SHEET

MEDICAL EMERGENCY ONLY, 24 HOUR SERVICE: 1-800-328-0026

ECOLAB INC ECOLAB CENTER
ST. PAUL MN 55102

PRODUCT INFORMATION: 1-612-293-2233
DATE OF ISSUE: MARCH 26, 1990

1.0 IDENTIFICATION /

- 1.1 PRODUCT NAME: ECO SAN
- 1.2 PRODUCT TYPE: LIQUID SODIUM HYPOCHLORITE

++ SECTION 2 PROVIDES SARA SECTION 313 REPORTING INFORMATION ++

2.0 HAZARDOUS COMPONENTS /

AIR LIMITS (MG/M3)		
%	TWA	OTHER
8.4	*	*

- 2.1 SODIUM HYPOCHLORITE 7681-52-9
* (TWA FOR CHLORINE = 1.5; STEL = 3)

THIS PRODUCT CONTAINS NO OTHER COMPONENT CONSIDERED HAZARDOUS ACCORDING TO THE CRITERIA OF 29 CFR 1910.1200.

3.0 PHYSICAL DATA /

- 3.1 APPEARANCE: CLEAR LIGHT YELLOW LIQUID WITH CHLORINE ODOR
- 3.2 SOLUBILITY IN WATER: COMPLETE
- 3.3 PH: (1%) 10.5
- 3.4 BOILING POINT: > 212 DEG F SPECIFIC GRAVITY: 1.16-1.17

4.0 FIRE AND EXPLOSION DATA /

- 4.1 SPECIAL FIRE HAZARDS: SEE LINE 5.1
- 4.2 FIRE FIGHTING METHODS: PRODUCT DOES NOT SUPPORT COMBUSTION.

5.0 REACTIVITY DATA /

- 5.1 STABILITY: HIGH TEMPERATURES MAY GENERATE HAZARDOUS DECOMPOSITION PRODUCTS INCLUDING CHLORINE GAS.
- 5.2 CONDITIONS TO AVOID: MIX ONLY WITH WATER. DO NOT MIX WITH ACIDS OR AMMONIA - WILL CAUSE HAZARDOUS VAPORS.

6.0 SPILL OR LEAK PROCEDURES / USE PROPER PROTECTIVE EQUIPMENT

- 6.1 CLEANUP: DIKE OR DAM LARGE SPILLS. PUMP TO CONTAINERS OR SOAK UP ON INERT ABSORBENT. FLUSH RESIDUE TO SANITARY SEWER.
- 6.2 WASTE DISPOSAL: UNUSED PRODUCT AS A WASTE IS CORROSIVE (D002) BY RCRA CRITERIA.

UNK = UNKNOWN AT THIS TIME PEL = PERMISSIBLE EXPOSURE LIMIT
TWA = OSHA 8 HOUR AVERAGE STEL = 15 MINUTE AVERAGE
C = CEILING LIMIT, NOT TO BE EXCEEDED

PRODUCT: ECO SAN
ECOLAB INC ECOLAB CENTER
MEDICAL EMERGENCY ONLY, 24 HOUR SERVICE: 1-800-328-0026

PAGE 2 OF 2 1,171
900043

7.0 HEALTH HAZARD DATA /

DANGER

7.1 EFFECTS OF OVEREXPOSURE:

SKIN AND EYES: CAUSES CHEMICAL BURNS. EYE CONTACT MAY CAUSE BLINDNESS.

IF SWALLOWED: HARMFUL. CAUSES CHEMICAL BURNS OF MOUTH, THROAT AND STOMACH.

IF INHALED: VAPORS OR MIST CAUSE IRRITATION, INCLUDING A BURNING TASTE, SNEEZING, COUGHING AND DIFFICULTY BREATHING. PEOPLE WITH ASTHMA OR OTHER LUNG PROBLEMS MAY BE MORE SUSCEPTIBLE.

8.0 FIRST AID /

8.1 EYES: IMMEDIATELY FLUSH WITH PLENTY OF COOL RUNNING WATER. REMOVE CONTACT LENSES. CONTINUE FLUSHING FOR AT LEAST 15 MINUTES, HOLDING EYELIDS APART TO ENSURE RINSING OF THE ENTIRE EYE.

CALL A PHYSICIAN IMMEDIATELY.

8.2 SKIN: IMMEDIATELY FLUSH SKIN WITH PLENTY OF COOL RUNNING WATER FOR AT LEAST 15 MINUTES WHILE REMOVING CONTAMINATED CLOTHING AND SHOES. WASH CLOTHING BEFORE REUSE.

8.3 IF SWALLOWED: RINSE MOUTH AT ONCE; THEN DRINK 1 OR 2 LARGE GLASSES OF WATER OR MILK. DO NOT INDUCE VOMITING. NEVER GIVE ANYTHING BY MOUTH TO AN UNCONSCIOUS PERSON.

8.4 IF INHALED: IMMEDIATELY MOVE TO FRESH AIR.

CALL A POISON CONTROL CENTER OR PHYSICIAN IMMEDIATELY

9.0 SPECIAL PROTECTION INFORMATION /

9.1 RESPIRATORY: AVOID BREATHING MISTS OR VAPORS OF THIS PRODUCT.

9.2 SKIN: RUBBER GLOVES - PROTECTIVE CUFF OR GAUNTLET TYPE PREFERRED.

9.3 EYES: SPLASHPROOF GLASSES, GOGGLES OR FACE SHIELD.

10.0 ADDITIONAL INFORMATION/PRECAUTIONS /

10.1 DOT CLASS: HYPOCHLORITE SOLUTION / CORROSIVE / UN1791

KEEP OUT OF REACH OF CHILDREN

THE ABOVE INFORMATION IS BELIEVED TO BE CORRECT WITH RESPECT TO THE FORMULA USED TO MANUFACTURE THE PRODUCT. AS DATA, STANDARDS AND REGULATIONS CHANGE, AND CONDITIONS OF USE AND HANDLING ARE BEYOND OUR CONTROL, NO WARRANTY, EXPRESS OR IMPLIED, IS MADE AS TO THE COMPLETENESS OR CONTINUING ACCURACY OF THIS INFORMATION.

Sodium Bromide, 40% Solution
Material Safety Data Sheet



TETRA Technologies, Inc.

Material Safety Data Sheet

This MSDS Sheet complies with the style format specified by ANSI Z400.1-1993

SECTION 1: CHEMICAL PRODUCT - COMPANY IDENTIFICATION

TETRA Technologies, Incorporated
25025 I-45 North
The Woodlands, Texas 77380
(214) 367-1983
(800) 327-7817

(800) 424-9300 - CHEMTREC (24 Hour Emergency Response)

SUBSTANCE: Sodium Bromide Solution
TRADE NAMES/SYNONYMS: BioRID™ 40i, Liquid Sodium Bromide, NaBr
CHEMICAL FAMILY: Inorganic Salt
MSDS CREATION DATE: 03 AUG 98
MSDS REVISION DATE: 03 AUG 98

SECTION 2: COMPOSITION, INFORMATION ON INGREDIENTS

COMPONENTS: Sodium Bromide, Water
CAS NUMBER: 7647-15-6 (Sodium Bromide), 7732-18-5 (Water)
RTECS NUMBER: VZ3150000 (Sodium Bromide)
PERCENTAGE: Sodium Bromide 1 - 45%
Water 54 - 99%
PROBABLE CONTAMINANT: Sodium Chloride

SECTION 3: HAZARDS IDENTIFICATION

NFPA RATINGS: (SCALE 0-4): HEALTH=0, FIRE=0, REACTIVITY=0

EMERGENCY OVERVIEW: Odorless, colorless, clear liquid. May cause skin, respiratory tract and eye irritation. Do not get in eyes, on skin or on clothing. May be harmful if swallowed but not an expected pathway in an industrial environment. Keep container tightly closed. Wash thoroughly after handling. Use only with adequate ventilation.



TETRA Technologies, Inc.

Material Safety Data Sheet

This MSDS Sheet complies with the style format specified by ANSI Z400.1-1993

POTENTIAL HEALTH EFFECTS:**INHALATION:**

Short Term Effects: May cause irritation

Long Term Effects: No information available.

SKIN CONTACT:

Short Term Effects: No information available.

Long Term Effects: No information available.

EYE CONTACT:

Short Term Effects: May cause irritation. Additional effects may include tearing.

Long Term Effects: No information available.

INGESTION:

Short Term Effects: May cause nausea, vomiting, digestive disorders, headache and kidney damage.

Long Term Effects: No information available.

CARCINOGEN STATUS:

OSHA: No NTP: No IARC: No

SECTION 4: FIRST AID MEASURES

INHALATION: Remove from exposure area to fresh air immediately. If breathing has stopped, perform artificial resuscitation. Keep person comfortable and at rest. Treat symptomatically and supportively. Get medical attention immediately.

SKIN CONTACT: Remove contaminated clothing and shoes immediately. Wash affected area with soap or mild detergent and large amounts of water until no evidence of chemical remains (at least 15-20 minutes). In cases of burns, cover area loosely with sterile, dry dressing. Get medical attention immediately.

EYE CONTACT: Flush eyes immediately with large amounts of water or normal saline solution, occasionally lifting upper and lower lids until no evidence of chemical remains (approximately 15-20 minutes). Get medical attention immediately.

INGESTION: Treat symptomatically and supportively. Get medical attention immediately. If vomiting occurs, keep head lower than hips to prevent aspiration.

NOTE TO PHYSICIAN: Antidote:

Antidote should be administered by qualified medical personnel. No specific antidote has been recommended. Treat symptomatically and supportively. The following antidote has been recommended for bromide poisoning. However, the decision as to whether the severity of poisoning requires administration of any antidote and actual dose required should be made by qualified medical personnel.



TETRA Technologies, Inc.

Material Safety Data Sheet

This MSDS Sheet complies with the style format specified by ANSI Z400.1-1993

BROMIDE POISONING: Give sodium chloride, 1 gram orally every hour in water or as salt tablets; for severe involvement in which oral medication is impossible, give normal saline, 1 liter every 8 hours intravenously to a maximum of 2 liters daily. Sodium chloride therapy must be continued until the blood bromide level drops below 50 mg/dL. Simultaneous administration of diuretics is also useful (Driesbach, Handbook of Poisoning, 12th Ed.).

SECTION 5: FIRE FIGHTING MEASURES

FIRE AND EXPLOSION HAZARD: Negligible fire hazard when exposed to heat or flame.

EXTINGUISHING MEDIA: Dry chemical, carbon dioxide, water spray or regular foam. For larger fires, use water spray, fog or regular foam.

FIRE FIGHTING: Move container(s) from fire area if you can without risk. Apply cooling water to sides of containers that are exposed to flames until well after fire is out. Extinguish fire using agent suitable for type of surrounding fire and/or chemicals. Do not use water directly on material. Avoid breathing corrosive vapors; keep upwind. Dike area to prevent runoff and contamination of water sources.

HAZARDOUS COMBUSTION PRODUCTS: Thermal decomposition products may include toxic and corrosive fumes of bromine, hydrogen bromide and sodium oxide. Product may react with some metals (aluminum, zinc, tin, etc.) to release flammable hydrogen gas.

SECTION 6: ACCIDENTAL RELEASE MEASURES

OCCUPATIONAL SPILL: Do not touch spilled material. Stop leak if you can without risk. For small spills, take up with sand or other absorbent material and place in containers for disposal. Move containers from spill area. For larger spills, dike far ahead of spill for later disposal. Keep unnecessary people away. Isolate hazard area and deny entry.

SECTION 7: HANDLING AND STORAGE

Observe all federal, state and local regulations when storing this product. Store in a tightly closed container. Store away from incompatible materials.



TETRA Technologies, Inc.

Material Safety Data Sheet

This MSDS Sheet complies with the style format specified by ANSI Z400.1-1993

SECTION 8: EXPOSURE CONTROLS, PERSONAL PROTECTION

EXPOSURE LIMITS: No occupational exposure limits established by OSHA/ACGIH/NIOSH.

VENTILATION: Provide local exhaust ventilation system.

EYE PROTECTION: Wear safety glasses with splash shields or safety goggles/shield to prevent contact with this product.

EMERGENCY WASH FACILITIES: Where there is any possibility that an employee's eyes and/or skin may be exposed to this product, the employer should provide an eye wash fountain and quick drench shower within the immediate work area for emergency use.

CLOTHING: Employee must wear appropriate protective (impervious) clothing and equipment to prevent repeated or prolonged skin contact with this product.

GLOVES: Employee must wear appropriate protective gloves to prevent contact with this product.

RESPIRATOR: The respirator selected must be based on contamination levels found in the work place and specific to the job assignment. Do not exceed the working limits of the respirator. Respirators must also be jointly approved by the National Institute for Occupational Safety and Health and the Mine Safety and Health Administration (NIOSH-MSHA). These respirators are ranked from minimum to maximum respiratory protection as listed below:

- Any dust and mist respirator with a full facepiece;
- Any air-purifying full facepiece respirator with a high-efficiency particulate filter;
- Any powered air-purifying respirator with a tight-fitting facepiece and high-efficiency particulate filter;
- Any Type 'C' supplied-air respirator with a full facepiece operated in pressure-demand or other positive-pressure mode or with a full facepiece, helmet or hood operated in continuous-flow mode;
- Any self-contained breathing apparatus with a full facepiece operated in pressure-demand or other positive-pressure mode.

FOR FIREFIGHTING AND OTHER IMMEDIATELY DANGEROUS TO LIFE OR HEALTH

CONDITIONS: Any self-contained breathing apparatus that has a full facepiece and is operated in a pressure-demand or other positive-pressure mode. Any supplied-air respirator that has a full facepiece and is operated in a pressure-demand or other positive-pressure mode in combination with an auxiliary self-contained breathing apparatus operated in pressure-demand or other positive-pressure mode.



TETRA Technologies, Inc.

Material Safety Data Sheet

This MSDS Sheet complies with the style format specified by ANSI Z400.1-1993

SECTION 9: PHYSICAL AND CHEMICAL PROPERTIES

DESCRIPTION: Odorless, colorless, clear liquid.

FORMULA: NaBr

MOLECULAR WEIGHT: 102.90 (for pure NaBr)

BOILING POINT: Not determined.

SPECIFIC GRAVITY: 1.007 - 1.522 @ 68°F (20°C)

WATER SOLUBILITY: Miscible with water in all proportions.

SOLVENT SOLUBILITY: Slightly to moderately soluble in alcohol.

SECTION 10: STABILITY AND REACTIVITY

REACTIVITY: Stable under normal temperatures and pressures. Can evolve hydrogen bromide and/or bromine when strongly heated.

CONDITIONS TO AVOID: Vapors may accumulate in tanks and hopper cars.

INCOMPATIBILITIES:

Strong acids, strong oxidizers and metal salts.

HAZARDOUS DECOMPOSITION: Thermal decomposition products may include toxic and corrosive fumes of hydrogen bromide, bromine and sodium oxide.

POLYMERIZATION: Hazardous polymerization has not been reported to occur under normal temperatures and pressures.

SECTION 11: TOXICOLOGICAL INFORMATION

TOXICITY DATA (SODIUM BROMIDE):

LD₅₀: 3500 mg/kg, rat, oral

LD₅₀: 2900 mg/kg, rat, subcutaneous

Mutagenic data and tumorigenic data-see Registry of Toxic Effects of Chemical Substances (RTECS) file.

CARCINOGEN STATUS: None.

LOCAL EFFECTS: Sodium Bromide is an eye, mucous membrane and skin irritant.

ACUTE TOXICITY LEVEL: Moderately toxic by ingestion.

TARGET EFFECTS: No data available.

INHALATION:

Acute Exposure: Inhalation of mist may cause irritation with coughing and shortness of breath.

Chronic Exposure: No data available.



TETRA Technologies, Inc.

Material Safety Data Sheet

This MSDS Sheet complies with the style format specified by ANSI Z400.1-1993

SKIN CONTACT:

Acute Exposure: Single, short exposure not likely to cause significant skin irritation. However, direct contact with dust or solutions may cause severe irritation, erythema, blistering, exfoliation, ulceration, necrosis and scarring. The degree of irritation depends on the concentration and duration of contact.

Chronic Exposure: Effects depend on concentration and duration of exposure. Repeated or prolonged contact with corrosive substances may result in dermatitis or effects similar to those in acute exposure.

EYE CONTACT:

Acute Exposure: Direct contact may cause irritation with redness and pain and superficial injury. Tearing and eye discharge may also occur.

Chronic Exposure: Repeated or prolonged exposure may result in conjunctivitis.

INGESTION:

Acute Exposure: Poisoning by acute exposure is rare because bromides irritate the gastric mucosa when ingested in large amounts as a single dose and cause immediate abdominal pain, nausea and vomiting.

Chronic Exposure: Repeated or prolonged ingestion of bromides may cause "bromism" which most frequently affects the gastrointestinal system, the central nervous system, and the skin. Gastrointestinal disturbances may include nausea and vomiting from gastric irritation, foul breath, weight loss, dehydration, and constipation. Neurological manifestations may include headache, decreased memory, impaired intellectual capacity, and ataxia. Discontinuation of exposure will normally result in reversal of symptoms. Maternal exposure may result in hypotonia in neonates. May cause abdominal spasms and nausea. Overdose may cause gastrointestinal tract or cardiovascular irregularities.

SECTION 12: ECOLOGICAL INFORMATION

ENVIRONMENTAL IMPACT RATING (0-4): No data available.

ECOTOXICITY DATA:

Fish Toxicity: 16,000,000 µg/L, 96 hour(s), LC₅₀ (Mortality), Guppy (*Poecilia reticulata*)

Invertebrate Toxicity: 5,700,000 - 10,800,000 µg/L, 48 hour(s), EC₅₀ (Immobilization), Water flea (*Daphnia magna*)

DEGRADABILITY: No data available.

LOG BIOCONCENTRATION FACTOR (BCF): No data available.

LOG OCTANOL/WATER PARTITION COEFFICIENT: No data available.

SECTION 13: DISPOSAL INFORMATION

Observe all federal, state and local regulations when disposing of this substance.



TETRA Technologies, Inc.

Material Safety Data Sheet

This MSDS Sheet complies with the style format specified by ANSI Z400.1-1993

SECTION 14: TRANSPORT INFORMATION

US DOT Shipping Name-ID Number: No classification assigned.

Air Transport IATA/ICAO: No classification assigned.

Maritime Transport IMDG: No classification assigned.

Land Transport ADR/RID: No classification assigned.

SECTION 15: REGULATORY INFORMATION

United States:

	TSCA STATUS:	Yes
40 CFR 302.4	CERCLA SECTION 103:	No
40 CFR 355.30	SARA SECTION 302:	No
40 CFR 355.40	SARA SECTION 304:	No
40 CFR 372.65	SARA SECTION 313:	No
40 CFR 370.21	SARA HAZARD CATEGORIES, SARA SECTIONS 311/312	
	ACUTE HAZARD:	No
	CHRONIC HAZARD:	No
	FIRE HAZARD:	No
	REACTIVITY HAZARD:	No
	SUDDEN RELEASE HAZARD:	No
29 CFR 1910.119	OSHA Process Safety	No
	STATE REGULATIONS:	
	CALIFORNIA PROPOSITION 65:	No

Foreign:

CANADIAN		
	DOMESTIC SUBSTANCE LIST (DSL)	Yes
	NON-DOMESTIC SUBSTANCE LIST (NDSL)	No
	EUROPEAN REGULATIONS (EINECS)	Yes
	AUSTRALIAN INVENTORY OF CHEMICAL SUBSTANCES (AICS)	Yes
	JAPAN INVENTORY STATUS (ENCS)	Yes
	KOREA (ECL)	Yes



TETRA Technologies, Inc.

Material Safety Data Sheet

This MSDS Sheet complies with the style format specified by ANSI Z400.1-1993

SECTION 16: OTHER INFORMATION

Individuals handling this product should be informed of the recommended safety precautions and should have access to this information.

This information relates to the specific product designated and may not be valid for such product used in combination with any other materials or in any other processes. Such information is to the best of our knowledge and belief, accurate and reliable as of the date compiled. However, no representation, warranty or guarantee is made as to its accuracy, reliability, or completeness. It is the user's responsibility to satisfy themselves as to the suitability and completeness of such information for their own particular use. We do not accept liability for any loss or damage that may occur from the use of this information nor do we offer warranty against patent infringement.

TETRA Technologies, Incorporated reserves the right to refuse shipment of this product to any consumer who fails to demonstrate the ability to consistently handle and use it safely and in compliance with all applicable laws, rules and regulations. Such demonstration may require on-site inspection of any or all storage, processing, packaging and other handling systems that come in contact with it.

Customers are responsible for compliance with local, state and federal regulations that may be pertinent in the storage, application and disposal of this product.

Eliminox
Material Safety Data Sheet



MATERIAL SAFETY DATA SHEET

PRODUCT

ELIMIN-OX OXYGEN SCAVENGER

877-813-3523

Emergency Telephone Number

Medical (800) 462-5378 (24 hours)

(800) I-M-ALERT

SECTION 1 PRODUCT IDENTIFICATION

TRADE NAME: ELIMIN-OX OXYGEN SCAVENGER

DESCRIPTION: An aqueous solution of a modified amino compound

NFPA 704M/HMIS RATING: 1/1 HEALTH 0/0 FLAMMABILITY 0/0 REACTIVITY 0 OTHER
0=Insignificant 1=Slight 2=Moderate 3=High 4=Extreme

SECTION 2 HAZARDOUS INGREDIENTS

Our hazard evaluation of the ingredient(s) under OSHA's Hazard Communication Rule, 29 CFR 1910.1200 has found none of the ingredient(s) hazardous.

SECTION 3 PRECAUTIONARY LABEL INFORMATION

CAUTION: May cause skin irritation. Avoid contact with skin and clothing. Avoid prolonged or repeated breathing of vapor. Use with adequate ventilation. Do not take internally.

Empty containers may contain residual product. Do not reuse container unless properly reconditioned.

SECTION 4 FIRST AID INFORMATION

EYES: Flush with water for 15 minutes.
SKIN: Flush with water for 15 minutes.
INGESTION: Induce vomiting. Give water. Call a physician.
INHALATION: Remove to fresh air. Treat symptoms. Call a physician.

NOTE TO PHYSICIAN: Based on the individual reactions of the patient, the physician's judgment should be used to control symptoms and clinical condition.

CAUTION: If unconscious, having trouble breathing or in convulsions, do not induce vomiting or give water.

SECTION 5 HEALTH EFFECTS INFORMATION

PRIMARY ROUTE(S) OF EXPOSURE: Eye, Skin

EYE CONTACT: Non-irritating.
SKIN CONTACT: Can cause mild, short-lasting irritation.

SYMPTOMS OF EXPOSURE: A review of available data does not identify any symptoms from exposure.

AGGRAVATION OF EXISTING CONDITIONS: A review of available data does not



MATERIAL SAFETY DATA SHEET

PRODUCT

ELIMIN-OX OXYGEN SCAVENGER

Emergency Telephone Number

Medical (800) 462-5378 (24 hours)

(800) I-M-ALERT

SECTION 5 HEALTH EFFECTS INFORMATION

(CONTINUED)

identify any worsening of existing conditions.

SECTION 6 TOXICOLOGY INFORMATION

ACUTE TOXICITY STUDIES: Acute toxicity studies have been conducted on this product. The results are shown below.

ACUTE ORAL TOXICITY (ALBINO RATS): LD₅₀ = Greater than 5 g/kg

ACUTE DERMAL TOXICITY (ALBINO RABBITS): LD₅₀ = Greater than 2 g/kg

PRIMARY SKIN IRRITATION TEST (ALBINO RABBITS):

SKIN IRRITATION INDEX DRAIZE RATING: 0.23/8.0 Minimal irritation

PRIMARY EYE IRRITATION TEST (ALBINO RABBITS):

EYE IRRITATION INDEX DRAIZE RATING: 0.33/110.0 Practically non-irritating

SECTION 7 PHYSICAL AND CHEMICAL PROPERTIES

COLOR: Colorless	FORM: Liquid	
DENSITY:	8.5-8.6 lbs/gal.	
SOLUBILITY IN WATER:	Completely	
SPECIFIC GRAVITY:	1.02-1.03 @ 60 Degrees F	ASTM D-1298
pH (NEAT) =	6 - 10 pH (at 1%) 6.7	ASTM E-70
VISCOSITY:	3 cps @ 60 Degrees F	ASTM D-2983
FREEZE POINT:	28 Degrees F	ASTM D-1177
FLASH POINT:	None (PMCC)	ASTM D-93

NOTE: These physical properties are typical values for this product.

SECTION 8 FIRE AND EXPLOSION INFORMATION

FLASH POINT: None (PMCC) ASTM D-93

EXTINGUISHING MEDIA: Not applicable

UNUSUAL FIRE AND EXPLOSION HAZARD: May evolve NO_x under fire conditions. Containers exposed in a fire should be cooled with water to prevent vapor pressure buildup leading to a rupture.

SECTION 9 REACTIVITY INFORMATION

INCOMPATIBILITY: Avoid mineral acids and nitrites.



MATERIAL SAFETY DATA SHEET

PRODUCT

ELIMIN-OX OXYGEN SCAVENGER

Emergency Telephone Number

Medical (800) 462-5378 (24 hours)

(800) I-M-ALERT

SECTION 9 REACTIVITY INFORMATION

(CONTINUED)

Avoid contact with strong oxidizers (eg. chlorine, peroxides, chromates, nitric acid, perchlorates, concentrated oxygen, permanganates) which can generate heat, fires, explosions and the release of toxic fumes.

STORAGE: Store at temperatures below 120 Degrees F and above 40 Degrees F. At temperatures below 40 Degrees F, this product loses its stability and form precipitates. Once formed, the precipitate cannot be resolubilized and loss of product activity will occur.

THERMAL DECOMPOSITION PRODUCTS: In the event of combustion CO, CO₂, NO_x may be formed. Do not breathe smoke or fumes. Wear suitable protective equipment.

SECTION 10 PERSONAL PROTECTION EQUIPMENT

RESPIRATORY PROTECTION: Respiratory protection is not normally needed since the volatility and toxicity are low. If significant vapors, mists or aerosols are generated, wear a NIOSH approved or equivalent respirator.

For large spills, entry into large tanks, vessels or enclosed small spaces with inadequate ventilation, a pressure-demand, self-contained breathing apparatus is recommended.

VENTILATION: General ventilation is recommended.

PROTECTIVE EQUIPMENT: Use impermeable gloves and chemical splash goggles when attaching feeding equipment, doing maintenance or handling product. Examples of impermeable gloves available on the market are neoprene, nitrile, PVC, natural rubber, viton and butyl (compatibility studies have not been performed).

The availability of an eye wash fountain and safety shower is recommended.

If clothing is contaminated, remove clothing and thoroughly wash the affected area. Launder contaminated clothing before reuse.

SECTION 11 SPILL AND DISPOSAL INFORMATION

IN CASE OF TRANSPORTATION ACCIDENTS, CALL THE FOLLOWING 24-HOUR TELEPHONE NUMBER (800) I-M-ALERT or (800) 462-5378.

SPILL CONTROL AND RECOVERY:

Small liquid spills: Contain with absorbent material, such as clay, soil or any commercially available absorbent. Shovel reclaimed liquid and absorbent into recovery or salvage drums for disposal. Refer to CERCLA in Section 14.



MATERIAL SAFETY DATA SHEET

PRODUCT

ELIMIN-OX OXYGEN SCAVENGER

Emergency Telephone Number

Medical (800) 462-5378 (24 hours)

(800) I-M-ALERT

SECTION 11 SPILL AND DISPOSAL INFORMATION

(CONTINUED)

Large liquid spills: Dike to prevent further movement and reclaim into recovery or salvage drums or tank truck for disposal. Refer to CERCLA in Section 14.

For large indoor spills, evacuate employees and ventilate area. Those responsible for control and recovery should wear the protective equipment specified in Section 10.

DISPOSAL: If this product becomes a waste, it does not meet the criteria of a hazardous waste as defined under the Resource Conservation and Recovery Act (RCRA) 40 CFR 261, since it does not have the characteristics of Subpart C, nor is it listed under Subpart D.

As a non-hazardous liquid waste, it should be solidified with stabilizing agents (such as sand, fly ash, or cement) so that no free liquid remains before disposal to an industrial waste landfill. A non-hazardous liquid waste can also be deep-well injected in accordance with local, state and federal regulations.

SECTION 12 ENVIRONMENTAL INFORMATION

AQUATIC DATA:

Results below are based on the product.

96 hour static acute LC₅₀ to Bluegill Sunfish = 190 ppm

96 hour static acute LC₅₀ to Rainbow Trout = 360 ppm

96 hour static acute LC₅₀ to Fathead Minnow = 400 mg/L

96 hour no observed effect concentration is 100 mg/L based on no mortality or abnormal effects.

48 hour static acute LC₅₀ to Daphnia magna = 96 mg/L

48 hour no observed effect concentration is 20 mg/L based on no mortality or abnormal effects.

If released into the environment, see CERCLA in Section 14.

SECTION 13 TRANSPORTATION INFORMATION

PROPER SHIPPING NAME/HAZARD CLASS MAY VARY BY PACKAGING, PROPERTIES,



MATERIAL SAFETY DATA SHEET

PRODUCT

ELIMIN-OX OXYGEN SCAVENGER

Emergency Telephone Number

Medical (800) 462-5378 (24 hours)

(800) I-M-ALERT

SECTION 13 TRANSPORTATION INFORMATION

(CONTINUED)

AND MODE OF TRANSPORTATION. TYPICAL PROPER SHIPPING NAMES FOR THIS PRODUCT ARE:

ALL TRANSPORTATION MODES : PRODUCT IS NOT REGULATED DURING TRANSPORTATION

SECTION 14 REGULATORY INFORMATION

The following regulations apply to this product.

FEDERAL REGULATIONS:

OSHA'S HAZARD COMMUNICATION RULE, 29 CFR 1910.1200:
Based on our hazard evaluation, this product is not hazardous.

CERCLA, 40 CFR 117, 302:
Notification of spills of this product is not required.

SARA/SUPERFUND AMENDMENTS AND REAUTHORIZATION ACT OF 1986
(TITLE III) - SECTIONS 302, 311, 312 AND 313:

SECTION 302 - EXTREMELY HAZARDOUS SUBSTANCES (40 CFR 355):
This product does not contain ingredients listed in Appendix A and B as an Extremely Hazardous Substance.

SECTIONS 311 and 312 - MATERIAL SAFETY DATA SHEET REQUIREMENTS (40 CFR 370):
Our hazard evaluation has found that this product is not hazardous under 29 CFR 1910.1200.

Under SARA 311 and 312, the EPA has established threshold quantities for the reporting of hazardous chemicals. The current thresholds are: 500 pounds or the threshold planning quantity (TPQ), whichever is lower, for extremely hazardous substances and 10,000 pounds for all other hazardous chemicals.

SECTION 313 - LIST OF TOXIC CHEMICALS (40 CFR 372):
This product does not contain ingredients on the List of Toxic Chemicals.

TOXIC SUBSTANCES CONTROL ACT (TSCA):
The chemical ingredients in this product are on the 8(b) Inventory List (40 CFR 710).

RESOURCE CONSERVATION AND RECOVERY ACT (RCRA), 40 CFR 261 SUBPART C & D:
Consult Section 11 for RCRA classification.



MATERIAL SAFETY DATA SHEET

PRODUCT

ELIMIN-OX OXYGEN SCAVENGER

Emergency Telephone Number

Medical (800) 462-5378 (24 hours)

(800) I-M-ALERT

SECTION 14 REGULATORY INFORMATION

(CONTINUED)

FEDERAL WATER POLLUTION CONTROL ACT, CLEAN WATER ACT, 40 CFR 401.15 (formerly Sec. 307), 40 CFR 116 (formerly Sec. 311):
None of the ingredients are specifically listed.

CLEAN AIR ACT, Sec. 111 (40 CFR 60), Sec. 112 (40 CFR 61, 1990 Amendments), Sec. 611 (40 CFR 82, CLASS I and II Ozone depleting substances):
This product does not contain ingredients covered by the Clean Air Act.

STATE REGULATIONS:

CALIFORNIA PROPOSITION 65:

Hydrazine is known to the State of California to cause cancer. This product contains levels of hydrazine as an impurity at less than 0.01%.

MICHIGAN CRITICAL MATERIALS:

This product does not contain ingredients listed on the Michigan Critical Materials Register.

STATE RIGHT TO KNOW LAWS:

The following ingredient(s) are disclosed for compliance with State Right To Know Laws:

Carbohydrazide	497-18-7
Water	7732-18-5

INTERNATIONAL REGULATIONS:

This is not a WHMIS controlled product under The House of Commons of Canada Bill C-70.

SECTION 15 ADDITIONAL INFORMATION

None

SECTION 16 USER'S RESPONSIBILITY

This product material safety data sheet provides health and safety information. The product is to be used in applications consistent with our product literature. Individuals handling this product should be informed of the recommended safety precautions and should have access to this information. For any other uses, exposures should be evaluated so that appropriate handling practices and training programs can be established to ensure safe workplace operations. Please consult your



MATERIAL SAFETY DATA SHEET

PRODUCT

ELIMIN-OX OXYGEN SCAVENGER

Emergency Telephone Number

Medical (800) 462-5378 (24 hours)

(800) I-M-ALERT

SECTION 16 USER'S RESPONSIBILITY

(CONTINUED)

local sales representative for any further information.

SECTION 17 BIBLIOGRAPHY

ANNUAL REPORT ON CARCINOGENS, U.S. Department of Health and Human Services, Public Health Service, PB 33-135855, 1983.

CASARETT AND DOULL'S TOXICOLOGY, THE BASIC SCIENCE OF POISONS, Doull, J., Klaassen, C. D., and Admur, M. O., eds., Macmillian Publishing Company, Inc., N. Y., 2nd edition, 1980.

CHEMICAL HAZARDS OF THE WORKPLACE, Proctor, N. H., and Hughes, J. P., eds., J. P. Lipincott Company, N.Y., 1981.

DANGEROUS PROPERTIES OF INDUSTRIAL MATERIALS, Sax, N. Irving, ed., Van Nostrand Reinhold Company, N.Y., 6th edition, 1984.

IARC MONOGRAPHS ON THE EVALUATION OF THE CARCINOGENIC RISK OF CHEMICALS TO MAN, Geneva: World Health Organization, International Agency for Research on Cancer, 1972-1977.

PATTY'S INDUSTRIAL HYGIENE AND TOXICOLOGY, Clayton, G. D., Clayton, F. E., eds., John Wiley and Sons, N. Y., 3rd edition, Vol. 2 A-C, 1981.

REGISTRY OF TOXIC EFFECTS ON CHEMICAL SUBSTANCES, U.S. Department of Health and Human Services, Public Health Service, Center for Disease Control, National Institute for Occupational Safety and Health, 1983 supplement of 1981-1982 edition, Vol. 1-3, OH, 1984.

Title 29 Code of Federal Regulations Part 1910, Subpart Z, Toxic and Hazardous Substances, Occupational Safety and Health Administration (OSHA).

THRESHOLD LIMIT VALUES FOR CHEMICAL SUBSTANCES AND PHYSICAL AGENTS IN THE WORKROOM ENVIRONMENT WITH INTENDED CHANGES, American Conference of Governmental Industrial Hygienists, OH.

Information on this MSDS has changed. The changes are indicated by asterisks on the right side of only the changed sections. This is an updated MSDS as required by OSHA's Hazard Communication Rule 29 CFR 1910.1200.

PREPARED BY: Ricky A. Stackhouse PhD., Toxicologist

DATE CHANGED: 05/05/95

DATE PRINTED: 06/10/95

MATERIAL SAFETY DATA SHEET



PRODUCT

Emergency Telephone Number

Medical (800) 462-5378 (24 hours)

(800) I-M-ALERT

Caustic
Material Safety Data Sheet

1. CHEMICAL PRODUCT AND COMPANY IDENTIFICATION

Old World Industries, Inc.
4065 Commercial Avenue
Northbrook, IL 60062-1851
Phone: (847) 559-2000

Effective Date: 12/2/96
Revision: Four
Last Revision Date: 3/1/96
Emergency Phone: (800) 424-9300
[CHEMTREC]

1-26-98
f;

PRODUCT: Liquid Caustic Soda, 50% Solution

Chemical Name: Sodium Hydroxide in Aqueous Solution
Synonyms: Sodium Hydroxide (50% solution); Sodium Hydrate; Lye; Alkali
Chemical Formula: NaOH/H₂O
Formula Wt.: 40

2. COMPOSITION/INFORMATION ON INGREDIENTS

<u>Ingredients</u>	<u>CAS No.</u>	<u>Wt %</u>
Sodium Hydroxide	1310-73-2	48.5 - 50.5 %
Sodium Chloride	7647-14-5	<1.0%
Sodium Chlorate	7775-09-9	<0.2%
Water	7732-18-5	BAL

Exposure Guidelines: ACGIH (TWA): 2 mg/m³ (ceiling)
ACGIH (STEL): None established
OSHA (TWA): 2 mg/m³ (ceiling)
OSHA (STEL): None established

3. HAZARDS IDENTIFICATION

EMERGENCY OVERVIEW

May be fatal if swallowed. Causes severe burns to areas of contact, especially eyes and skin.
Harmful if inhaled. Reacts violently with acids. Do not get in eyes, on skin, or clothing. Flush areas of contact with water for at least 15 minutes.

NFPA Ratings -		Key:
Health	3	0 - Minimal
Fire	0	1 - Slight
Reactivity	1	2 - Moderate
		3 - Serious
		4 - Severe

POTENTIAL HEALTH EFFECTS:

Target Organs: Eyes, respiratory system, skin, and lungs

Routes of Exposure: Eye contact, inhalation, skin contact

Eyes: Disintegration/ulceration of eye tissue may lead to opacification of cornea and permanent damage.

Skin: Redness, burns, and white scabs may form without immediate pain.

Ingestion:	Burns to mouth, throat and intestinal tract. May be fatal if swallowed.
Inhalation:	Severe irritation to respiratory system which may lead to pulmonary edema and lung inflammation.
Signs/Symptoms:	Redness/tearing of eyes; redness/burns to skin; nausea; vomiting; bloody diarrhea.
Chronic Effects:	Discomfort and ulceration of skin, respiratory system and lungs.

4. FIRST AID MEASURES

Ensure physician has access to this MSDS.

Eyes:	Immediately flush eyes with large amounts of water for 15 minutes, lifting lower and upper lids. Get medical attention as soon as possible. Contact lenses should never be worn when working with this chemical.
Skin:	Flush area of skin contact immediately with large amounts of water for at least 15 minutes while removing contaminated clothing. If irritation persists after flushing, get medical attention promptly. Wash clothing before re-use.
Inhalation:	If inhaled, immediately remove victim to fresh air and call emergency medical care . If not breathing, give artificial respiration. If breathing is difficult, give oxygen.
Ingestion:	If swallowed, immediately call physician . DO NOT induce vomiting as further damage may result. If conscious, give large amounts of water, followed by DILUTED vinegar, fruit juice, or egg whites beaten with water.

5. FIRE FIGHTING MEASURES

Flashpoint (PMCC):	Nonflammable	
Auto Ignition Temp:	Nonflammable	
LEL:	Nonflammable	
UEL:	Nonflammable	
Sensitive to Mechanical Impact:	No	Static: No

Extinguishing Media: Use media appropriate to surrounding fire.

Special Procedures: Firefighters should wear proper protective equipment and self-contained breathing apparatus with full facepiece operated in positive pressure mode. Flood area with water but do not splatter or splash this material.

Explosion Hazards: Reacts with most metals (especially aluminum, tin, or zinc) to produce hydrogen gas, which can form an explosive mixture with air.

Small Fire: Dry chemical, carbon dioxide, water spray or regular foam.

Large Fire: Water spray, fog or regular foam

6. ACCIDENTAL RELEASE MEASURES

Large Spill: Wear self-contained breathing apparatus and full protective clothing. Stop leak if you can do so without risk. Ventilate area. Carefully neutralize spill with a caustic neutralizer. Use caution to avoid splashing on skin if flushing area with water.

Small Spill: Use full protective clothing including high efficiency particulate respirator. Carefully neutralize area with caustic neutralizer.

7. HANDLING AND STORAGE

- Avoid breathing mist
- Avoid breathing vapors
- Hazardous carbon monoxide gas can form upon contact with food and beverage products in enclosed spaces and can cause death. Follow appropriate tank entry procedures (ANSI Z117.1).
- Containers, even those that have been emptied, will retain product residue and vapor and should be handled as if they were full.
- Do not get in eyes, on skin, or clothing.
- Do not take internally.
- Keep away from acids to avoid possible violent reaction.
- Wash contaminated clothing before reuse.
- Wash thoroughly after handling. Exposure can cause burns which are not immediately painful or visible.
- Wear personal protective equipment as described in Exposure Controls/Personal Protection (Section 8).
- If product is added too rapidly or without stirring, and becomes concentrated at bottom of mixing vessel, excessive heat may be generated, resulting in DANGEROUS boiling and spattering and a possible IMMEDIATE AND VIOLENT ERUPTION of a highly caustic solution.
- Keep container tightly closed and properly labeled. Dike storage containers to contain 110% of tank volume.
- Under normal conditions this product can be stored satisfactorily in mild steel without an interior lining. Aluminum is not recommended for storage and handling.
- Do not store below 12°C (53°F).

8. EXPOSURE CONTROLS/PERSONAL PROTECTION

Respiratory Protection: Required if airborne concentration exceeds TLV. At concentrations up to 60 ppm, a high efficiency particulate respirator is recommended. Above this level, a self-contained breathing apparatus is advised.

Skin Protection:	Chemical resistant gloves and apron.
Eye Protection:	Safety goggles and face shield.
Engineering Controls:	Use general or local exhaust ventilation to meet TLV requirements.
Other:	Emergency shower and eyewash facility must be in close proximity to all work areas.

9. PHYSICAL AND CHEMICAL PROPERTIES

Appearance:	Clear, colorless viscous liquid
Odor:	No discernible odor
Physical State:	Liquid
Boiling Point:	142°C (287°F) @ 760 mm Hg
Freezing Point:	12°C (53.6°F)
Vapor Pressure:	1.5 mm Hg @ 15.6°C (60°F)
Vapor Density:	Not applicable
Solubility (H ₂ O):	Complete (100%)
% Volatiles:	Not applicable (water solution)
Specific Gravity:	1.53 (H ₂ O = 1)
Evaporation Rate:	Not known

10. STABILITY AND REACTIVITY

Stability:	Heat, contact with incompatibles listed below. Flammable, poisonous gases may accumulate in tanks and hopper cars.
Incompatibility:	Rapid increase in temperature and pressure when mixed with strong acids, combustible materials, organic materials, or water. Hydrogen gas and possible explosion when in contact with zinc, aluminum, peroxides, or halogenated hydrocarbons.

Hazardous Decomposition Products: None identified

Hazardous Polymerization: Will not occur

11. TOXICOLOGICAL INFORMATION

Irritation data:	skin-rabbit	500 mg/24H SEVERE
	eye-rabbit	4 g MILD
	eye-rabbit	1% SEVERE
	eye-rabbit	50 mg/24H SEVERE
	eye-rabbit	1 mg/24H SEVERE
	eye-rabbit	100 mg rinse SEVERE

Mutagenic Data: Cryptogenic Analysis (grasshopper-parenteral): 20 mg

Toxicity Data: intraperitoneal-mouse LD50: 40 mg/kg
oral-rabbit LDLo: 500 mg/kg

Classification of carcinogenicity: None known

12. ECOLOGICAL INFORMATION

Ecotoxicity Values: LC100 Cyprinus Carpio 180 ppm/2⁴ HR @ 25°C [Nishiuchi Y; Suisan Zoshoku 23: 132 (1975)]

TLm mosquito fish 125 ppm/96 hr (fresh water) [U.S. Coast Guard, Department of Transportation. CHRIS - Hazardous Chemical Data. Volume II. Washington, D.C.: U.S. Government Printing Office, 1984-5.]

TLm Bluegill 99 mg/L/48 hr (tap water) [Environment Canada; Tech Info for Problem Spills: Sodium Hydroxide (Draft) p.61 (1981)]

Biodegradation: None known

Abiotic Degradation: No data available

There is limited information available on the environmental fate and effects of sodium hydroxide (NaOH). Laboratory toxicity data indicate that NaOH is moderately toxic to aquatic and terrestrial organisms. The primary mode of action is due the corrosive nature of this chemical and its tendency to increase pH in poorly buffered environments. Aquatic organisms become increasingly stressed as pH exceeds 9, with many aquatic species being intolerant of pH levels in excess of 10. Increased pH due to the introduction of NaOH into aquatic environments may lead to the precipitation of essential micronutrients. Exposed terrestrial species would be subject to skin irritation and burns due to the corrosive nature of this material. Due caution should be exercised to prevent the accidental release of this material to aquatic or terrestrial environments.

13. DISPOSAL INFORMATION

Classified as a corrosive/reactive waste (D002/D003). Dispose in accordance with applicable federal, state, and local regulations.

14. TRANSPORT INFORMATION

Proper Shipping Name: Sodium Hydroxide, Solution
ID No.: UN 1824
Hazard Class: 8
Packaging Group: II
Label: Corrosive

15. REGULATORY INFORMATION

United States -

TSCA - Inventory: Listed

Water Standards: Designated as a hazardous substance under section 311(b)(2)(A) of the Federal Water Pollution Control Act and further regulated by the Clean Water Act Amendments of 1977 and 1978. These regulations apply to discharges of sodium hydroxide. [40 CFR 116.4]

CERCLA: Persons in charge of vessels or facilities are required to notify the National Response Center (NRC) immediately, when there is a release of this designated hazardous substance, in an amount equal to or greater than its reportable quantity of 1,000 lb or 454 kg. The toll free telephone number of the NRC is (800) 424-8802.

SARA Title III: Section 311/312 - Categories: Acute; reactive

Section/312 - Inventory Reporting: Caustic soda is subject to Tier I and/or Tier II annual inventory reporting.

Section 313 - Emission Reporting: Caustic soda is not subject to Form R reporting requirements.

Section 302 - Extremely Hazardous Substances: Caustic soda is not listed.

Other Regulations -

California

Proposition 65 List: not listed

Prop. Dir. List of Haz. Subs.: listed

Florida

Hazardous Substances List: listed

Massachusetts

Right-to-Know List: listed

Minnesota

Haz. Subs. List: listed

New Jersey

Right-to-Know List (Total): sn 1706

Pennsylvania

Right-to-Know List: environmental hazard

Michigan

Critical Materials List: not listed

Canada

WHMIS: D1B; E

Risk Phrases: R: 35
S: 2-26-37/39

16. **OTHER INFORMATION**

Contact: Mr. Michael Reed, Technology Manager Phone: (847) 559-2000

This Material Safety Data Sheet is applicable for all grades of liquid caustic soda (diaphragm, membrane, and mercury cell (rayon)) sold by Old World Industries, Inc.

Old World Industries, Inc. makes no warranty, representation or guarantee as to the accuracy, sufficiency or completeness of the material set forth herein. It is the user's responsibility to determine the safety, toxicity and suitability of his own use, handling and disposal of this product. Since actual use by others is beyond our control, no warranty, expressed or implied, is made by Old World Industries, Inc. as to the effects of such use, the results to be obtained or the safety and toxicity of this product, nor does Old World Industries, Inc. assume liability arising out of the use by others of this product referred to herein. The data in this MSDS relates only to the specific material designated herein and does not relate to use in combination with any other materials or in any process.

Sulfuric Acid
Material Safety Data Sheet

MATERIAL SAFETY DATA SHEET

IDENTIFICATION

Name

Sulfuric Acid, various strengths, 77-100%

Synonyms

Sulphuric Acid

CAS Name

Sulfuric Acid

I.D. Nos./Codes NIOSH Registry No. WS 56000

Wiswesser Code WSQQ

Manufacturer/Distributor

E. I. Du Pont De Nemours & Co., (Inc.)

Address

Wilmington, DE 19898

Chemical Family

Mineral Acid

CAS Registry No.

7664-93-9

Formula:

H₂SO₄

Product Information and Emergency Phone

(302) 774-2421

Transportation Emergency Phone

(800) 424-9300

HAZARDOUS COMPONENTS

Material(s)

60° Tech.
66°, 1.835 Electrolyte
Reagent
98, 99 & 100%

Approximate %

77.7%
93.2%
96.0%
98, 99 & 100% respectively

PHYSICAL DATA

Boiling Point, 760 mm Hg

193-327° (379-621°F)

Specific Gravity

1.706 - 1.839 @ 60°F

Vapor Density

~ 3.4

% Volatiles by Vol.

0% @ 70°F

Form

Liquid

Appearance

Clear to turbid, oily liquid

Melting Point

-35° to + 10.6°C (-31° to + 51°F)

Vapor Pressure

< 0.3 @ 25°C; < 0.6 @ 37.7°C

Solubility in H₂O

Complete

Evaporation Rate (Butyl Acetate = 1) < 1

Color

Colorless to light brown

Odor

None

pH Information

< 1

Octanol/Water Partition Coefficient

FIRE AND EXPLOSION DATA

Flash Point

Non-flammable

Method

Autoignition Temperature

Flammable Limits in Air, % by Vol.

Will not burn.

Lower

Upper

Fire and Explosion Hazards Reacts with most metals, especially when diluted, to yield flammable hydrogen gas.

Extinguishing Media Water, dry chemical or carbon dioxide (for fires in area). Do not get water in tank.

Special Fire Fighting Instructions Generates heat upon addition of water, with possible splattering. Wear full protective clothing (see Protection Information on back of page). Use care not to ignite hydrogen gas which may accumulate from reaction with metal.

HAZARDOUS REACTIVITY

Instability

Stable. Will react with many materials.

Incompatibility Combustible materials; oxidizing materials, organic peroxides, strong reducing agents, powdered metals, cyanides, carbides, chlorates, nitrates, fulminates, picrates, sulfides.

Decomposition: Releases sulfur dioxide at extreme high temperature. Reaction with above may release toxic gases, such as hydrogen cyanide or hydrogen sulfide.

Polymerization: None

HEALTH HAZARD INFORMATION

Exposure Limits Air Concentrations: Time Weighted Average (OSHA) = 1 mg/m^3

Routes of Exposure and Effects: Causes severe burns of skin, eyes and all body tissue. Ingestion causes severe burns of mouth, esophagus and stomach. Inhalation of vapors or mists may cause respiratory irritation. Long term over-exposure to vapors or mists may result in damage to teeth.

First Aid: In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes while removing contaminated clothing and shoes. Call a physician. Wash clothing before reuse. If swallowed, give large quantities of water until physician is contacted. Never give anything by mouth to an unconscious person. If inhaled, remove to fresh air. Have patient lie down and keep quiet. If not breathing, give artificial respiration, preferably mouth-to-mouth. If breathing is difficult, give oxygen. Call a physician.

PROTECTION INFORMATION

Ventilation

Keep in well ventilated room. Use only with adequate ventilation.

Personal Protective Equipment Coverall chemical splash goggles, rubber or plastic gloves, rubber protective footwear, full rubber chemical suit.

Other

Respiratory protection not required for normal use.

DISPOSAL PROCEDURES

Spill, Leak or Release: If possible, stop flow. Dike large spills. Neutralize spills with lime or soda ash and flush to waste water treatment system. Wear protective clothing if necessary to enter spill area.

Waste Disposal Comply with Federal, State and local regulations. If approved, neutralize and drain to sewer to waste water treatment system.

SHIPPING PRECAUTIONS

Transportation DOT Shipping Name - Sulfuric Acid. DOT Hazard Class - Corrosive Material. STCC Code = 4930040. UN No. 1831. IMCO Class 8.

Shipping Containers Tank cars, tank trucks, 55 gal stainless steel drums.

Storage Conditions: Keep out of sun and away from heat. Keep fire, sparks and flame away from opening. Keep container tightly closed and closure (drums) up to prevent leakage. Loosen closure carefully. Do not use pressure to empty. Relieve internal pressure when received and at least weekly thereafter. Before moving container be sure closure is securely fastened.

REFERENCES AND ADDITIONAL INFORMATION

Do not wash out container or use for other purposes; replace closure and return with empty container.

Do not get in eyes, on skin or clothing.

Avoid breathing vapor or mists.

Do not add water to contents while in container because of violent reaction.

Wash thoroughly after handling.

REFERENCES: Du Pont Sulfuric Acid Data Sheet.

Du Pont Sulfuric Acid Storage & Handling Bulletin.

Du Pont Sulfuric Acid Commodity Distribution Data.



Aluminum Sulfate, 48% Solution
Material Safety Data Sheet

Jim Longford

P1020

MATERIAL SAFETY DATA SHEET

PG 1

ALUMINUM SULFATE GRAN

EFFECTIVE DATE: 04-25-90

RECEIVED
NOV 20 1991
TMPA DOCUMENT CONTROL
G.C.S.E.S. # 1

MAIL TO:

46420081
TEXAS MUNICIPAL POWER AG-
ENCY ACCOUNTS PAYABLE
P O BOX 7000
BRYAN TX 77805

NOV 8 1991

NOV 21 1991
NO. 211391
ORDER NO: 462730353
PROD NO: 04045237

VAN WATERS & ROGERS INC., SUBSIDIARY OF UNIVAR
1600 NORTON BLDG. SEATTLE, WA 98104-1564 (408) 435-8700

EMERGENCY ASSISTANCE

FOR EMERGENCY ASSISTANCE INVOLVING CHEMICALS CALL CHEMTREC (800)424-9300
FOR PRODUCT AND SALES INFORMATION

CONTACT YOUR LOCAL VAN WATERS & ROGERS BRANCH OFFICE

PRODUCT IDENTIFICATION

PRODUCT NAME: ~~ALUMINUM SULFATE SOLID~~
COMMON NAMES/SYNONYMS: ALUM (DRY);
ALUMINUM SULFATE; ALUMINUM TRISULFATE;
ALUMINUM TRISULFATE
CAS NO.: 10043-01-3
VW&R CODE: P1020

FORMULA: O12 S3 AL2 . 14 H2 O
HAZARD RATING (NFPA 704)
HEALTH: 2
FIRE: 0
REACTIVITY: 0
SPECIAL: NONE

DATE ISSUED: 04/90
SUPERCEDES: 08/89
HAZARD RATING SCALE:
0=MINIMAL 3=SERIOUS
1=SLIGHT 4=SEVERE
2=MODERATE

HAZARDOUS INGREDIENTS

COMPONENT	EXPOSURE LIMITS, MG/M3				HAZARD IRRITANT
	%	OSHA PEL	ACGIH TLV	OTHER LIMIT	
ALUMINUM SULFATE	>99	NONE	2(AL)	NONE	

PHYSICAL PROPERTIES

BOILING POINT, DEG F: NOT APPLICABLE VAPOR PRESSURE, MM HG/20 DEG C: NEGLIGIBLE
MELTING POINT, DEG F: 1,400 DEC. VAPOR DENSITY (AIR=1): N/A
SPECIFIC GRAVITY (WATER=1): 1.61 WATER SOLUBILITY, %: 50
APPEARANCE AND ODDR: WHITE EVAPORATION RATE (BUTYL ACETATE=1): N/A
OR CREAMY WHITE GRANULES OR POWDER; ODDRLESS

FIRST AID MEASURES

IF INHALED: REMOVE TO FRESH AIR. GIVE ARTIFICIAL RESPIRATION IF NOT BREATHING. GET IMMEDIATE MEDICAL ATTENTION.
IN CASE OF EYE CONTACT: IMMEDIATELY FLUSH EYES WITH LOTS OF RUNNING WATER FOR 15 MINUTES, LIFTING THE UPPER AND LOWER EYELIDS OCCASIONALLY. GET IMMEDIATE MEDICAL ATTENTION.
IN CASE OF SKIN CONTACT: IMMEDIATELY WASH SKIN WITH LOTS OF SOAP AND WATER. REMOVE CONTAMINATED CLOTHING AND SHOES; WASH BEFORE REUSE. GET

PROD: 04045237 05:49:25 10 NOV 1991 CUST: 46420081 INVOICE: 462730353

LUMINUM SULFATE GRAN

EFFECTIVE DATE: 04-25-90

MEDICAL ATTENTION IF IRRITATION PERSISTS AFTER WASHING.

IF SWALLOWED: IF CONSCIOUS, IMMEDIATELY INDUCE VOMITING BY GIVING 2 GLASSES OF WATER AND STICKING A FINGER DOWN THE THROAT. GET IMMEDIATE MEDICAL ATTENTION. DO NOT GIVE ANYTHING BY MOUTH TO AN UNCONSCIOUS OR CONVULSING PERSON.

-----HEALTH HAZARD INFORMATION-----

PRIMARY ROUTES OF EXPOSURE: SKIN OR EYE CONTACT

SIGNS AND SYMPTOMS OF EXPOSURE

INHALATION: BREATHING DUST MAY IRRITATE RESPIRATORY TRACT.

EYE CONTACT: DUSTS MAY STRONGLY IRRITATE OR BURN THE EYES.

SKIN CONTACT: PROLONGED OR REPEATED CONTACT WITH THE DUST MAY IRRITATE THE SKIN, ESPECIALLY IF MOISTURE IS PRESENT.

SWALLOWED: SWALLOWING THE SOLIDS MAY CAUSE IRRITATION OF THE GASTRO-INTESTINAL TRACT, NAUSEA AND VOMITING. SWALLOWING LARGE AMOUNTS MAY CAUSE BURNS TO THE DIGESTIVE TRACT. HUMAN FATAL DOSE RECORDED AT 30 GRAMS.

CHRONIC EFFECTS OF EXPOSURE: NO SPECIFIC INFORMATION AVAILABLE.

MEDICAL CONDITIONS GENERALLY AGGRAVATED BY EXPOSURE: NONE REPORTED.

-----TOXICITY DATA-----

ORAL: MOUSE LD50 = 10.8 G/KG; REPORTED HUMAN FATAL DOSE OF 30 GRAMS.

DERMAL: NO DATA FOUND.

INHALATION: NO DATA FOUND.

CARCINOGENICITY: THIS MATERIAL IS NOT CONSIDERED TO BE A CARCINOGEN BY THE NATIONAL TOXICOLOGY PROGRAM, THE INTERNATIONAL AGENCY FOR RESEARCH ON CANCER, OR THE OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION

OTHER DATA: NONE.

-----PERSONAL PROTECTION-----

VENTILATION: LOCAL MECHANICAL EXHAUST VENTILATION CAPABLE OF MAINTAINING DUST EMISSIONS AT THE POINT OF USE BELOW THE TLV.

RESPIRATORY PROTECTION: IF USE CONDITIONS GENERATE DUSTS, WEAR A NIOSH-APPROVED RESPIRATOR APPROPRIATE FOR THOSE EMISSION LEVELS. APPROPRIATE RESPIRATORS MAY BE A FULL FACEPIECE OR A HALF MASK AIR-PURIFYING CART-RIDGE RESPIRATOR WITH PARTICULATE FILTERS, A SELF-CONTAINED BREATHING APPARATUS IN THE PRESSURE DEMAND MODE, OR A SUPPLIED-AIR RESPIRATOR.

EYE PROTECTION: CHEMICAL GOGGLES UNLESS A FULL FACEPIECE RESPIRATOR IS ALSO WORN. IT IS GENERALLY RECOGNIZED THAT CONTACT LENSES SHOULD NOT BE WORN WHEN WORKING WITH CHEMICALS BECAUSE CONTACT LENSES MAY CONTRIBUTE TO THE SEVERITY OF AN EYE INJURY.

PROTECTIVE CLOTHING: LONG-SLEEVED SHIRT, TROUSERS, SAFETY SHOES, RUBBER GLOVES, AND RUBBER APRON.

OTHER PROTECTIVE MEASURES: AN EYEWASH AND SAFETY SHOWER SHOULD BE NEARBY AND READY FOR USE.

-----FIRE AND EXPLOSION INFORMATION-----

FLASH POINT, DEG F: NOT FLAMMABLE

FLAMMABLE LIMITS IN AIR, %

METHOD USED: N/A

LOWER: N/A UPPER: N/A

EXTINGUISHING MEDIA: THIS MATERIAL IS NOT COMBUSTIBLE. USE EXTINGUISHING MEDIA APPROPRIATE FOR SURROUNDING FIRE.

SPECIAL FIRE FIGHTING PROCEDURES: FIRE FIGHTERS SHOULD WEAR SELF-

PROD: 04045237 05:49:25 10 NOV 1991 CUST: 464200B1 INVOICE: 462730353

ALUMINUM SULFATE GRAN

EFFECTIVE DATE: 04-25-90

CONTAINED BREATHING APPARATUS AND FULL PROTECTIVE CLOTHING. USE WATER SPRAY TO COOL NEARBY CONTAINERS AND STRUCTURES EXPOSED TO FIRE.

UNUSUAL FIRE AND EXPLOSION HAZARDS: TEMPERATURES ABOVE 1400 DEG F YIELD TOXIC AND CORROSIVE GASES.

-----HAZARDOUS REACTIVITY-----

STABILITY: STABLE POLYMERIZATION: WILL NOT OCCUR
CONDITIONS TO AVOID: TEMPERATURES ABOVE 1,400 DEG F.

MATERIALS TO AVOID: ALKALIES AND WATER REACTIVE MATERIALS SUCH AS OLEUM. ALUM CORRODES IRON AND ALUMINUM.

HAZARDOUS DECOMPOSITION PRODUCTS: MAY LIBERATE SULFUR OXIDE GASES WHICH ARE TOXIC AND ARE OXIDIZERS AND CORROSIVE. THE TRIOXIDE IS ALSO A FIRE HAZARD. THE LOSS OF THESE GASES LEAVES A CAUSTIC RESIDUE.

-----SPILL, LEAK, AND DISPOSAL PROCEDURES-----

ACTION TO TAKE FOR SPILLS OR LEAKS: WEAR PROTECTIVE EQUIPMENT INCLUDING RUBBER BOOTS, RUBBER GLOVES, RUBBER APRON, AND A FULL FACEPIECE OR A HALF MASK AIR-PURIFYING CARTRIDGE RESPIRATOR WITH PARTICULATE FILTERS. WEAR CHEMICAL GOGGLES IF A HALF MASK IS WORN. FOR SMALL SPILLS, SWEEP UP AND DISPOSE OF IN DOT-APPROVED WASTE CONTAINERS. FOR LARGE SPILLS, SHOVEL INTO DOT-APPROVED WASTE CONTAINERS. KEEP OUT OF SEWERS, STORM DRAINS, SURFACE WATERS, AND SOIL.
COMPLY WITH ALL APPLICABLE GOVERNMENTAL REGULATIONS ON SPILL REPORTING, AND HANDLING AND DISPOSAL OF WASTE.

DISPOSAL METHODS: DISPOSE OF CONTAMINATED PRODUCT AND MATERIALS USED IN CLEANING UP SPILLS OR LEAKS IN A MANNER APPROVED FOR THIS MATERIAL. CONSULT APPROPRIATE FEDERAL, STATE AND LOCAL REGULATORY AGENCIES TO ASCERTAIN PROPER DISPOSAL PROCEDURES.

NOTE: EMPTY CONTAINERS CAN HAVE RESIDUES, GASES AND MISTS AND ARE SUBJECT TO PROPER WASTE DISPOSAL, AS ABOVE.

-----SPECIAL PRECAUTIONS-----

STORAGE AND HANDLING PRECAUTIONS: STORE IN A COOL, DRY, WELL-VENTILATED PLACE AWAY FROM INCOMPATIBLE MATERIALS. KEEP BAGS OR FIBER DRUMS DRY AT ALL TIMES. WASH THOROUGHLY AFTER HANDLING. DO NOT GET IN EYES, ON SKIN, OR ON CLOTHING.

REPAIR AND MAINTENANCE PRECAUTIONS: NONE.

OTHER PRECAUTIONS: CONTAINERS, EVEN THOSE THAT HAVE BEEN EMPTIED, WILL RETAIN PRODUCT RESIDUE AND VAPORS. ALWAYS OBEY HAZARD WARNINGS AND HANDLE EMPTY CONTAINERS AS IF THEY WERE FULL.

-----FOR ADDITIONAL INFORMATION-----

CONTACT MSDS COORDINATOR, VAN WATERS & ROGERS INC.
DURING BUSINESS HOURS, PACIFIC TIME (408)435-8700

-----OTHER REGULATORY INFORMATION-----

THE COMPONENTS OF THIS PRODUCT ARE ON THE TSCA INVENTORY OF CHEMICAL SUBSTANCES.

THIS PRODUCT CONTAINS THE FOLLOWING CHEMICAL(S) CONSIDERED BY THE STATE OF CALIFORNIA'S SAFE DRINKING WATER AND TOXIC ENFORCEMENT ACT OF 1986 (PROPOSITION 65) AS CAUSING CANCER OR REPRODUCTIVE TOXICITY AND FOR WHICH WARNINGS ARE NOW REQUIRED:

CHEMICAL	CAS NO.	%, WT.
ARSENIC	7440-38-2	TRACE

UNDER MASSACHUSETTES RIGHT-TO-KNOW LAW, HAZARDOUS SUBSTANCE AND EXTRA-ORDINARILY HAZARDOUS SUBSTANCES COMPONENTS PRESENT IN THIS PRODUCT

PROD: 04045237 05:49:25 10 NOV 1991 CUST: 46420081 INVOICE: 462730353

ALUMINUM SULFATE GRAN

EFFECTIVE DATE: 04-25-90

WHICH REQUIRES REPORTING ARE:

EXTRAORDINARILY HAZARDOUS SUBSTANCES
CHEMICAL

CAS NO.

CONCENTRATION (=> 0.0001%)

ARSENIC

7440-38-2

TRACE

UNDER THE PENNSYLVANIA RIGHT-TO-KNOW LAW, HAZARDOUS SUBSTANCES AND
SPECIAL HAZARDOUS SUBSTANCES COMPONENTS PRESENT IN THIS PRODUCT
WHICH REQUIRE REPORTING ARE:SPECIAL HAZARDOUS SUBSTANCES
CHEMICAL

CAS NO.

CONCENTRATION (=> 0.01%)

ARSENIC

7440-38-2

TRACE

HAZARDOUS SUBSTANCES
CHEMICAL

CAS NO.

CONCENTRATION (=> 1%)

ALUMINUM SULFATE

10043-01-3

>99

-----NOTICE-----

**VAN WATERS & ROGERS INC. ("VW&R") EXPRESSLY DISCLAIMS ALL EXPRESS OR IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, WITH RESPECT TO THE PRODUCT OR INFORMATION PROVIDED HEREIN. **

ALL INFORMATION APPEARING HEREIN IS BASED UPON DATA OBTAINED FROM THE MANUFACTURER AND/OR RECOGNIZED TECHNICAL SOURCES. WHILE THE INFORMATION IS BELIEVED TO BE ACCURATE, VW&R MAKES NO REPRESENTATIONS AS TO ITS ACCURACY OR SUFFICIENCY. CONDITIONS OF USE ARE BEYOND VW&R'S CONTROL AND THEREFORE USERS ARE RESPONSIBLE TO VERIFY THIS DATA UNDER THEIR OWN OPERATING CONDITIONS TO DETERMINE WHETHER THE PRODUCT IS SUITABLE FOR THEIR PARTICULAR PURPOSES AND THEY ASSUME ALL RISKS OF THEIR USE, HANDLING, AND DISPOSAL OF THE PRODUCT, OR FROM THE PUBLICATION OR USE OF, OR RELIANCE UPON, INFORMATION CONTAINED HEREIN. THIS INFORMATION RELATES ONLY TO THE PRODUCT DESIGNATED HEREIN, AND DOES NOT RELATE TO ITS USE IN COMBINATION WITH ANY OTHER MATERIAL OR IN ANY OTHER PROCESS.

-----REVISION-----

06/86: CORRECTED SWALLOWING FIRST AID ADVICE. REVISED VENTILATION, RESPIRATORY, AND EYE PROTECTION RECOMMENDATIONS. EXPANDED FIRE AND EXPLOSION INFORMATION AND PROTECTIVE RECOMMENDATIONS. REVISED SPILL/LEAK PROCEDURES AND HANDLING ADVICE.

12/88: ADDED OTHER REGULATORY INFORMATION.

08/89: CHANGED HEADING AND CONTACT INFORMATION.

04/90: ADDED FATAL DOSAGE LEVEL FOR HEALTH HAZARD SWALLOWED
MASS & PENN RIGHT-TO-KNOW, TSCA.
REVISED BOILING POINT, VAPOR PRESSURE, & PROP 65
**** E N D O F M S D S ****

PROD: 04045237 05:49:25 10 NOV 1991 CUST: 46420081 INVOICE: 462730353


**Morris Instruction Manual 022C, Morris Pumps, Inc.,
December 20, 1982.**

Environmental Resources Management
206 East 9th Street, Suite 1700
Austin, Texas 78701
(512) 459-4700

INDEX


- TAB 1 TMPA TAG NO. 1-P-014A-WSD & 1-P-014B-WSD
 M-22544-2545
 4 VJC-14
- a) DRAWINGS
 INSTALLATION
 ASSEMBLY
- b) BILL OF MATERIAL
- c) PUMP PERFORMANCE CURVE
- TAB 2 TMPA TAG NO. 1-P-023A-WSD & 1-P-023B-WSD
 M-22546-2547
 10 VJC-22
- a) DRAWINGS
 INSTALLATION
 ASSEMBLY
- b) BILL OF MATERIAL
- c) PUMP PERFORMANCE CURVE
- TAB 3 MORRIS PUMPS, INC. INSTALLATION, OPERATING & MAINTENANCE
 INSTRUCTION BOOK NO. 2011
- V-BELT DRIVE INSTALLATION, OPERATING & MAINTENANCE BOOK
- TAB 4 TEST REPORT
 M-22544-2545
 4 VJC-14
- TAB 5 TEST REPORT
 M-22546-2547
 10 VJC-22
- TAB 6 RELIANCE MOTOR DRAWING & DATA
- a) M-22544-2545
 4 VJC-14
- b) M-22546-2547
 10 VJC-22
- c) RELIANCE INSTALLATION, OPERATION & MAINTENANCE
 MANUAL B-3620-11





DISCHARGE FLANGE:
ASA STD. 4" 125 LB. HOLES
STANDARD

M-22545




TEXAS MUNICIPAL POWER AGENCY
I-P-014A I-P-014B-WSD (A)
SCRUBBER AREA DRAINAGE PUMPS
TIPPETT & GEE GC-1166
(B) DESIGN: 800GPM AT 110 FT. HEAD

JAN 18 1980

THIS UNIT MUST NEVER BE USED WITHOUT PRIOR INSTALLATION OF THE SAFETY GUARDS FOR ROTATING PARTS AS PRESCRIBED BY O.S.H.A.

JAN 17 1980
0651 07 14M

REV.	CHANGE	BY	DATE	CHK.	SCALE	TITLE	MORRIS MACHINE WORKS - BALDWINVILLE, N. Y.
C	REMOVE MIN SUBMERGENCE	DL	1-17-80	117/6.6	NONE	VJC-14	PART NAME
B	1" JT. POSITION CHG, ADD DESIGN	DL	5-23-80				INSTALLATION DWG
A	7'-4 1/2" WAS 7'-7 3/4", ADD 1/2" TAP	DL	2-1-80	2/5			
A	ADD VIEW FOR MOT. POSITION						
A	WSD WAS 3'-2", 2'-10 3/4" WAS 3'-2"						
APPROVED					DATE	ORDER NO.	BWG NO.
APPROVED					9-28-77	M-22544-46	B-5614750-M2
APPROVED					DATE	PATT. NO.	BWG NO.
APPROVED							



NOTE "A"
ASSEMBLY MEASURE LENGTH "L"
AND INSTALL NECESSARY SHIMS TO
MAKE .002 - .004 GAP. AT G.

NOTE "M"
AT ASSEMBLY SHIM HERE IS REQ'D TO
LOCATE IMPELLER IN CASING.

(A)
SEAL WITH SILASTIC
732 RTV

*ALTERNATE DISCHARGE PIPING ASSEMBLY.

TEXAS MUNICIPAL POWER AGENCY
I-P-014A & I-P-014B-SSU
SCRUBBER AREA DRAINAGE PUMPS
TIPPETT & GEE GC-1166

THIS UNIT MUST NEVER BE USED
WITHOUT PRIOR INSTALLATION OF
THE SAFETY GUARDS FOR ROTATING
PARTS AS PRESCRIBED BY O.S.H.A.

MRC 232 RDUBB BRG. *OVM *1 VM & *2 VM BRG'S.

REDRAWN J.M. 9-22-78
CK 788

REDRAWN J.M. 8-9-79

MAY 28 1980

Microfilm	C PUMPS WAS SUMPS	DATE	SCALE	TYPE	MORRIS MACHINE WORKS - BALDWINVILLE, N. Y.
	B SHAFT WT. VIEW ADDED	02/15/80	NONE	VJC	PART NAME
	A DELETE 8102 & ADD SEAL	02/15/80	JMB FK		ASSEMBLY
	A WITH SILASTIC 732 RTV	02/15/80			DATE
					9-10-75
					INDEX NO.
					M-22544-45
					DWG. NO.
					B-5608849

2/06/81

Rev. 11-9-81

MORRIS PUMPS, INC.

SHEET 1

ROTATION
AND
POSITION

VERT. RH, 4'-6" LL, FR.#326T

INST. DWG. 5614750M2 REV B MORRIS SERIAL # M22544-2545

ASSM. DWG. 5608849 Rev.C PUMP 4 VJC 14

DISCHARGE: VERT. UP

B/M MASTER # 144/04/3
915/00/2 ST.

CUSTOMER: TEXAS MUN. POWER AGENCY

BEARING "D" VM

WRITTEN: PLM 09/26/79

CUST P.O. # 1316

OPER. INST. # 2011

APPROVED:

CUST. NO. 8852

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION-1
----------	-------------	----------	------------	-------------	---------------	---------	-----------

SCRUBBER AREA DRAINAGE PUMPS

100	CASING	CAST IRON	1	5579200002	5191000CA	ASTM A48 CLASS 35	
200	IMPELLER 6V 14.000 DIA. DYNAMIC BALANCE TO WITHIN 1.9 OZ. INCHES	28% CHROME IRON	1	4963001022	4892200AA	ASTM A592, CLASS 3, TYPE A	
300	SUCTION DISC	CAST IRON	1	4893300002	4893300AA	ASTM A48 CLASS 35	
311	SUCTION DISC LINER	CAST IRON	1	4894400002	4894400AA	ASTM A48 CLASS 35	
400	HUB DISC	CAST IRON	1	5194200002	5194200AA	ASTM A48 CLASS 35	
504	HUB THROTTLE	CAST IRON	1	5194300002	5194300AA	ASTM A48 CLASS 35	
600	SHAFT	STEEL	1	5606894103		AISI #1045	
618	SHEAVE KEY	STEEL	1	5582704104	HDW.	3/8" SQ. X 2-5/8" LG.	
619	SHAFT SLEEVE 006500	STAIN. STEEL	1	4896900141	B100044141	AISI #416	
1116	SUC. PIPE SUB-ASSY.	STEEL	1	5607181888		2'-10-3/4" O.A. LG.	
1116A	FLANGE	STEEL	1	5583104104			
1116B	REDUCER	STEEL	1	5583305104			
1116C	PIPE 27.500	STEEL	1	5582804104		6" SCH. #40 X 27-1/2" LG.	
1600	PIPE COLUMN	STRUC. STEEL	1	5606896104			
2100	MOTOR SUPPORT	STEEL	1	5614751104			

MORRIS SERIAL # M22544-2545
PUMP 4 VJC 14

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION-1
2119	BELT ADJ. SCREW S/A	STEEL	2	5601217807	001/22/8HDW.		
2119A	HEX NUT	STEEL	2		HDW.	5/8"-11 NC2, STD.	
2119B	COTTER PIN	STEEL	2		HDW.	1/8 X 2" LG.	
2119C	WASHER	STEEL	4		HDW.	5/8" STD. FLAT	
2119D	THREADED ROD	STEEL	2		HDW.	5/8"-11 NC2 X 9" LG.	
2119E	HEX NUT	STEEL	2		HDW.	5/8"-11 NC2 STD.	
2606	BELT ADJ. SCR. BRACKET (2100, 2119)	STEEL	2	5604871104			
2700	SEAL RING (100-300)	BUNA "N"	1	4974803342	HDW.		
2800	FLOOR PLATE	PLATE STEEL	1	5613677104		1" THICK PLATE	
4900	BELT GUARD (2100)	STEEL	1	5614752104			
7100	PRIMER MINIMUM DRY THICKNESS WILL BE 4 MILS, PER TIPPETT & GEE SPEC. GC-1166		1			MOBIL ZINC 7, 1 GAL. CAN	
7600	HEX HD BOLT & HEXNUT STAIN. (100-9001)	STEEL	8		HDW.	5/8"-11 NC2 X 3" LG. 18-8	
7602	HEX HD BOLT & HEXNUT STAIN. (700-2800)	STEEL	4		HDW.	7/8"-9 NC2 X 3-1/4" LG. 18-8	
7604	HEX HD BOLT & HEXNUT STAIN. (300-1116)	STEEL	8		HDW.	3/4"-10 NC2 X 3" LG. 18-8	
7605	HEX HD BOLT & HEXNUT (700-2100)	STEEL	2		HDW.	5/8"-11 NC2 X 2-1/2" LG.	
7606	HEX HD BOLT & HEXNUT (700-2606-2100)	STEEL	2		HDW.	5/8"-11 NC2 X 2-3/4" LG.	

MORRIS SERIAL # M22544-2545
PUMP 4 VJC 14

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION-1
7701	HEX HD. CAP SCREW (100-300)	STAIN. STEEL	8		HDW.	5/8"-11 NC2 X 1-3/4" LG. 18-8	
7702	HEX HD. CAP SCREW (100-400 & 1600)	STAIN. STEEL	8		HDW.	5/8"-11 NC2 X 2-1/4" LG. 18-8	
7703	HEX HD. CAP SCREW (504-400)	STAIN. STEEL	2		HDW.	1/2"-13 NC2 X 1" LG. 18-8	
7705	HEX HD. CAP SCREW (700-1600)	STAIN. STEEL	6		HDW.	7/8"-9 NC2 X 2-1/4 LG. 18-8	
7706	HEX HD. CAP SCREW (2100-4900)	STEEL	3		HDW.	3/8"-16 NC2 X 1/2" LG.	
7707	HEX HD. CAP SCREW (2100-9900)	STEEL	4		HDW.	5/8"-11 NC2 X 1-1/2" LG.	
8101	GASKET (100-9001)	RUBBER CLOTH	1		HDW.	6-7/8" OD X 4" ID X 1/16" THK.	
8103	GASKET (100-400)	RUBBER CLOTH	1	4975102305	HDW.	11" OD X 9-17/32" ID X 1/16" THK.	
8104	GASKET (300-1116)	RUBBER CLOTH	1		HDW.	11" OD X 6" ID X 1/16" THK.	
8200	WASHER (7702)	STAIN. STEEL	8		HDW.	5/8" STD. 18-8	
8201	WASHER (7701)	STAIN. STEEL	8		HDW.	5/8" STD. 18-8	
8202	WASHER (7600)	STAIN. STEEL	8		HDW.	5/8" STD. 18-8	

MORRIS SERIAL # M22544-2545
PUMP 4 VJC 14

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION-1
8204	WASHER (7604)	STAIN. STEEL	8			HDW. 3/4" STD. 18-8	
8205	WASHER (7605)	STEEL	2			HDW. 5/8" STD.	
8700	HEX NUT (2606) TACK WELD TO ITEM 2606	STEEL	2			HDW. 5/8"-11 NC2 STD.	
8800	HEX JAM NUT (2119)	STEEL	2			HDW. 5/8"-11 NC2 STD.	
9000	DISCHARGE PIPE (9002-9003)	STEEL	1	5615210104		HDW. 4", STD. WGT. PIPE X 4" - 2-1/4" LG.	
9001	FLANGE-WELDING NECK (100-9002)	STEEL	1	5583003104		HDW. 4", 150#, PART #30 TUBE TURN	
9002	ELBOW - SHORT RADIUS (9000-9001)	STEEL	1	5582927104		HDW. 4", 90 DEG., PART #3 TUBE TURN	
9003	FLANGE - (SLIP-ON) (9000)	STEEL	1	5583103104		HDW. 4", 150#, PART #50 TUBE TURN	

PUMP 4 VJC 14

BEARING "D" VM
LUBRICATION GREASEMORRIS SERIAL # M22544-2545
WRITTEN: PLN 09/26/79

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION=2
700	BEARING FRAME	CAST IRON	1	5605036001	5605036AA	ASTM A159, GRADE G2500	
800	THRUST BEARING		2/2	9001217201		MRC7221DU DUPLEX MOUNTING DF OR EQUAL	
801	THRUST BRG. HOUSING	CAST IRON	1	5605037001	5605037AA	ASTM A159, GRADE G2500	
804	THRUST BRG. RETAINER	CAST IRON	1	5605039001	5605039AA	ASTM A159, GRADE G2500	
900	RADIAL BEARING		2/2	9001210203		MRC221RDU DUPLEX MOUNTING DB OR EQUAL	
904	RADIAL BRG. RETAINER	CAST IRON	1	5310800001	5310800AA	ASTM A159, GRADE G2500	
1900	GREASE SEAL (804)		1	9241057030		JOHNS-MANVILLE #8991*LPD 2-1/4" ID X 3-1/2" OD X .50	
1901	GREASE SEAL (904)		1	9241100060		JOHNS-MANVILLE #5192*LPD 3-15/16 ID X 5-1/8 OD X .468	
2300	SLINGER	CAST IRON	1	5605035002	5605035AA	ASTM A48 CLASS 35	
2430	EXCLUDER SLINGER (UPPER)		1			JOHNS-MANVILLE: 11992SSW	
2431	EXCLUDER SLINGER (LOWER)		1			JOHNS-MANVILLE: 14613SSW	
7300	THR & RAD BRG LCKNT		2	9141021104		HDW. AN-21	
7400	THR & RAD BRG LKWSHR		2	9389021104		HDW. W-21	
7730	HEX HD. CAP SCREW (801-804)	STEEL	8			HDW. 1/2"-13 NC2 X 1-3/4" LG.	
7731	HEX HD. CAP SCREW (700-801)	STEEL	8			HDW. 1/2"-13 NC2 X 2-1/4" LG.	

MORRIS SERIAL # M22544-2545
PUMP 4 VJC 14

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION=2
7732	HEX HD. CAP SCREW (700-904)	STEEL	4		HDW.	1/2"-13 NC2 X 1-1/2" LG.	
8000	HEX SOC. SET SCREW (2300)	STEEL	3		HDW.	1/4"-20 NC2 X 1/2" LG. "VC-3 TREATMENT"	
8100	GASKET (700-904)	VELLUMOID	1		HDW.	9-1/2" OD X 7-1/2" ID X 1/16" THK.	
9100	GREASE FITTING (700 & 9132)		4		HDW.	ALEMITE #1610	
9131	PIPE NIPPLE (804)	STEEL	2		HDW.	1/8"-27 NPT X 4-1/2" LG.	
9132	PIPE COUPLING (9100-9131)	STEEL	2		HDW.	1/8"-27 NPT STD.	
9200	SHIM (801-804)	PLASTIC	1	4695726350	HDW.	REQUIRES: 3-.005, 2-.0075, 2-.020 THK.	
9201	SHIM (700-801)	ALUMINUM	16	5604402252	HDW.		

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION-3
RESALE ITEMS							
WOOD'S ULTRA-V BELT DRIVE OR EQUAL							
5000	PUMP SHEAVE		1			5V10.9, 4 GR.	
5000A	BUSHING (5000)		1			"E", BORE: 1-5/8" KEYSEAT: 3/8" X 3/16"	
5001	MOTOR SHEAVE		1			5V8.0, 4 GR.	
5001A	BUSHING (5001)		1			"E", BORE: 2-1/8" KEYSEAT: 1/2" X 1/4"	
5002	BELTS		4			5V710	
9900	MOTOR		1			RELIANCE, FR. 326T	
	50 HP, 1800 RPM, TEFC, 3/60/460V, S.F. 1.0, HORIZ., ROUTINE TESTS AND REPORTS, IMMERSION TEST ON WP11, 40 DEG. C AMB., CONT. DUTY, "BE" INS. ON TEFC, B-ENCAP ON WP11, A/F BEARINGS, 1/60/230V SPACE HEATERS, OVERSIZE CONDUIT BOX, GND. HOLE IN FOOT, 85 DBA MAX. AT 1 METER, STAIN. ST. NAMEPLATE, BEARING RTD'S ON 300 HP, STATOR RTD'S ON 300 HP, PER QUOT. 261A-3794A DATED JULY 11, 1979, DIM. SHEET 602531-1						

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION-9
----------	-------------	----------	------------	-------------	---------------	---------	-----------

INSTRUCTIONS

PERFORMANCE TEST REQUIRED • NON-WITNESS

EXTENDED WARRANTY REQUIRED

PAINT: MORRIS PUMPS INC. STD. FINISH COAT WITH SPECIAL
PRIMER, SEE ITEM 7100.

NAME PLATE: TYPE "B"

S.G.: 1.06, CAP.: 800 GPM, TOTAL HEAD: 110 FT.,

SPEED: 1280 RPM, BHP: 36.2

SCRUBBER AREA DRAINAGE PUMP

M-22544 - 1-P-014A-WSD

M-22545 - 1-P-014B-WSD



TYPE 4VJC14 PUMP


Max. Sphere Size 1 3/8"

Impeller Hydraulic No. 4963001

Casing Hydraulic No. 5579200 Number of Vanes 6

221.1 CC-3A

January 1977






These curves show the characteristics when pumping clear water at 66°F / 20°C

MORRIS PUMPS, INC. • BALDWINVILLE, NEW YORK 13027

186 H 25

5608051

THIS UNIT MUST NEVER BE USED WITHOUT PRIOR INSTALLATION OF THE SAFETY GUARDS FOR ROTATING PARTS AS PRESCRIBED BY O.S.H.A.



NOTE:
THE DISCHARGE PIPE SHOULD BE SUPPORTED INDEPENDENTLY, NEAR THE PUMP, SO THAT WHEN THE FLANGE BOLTS ARE TIGHTENED, NO STRAIN WILL BE TRANSMITTED TO THE PUMP CASING.

TEXAS MUNICIPAL POWER AGENCY
I-P-023A & B-WSD (A)
ASH WATER PUMP COMPLEX
TIPPETT & GEE GC-1166
(C) DESIGN: 5000GPM AT 80 FT. HEAD.


MAY 15 1980 MAY 28 1980 JAN 17 1983

Microfilmed	D REMOVE MIN. SUBMERGENCE	DL 1-17-85	SCALE 1"=1'-0"	TYPE 10VJC22	MORRIS MACHINE WORKS - BALDWINVILLE, N. Y.
Microfilmed	C ADD DESIGN INFO.	DL 1-17-85	DATE 10-4-79	ORDER NO. M-22546-47	PART NAME
				5611275	INSTALLATION DWG.
					B-5614781-M2

FEB 05 1980

MTR., RELIANCE. 200HP, 1800 RPM, FR. 447T (B) 10151979 MTR. SHEAVE 5V14.0-8 PUMP 5V28.0-8 BELTS: (B) 5V1250

3VM BRG. FILE - SEC 03



NOTE "M"
 AT ASSEMBLY, USE SHIMS AS REQUIRED
 TO LOCATE IMPELLER IN CASING

NOTE "N"
 AT ASSEMBLY MEASURE LENGTH "L" AND
 INSTALL NECESSARY SHIMS TO MAKE
 CLEARANCE GAP OF .004 TO .006 AT "G"

TEXAS MUNICIPAL POWER AGENCY
 I-P-023A/B-SSU
 ASH WATER PUMP COMPLEX
 TIPPETT & GEE GC-1166

THIS UNIT MUST NEVER BE USED WITHOUT PRIOR INSTALLATION OF THE
 SAFETY GUARDS FOR ROTATING PARTS AS PRESCRIBED BY O.S.H.A.

			3" x 10"	VJC	MORRIS PLUMBS, INC.	BALDWINVILLE, N.Y.
			10" x 22"		ASSEMBLY	
A					10-12-79	P. 128-6-47
						C-5614822

21067

Rev. 5/15/80 11-9-81

MORRIS MPS, INC.

NOV 15 1982

SHEET 1

ROTATION AND POSITION VERT. R.H., 6'-6"LL, FR. 447T

INST. DWG. 5614781M2 REV C MORRIS SERIAL # M22546-2547
ASSM. DWG. 5614822 PUMP 10 VJC 22

DISCHARGE: VERT. UP

B/M MASTER # 147/10/1
915/03/1 ST. CUSTOMER: TEXAS MUN. POWER AGENCY

BEARING 3 VM

WRITTEN: PLN 10/03/79 CUST P.O. # 1316

OPER. INST. # 2011

APPROVED: CUST. NO. 8852

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION-1
----------	-------------	----------	------------	-------------	---------------	---------	-----------

ASH WATER PUMP COMPLEX

100	CASING	CAST IRON	1	5609085002	5609085AA	ASTM A48 CLASS 35	
200	IMPELLER 5V 22.000 DIA.	CAST IRON	1	5609586002	5609050CA	ASTM A48 CLASS 35	
300	SUCTION DISC	CAST IRON	1	5609045002	5609045AA	ASTM A48 CLASS 35	
311	SUCTION DISC LINER	CAST IRON	1	5609047002	5609047AA	ASTM A48 CLASS 35	
400	HUB DISC	CAST IRON	1	5611035002	5609040AA	ASTM A48 CLASS 35	
504	HUB THROTTLE	CAST IRON	1	5610989002	5610989AA	ASTM A48 CLASS 35	
600	SHAFT	STEEL	1	5614786103		AISI #1045	
618	SHEAVE KEY	STEEL	1	5582711104	HOW.	7/8" SQ. X 4-1/2" LG.	
619	SHAFT SLEEVE	STAIN. STEEL	1	5609095141		AISI #416	
1116	SUC. PIPE SUB-ASSY.	STEEL	1	5611191888		4'-0" O.A. LNG.	
1116A	FLANGE	STEEL	1	5583107104			
1116B	REDUCER	STEEL	1	5583314104			
1116C	PIPE LG.	STEEL	1	5582807104		12" STD. WT. X 33-1/2" LG.	
1600	PIPE COLUMN	STRUC. STEEL	1	5614783104			
2100	MOTOR SUPPORT	STRUC. STEEL	1	5614785104			

MORRIS SERIAL # M22546-2547
PUMP 10 VJC 22

SECTION-1

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS
2119	ADJUSTING SCREW SUB-ASSY.	STEEL	2	5604852807	001/99/6HDW.	
2119A	HEX NUT	STEEL	4		HDW.	3/4"-10 NC2 S.F. HVY.
2119B	CONT. THREADED ROD	STEEL	2		HDW.	3/4"-10 NC2 X 10" LG.
2700	"O" RING SEAL (100-400)	BUNA "N"	1	4974809342	HDW.	
2701	"O" RING SEAL (100-300)	BUNA "N"	1	4974808342	HDW.	
2800	FLOOR PLATE	STRUC. STEEL	1	5614787104		
2801	DISCHARGE PIPE ADAPT PLATE PLATE WELD TO DISCHARGE PIPE (9002) AT ASSY., BEFORE WELDING FLANGE (9003) & AFTER BOLTING DISC. PIPE ADAPT. PLATE (2801) TO FLOOR PLATE (2800)	STEEL	1	5614782104		
4900	BELT GUARD	STEEL	1	5614784104		
7100	PRIMER MINIMUM DRY THICKNESS WILL BE 4 MILS. PER TIPPETT & GEE GC-1166		1			MOBIL ZINC 7, 1 GAL. CAN
7600	HEX HD BOLT & HEXNUT STAIN. STEEL (100-9000)	STEEL	12		HDW.	7/8"-9 NC2 X 3-1/2" LG. 18-8
7603	HEX HD BOLT & HEXNUT STAIN. STEEL (700-1600)	STEEL	8		HDW.	7/8"-9 NC2 X 3-1/2" LG. 18-8
7604	HEX HD BOLT & HEXNUT STAIN. STEEL (700-2800)	STEEL	4		HDW.	7/8"-9 NC2 X 3-1/4" LG. 18-8
7605	HEX HD BOLT & HEXNUT STAIN. STEEL (300-1116)	STEEL	12		HDW.	7/8"-9 NC2 X 3-3/4" LG. 18-8
7606	HEX HD BOLT & HEXNUT STEEL (2100-2800)	STEEL	4		HDW.	3/4"-10 NC2 X 2-1/4" LG.

210678

MORRIS SERIAL # M22546-2547
PUMP 10 VJC 22

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION-1
7607	HEX HD BOLT & HEXNUT (2100-9900)	STEEL	4		HDW.	3/4"-10 NC2 X 2-3/4" LG.	
7608	HEX HD BOLT & HEXNUT (2800-2801)	STAIN. STEEL	4		HDW.	1/2"-13 NC2 X 2-1/4" LG. 18-8	
7700	HEX HD. CAP SCREW (100-300)	STAIN. STEEL	12		HDW.	3/4"-10 NC2 X 2" LG. 18-8	
7701	HEX HD. CAP SCREW (100-400-1600)	STAIN. STEEL	8		HDW.	3/4"-10 NC2 X 3" LG. 18-8	
7702	HEX HD. CAP SCREW (400-504)	STAIN. STEEL	2		HDW.	5/8"-11 NC2 X 1" LG. 18-8	
7704	HEX HD. CAP SCREW (2100-4900)	STEEL	4		HDW.	3/8"-16 NC2 X 1/2" LG.	
8101	GASKET (100-9000)	RUBBER CLOTH	1		HDW.	13-1/4" OD X 10" ID X 1/16" THK.	
8104	GASKET (300-1116)	RUBBER CLOTH	1		HDW.	15" OD X 12" ID X 1/16" THK.	
8201	WASHER (7700)	STAIN. STEEL	12		HDW.	3/4" STD. 18-8	
8202	WASHER (7605)	STAIN. STEEL	12		HDW.	7/8" STD., 18-8	
8203	WASHER (7605)	STAIN. STEEL	12		HDW.	7/8" STD. 18-8	
8204	WASHER (7605)	STEEL	4		HDW.	3/4" STD.	

PUMP 10 VJC 22

BEARING 3 VM
LUBRICATION GREASEMORRIS SERIAL # M22546-2547
WRITTEN: PLN 10/03/79

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION-2
700	BEARING FRAME	CAST IRON	1	5610780001	5610780AA	ASTM A159, GRADE G2500	
800	THRUST BEARING		1	9001300202		MRC 230R OR EQUAL	
801	THR. BRG. HOUSING	CAST IRON	1	5610781001	5345700BA	ASTM A159, GRADE G2500	
804	THRUST BRG. RETAINER	CAST IRON	1	5613810001	5604203BA	ASTM A159, GRADE G2500	
819	THRUST BRG. SPACER	STEEL	1	5610784101		AISI 1020	
830	THRUST BEARING		1/2	9001307303	N/A	MRC 7330P OR EQUAL	
900	RADIAL BEARING		2/2	9001380102		MRC 138KRDU MTG. DB. OR EQUAL	
904	RADIAL BRG. RETAINER	CAST IRON	1	5610785001	5601117AA	ASTM A159, GRADE G2500	
1900	GREASE SEAL (804)		1	9241114071		J-M9170*LPD 4.50 ID X 5.50 OD X .50	
1901	GREASE SEAL (904)		1	9241186108		J-M8990LUP 7.312 ID X 8.438 OD X .56	
2300	SLINGER (600-900)	CAST IRON	1	5610786002	5610786AA	ASTM A48 CLASS 35	
2707	"O" RING (801-700)	BUNA "N"	1			1/8" DIA. X 15-3/4" ID X 16" OD (APPROX. 52" LG.)	
7300	THRUST BRG. LOCKNUT		1	9141030104		HDW. AN30	
7301	RADIAL BRG. LOCKNUT		1	9141038104		HDW. AN38	
7400	THRUST BRG. LIWASHER		1	9389030104		HDW. W30	
7401	RADIAL BRG. LIWASHER		1	9389038104		HDW. W38	

MORRIS SERIAL # M22546-2547
PUMP 10 VJC 22

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION-2
7730	HEX HD. CAP SCREW (804-801)	STEEL	8		HDW.	5/8"-11 NC2 X 1-3/4" LG.	
7731	HEX HD. CAP SCREW (801-700)	STEEL	8		HDW.	3/4"-10 NC2 X 2-3/4" LG.	
7732	HEX HD. CAP SCREW (904-700)	STEEL	4		HDW.	1/2"-13 NC2 X 1-1/2" LG.	
7733	HEX HD. CAP SCREW (904)	STEEL	3		HDW.	1/4"-20 NC2 X 1/2" LG.	
8100	GASKET (904-700)	VELLUMOID	1		HDW.	14-1/4" OD X 11-1/2" ID X .010 THK.	
8203	WASHER (7733)	STEEL	3		HDW.	1/4" STD.	
9101	GREASE FITTING (700-801-804)		3		HDW.	ALEMITE #1627-B 1/4"-18 NPT	
9200	SHIM (801-804)	PLASTIC	1	4695727350	HDW.	REQ'S: 3-.005THK, 3-.0075THK 3-.020THK	
9201	SHIM (801-700)	ALUMINUM	20	5605457252	HDW.		

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION-3
RESALE ITEMS							
WOOD'S ULTRA-V BELT DRIVE OR EQUAL							
5000	PUMP SHEAVE		1			5V28.0, 8 GR.	
5000A	BUSHING		1			"J", BORE: 3-1/2" KEYSEAT: 7/8" X 7/16"	
5001	MOTOR SHEAVE		1			5V14.0, 8 GR.	
5001A	BUSHING		1			"F", BORE: 3-3/8" KEYSEAT: 7/8" X 3/16"	
FURNISH FLAT KEY 7/8" X 5/8" X 3-5/8" LG.							
5002	BELTS		7			5V1250	
9900	MOTOR		1			RELIANCE, FR. 447T	
200 HP, 1800 RPM, TEFC, 3/60/460V, S.F. 1.0, HORIZ., ROUTINE TESTS & REPORTS, IMMERSION TEST ON WP11, 40 DEG. C AMB., CONT. DUTY, BE INS. ON TEFC, B-ENCAP. ON WP11, A/F BEARINGS, SPACE HEATERS 1/60/230V, GND. HOLE IN FOOT, 85 DBA MAX AT 1 METER, STAIN. ST. NAMEPLATE BEARING RTD'S ON 300 HP, STATOR RTD'S ON 300 HP, OVERSIZE CONDUIT BOX. PER QUOT. 261A-3794A DATED JULY 11, 1979, DIM. SH. 604990-60.							

MORRIS SERIAL # M22546-2547

ITEM NO.	DESCRIPTION	MATERIAL	NUMBER REQ.	PART NUMBER	SOURCE NUMBER	REMARKS	SECTION-9
----------	-------------	----------	-------------	-------------	---------------	---------	-----------

INSTRUCTIONS

PERFORMANCE TEST REQ'D. - NON-WIT.

EXTENDED WARRANTY REQ'D.

PAINT: MORRIS PUMPS, INC. STD. FINISH COAT WITH SPECIAL PRIMER,
SEE ITEM 7100

NAME PLATE: TYPE "B"

S.G.: 1.1, CAPACITY: 5000 GPM, TOTAL HEAD: 80 FT.,


SPEED: 870 RPM, BHP: 144

ASH WATER PUMP COMPLEX

M-22546 - 1-P-23A-WSD

M-22547 - 1-P-23B-WSD

PUMP OVJC R2	IMP. HYD. NO. 5609585 CAS. HYD. NO. 5608765	IMP. DIA. R2 NO. VANES 5	SPHERE 2.25 IN.	VARIABLE R.P.M.	NO. 3D-11509 DATE 5-3-78
-----------------	--	-----------------------------	--------------------	--------------------	-----------------------------




LIQUID. WATER	S.G. - 1.0	CAPACITY 1000 U.S. G.P.M.	ORDER NO.
TEMP. 70	H _a - 29.92	DRAWN - VML	

MORRIS PUMPS, INC.
BALDWINVILLE, NEW YORK 13027

REF. CURVE NO. _____



INSTALLATION AND OPERATING INSTRUCTIONS



MORRIS PUMPS, INC.
BALDWINVILLE, NEW YORK 13027

INST NO:
2011

Section I General Pump Instructions

This section is a general installation and operating instruction for most Morris pumps. Specific text and illustrations are included in Section II. The purpose of Section I is to explain those conditions common to different types of pumps.

To insure pump performance and operating life, proper installation and reasonable maintenance are required. The following instructions are a guide for installation and maintenance personnel and the pump operator.

A. PREPARATION FOR SHIPMENT

Morris pumps are prepared at the factory for shipment under covered conditions. They are protected for transport and short term covered storage. Unless otherwise specified, it is assumed the pump will be installed upon delivery. Additional protection can be provided by request.

B. INSTALLATION

1. Location of Unit

The pump should be located in a clean, dry area free from flooding. The area should provide adequate space for maintenance and repair, considering complete disassembly and handling of equipment. The unit should be positioned to provide the most efficient pipeline system.

2. Piping

Short, direct suction and discharge pipelines and a minimum of elbows and fittings result in the least amount of pipe friction.

Suction Piping

- a. Excessive friction losses will cause cavitation.
- b. Must be kept free of air leaks, particularly in long lines or conditions of high suction lift.
- c. Flow regulating valves must not be located on suction side of the pump.

Discharge Piping

- a. Excessive friction losses result in insufficient head.
- b. A check valve should be located in the discharge line to protect the pump from reverse flow and excessive pressure.

Piping Support


The pumps are not designed to carry loads imposed by the weight of the pipeline. Suction and discharge piping must be supported near

the pump, unless otherwise specified. Pumps and subbases can be designed to carry loads due to thermal expansion.

3. Foundation

The foundation must be a permanent, rigid support for the subbase or floorplate. It should be an industrially accepted design capable of absorbing excessive vibration. Foundations are typically concrete with anchor bolts cast in to secure the pump.

An anchor bolt assembly consists of a bolt and washer with a sleeve 2-½ times the diameter of the bolt. When the assembly is cast in concrete, the washer prevents the sleeve and bolt from being pulled. The sleeve I.D. provides an adjustment allowance around the bolt. A lug is generally welded on the bolt to prevent rotation when tightening. Anchor bolts should be located in the concrete by a template dimensioned from the pump installation drawing. The top of the sleeve should be temporarily sealed with waste material to prevent concrete from entering during the concrete pouring operation.



Typical Anchor Bolt

Fig W1

4. Installing Pump on Foundation

If subbases or floorplates were directly anchored to poured concrete foundations, surface irregularities would cause distortion. Rectangular metal blocks and shims, or metal wedges having a small taper, are placed beside each anchor bolt to level the subbase or floorplate (see Fig. W2 and Fig. W3 on following page). The anchor bolts are then drawn tight enough to maintain position and level.

Wet pit vertical pumps are supported on the perimeter of the floorplate. Level by shims beside each anchor bolt and grout as described in "Installing Pump on Foundation".




Fig W5

Subbase mounted horizontal pumps may be shipped with or without drivers and gears. Be sure pump and drivers are uncoupled before installation. Level by shimming beside each anchor bolt and grout as described in "Installing Pump on Foundation".




Fig W6

C. PUMP-DRIVER ALIGNMENT


1. Shaft Alignment of Horizontal Pump & Driver

Pumps and drivers that are received from the factory with both machines mounted on a common subbase were accurately aligned before shipment. Because all subbases are, to some extent, flexible, factory alignment may be altered during shipment and handling. After the subbase has been leveled, grouted, and secured, check the alignment. Alignment should be rechecked after the pump is fully installed and before startup. Refer to the "Alignment Procedure".

- a. On certain large units, limited end-float couplings are used, and the instruction book furnished with such units should be consulted for the special alignment instructions that apply to such couplings.
- b. Disconnect coupling halves before proceeding with alignment. Check for angular and parallel alignment in the next section, "Alignment Procedure". The faces and outside diameters of the coupling halves must be square and concentric with the bores. If this condition does not exist, the "Alternate Method" of alignment described on page 4 is recommended.

2. Alignment Procedure

A check for angular alignment is made by inserting the taper gauge or feelers at four points between the coupling faces and comparing the distance between the faces at four points spaced around the coupling. The unit will be in angular alignment when the measurements show that the coupling faces are the same distance apart at all points (Fig. W7).



CHECKING ANGULAR ALIGNMENT

Fig. W7

5. Alignment of Spacer Type Couplings

Where a spacer type coupling is used between the pump and driver, it is not possible to align the couplings of the pump and driver as previously described. To align units with a floating coupling, remove the spacer between the pump and driver. Make a bracket, as shown in Fig. W10, which can be fastened to one of the coupling halves and which is long enough to reach the other coupling half. Fasten this bracket to one coupling half and a dial-type indicator to the bracket arm so that the indicator is in contact with the rim of the other coupling half as shown at A, Fig. W10. Revolve one coupling half by hand so that the indicator moves around the other coupling half.




Fig.W10

After alignment on the coupling rim has been obtained, change the indicator so it bears against the face of the same coupling half and make any necessary adjustments. If the shafts have end play, it is preferable to make this check of face alignment by using inside micrometers as shown at B, Fig.W10.

Change the bracket, fastening it to the other coupling half, and use the indicator, as described above, against the face and rim of opposite coupling half.

After final alignment is obtained, insert the spacer and bolt the coupling halves.

6. Shaft Alignment of Vertical Pump & Driver

Check for parallel alignment by placing a straight edge across both coupling rims at four points. The unit will be in parallel alignment when the straight edge rests evenly on the coupling rim at all positions (Fig. W11).




Fig.W11

(Refer to "Alternate Method of Alignment" under Horizontal Section).

7. Factors That May Disturb Alignment

The unit should be checked periodically for alignment. If the unit does not stay in line after being properly installed, the following are possible causes:

- (1) Settling, seasoning or spring of the foundation.
- (2) Wear of the bearings.
- (3) Pipe strains distorting or shifting the machine.
- (4) Springing of the base plate by heat from an adjacent steam pipe or from a steam turbine.
- (5) Shifting of the building structure due to variable loading or other causes.
- (6) Loose nuts or bolts on the pump or driver assembly.

D. STUFFING BOXES

In the conventional stuffing box, mechanical seals and packing seal between the stationary and rotating components of the pump. Generally a clear liquid such as water is forced through the stuffing box to lubricate the sealing elements. The lubricating liquid pressure must exceed the pressure of the pumpage at the stuffing box. For end suction pumps, lubricating liquid pressure should be 10-15 PSIG higher than the discharge pressure. For side and double suction pumps, lubricating liquid pressure should be 10-15 PSIG higher than the suction pressure.

NOTE: TO DETERMINE SUCTION OR DISCHARGE PRESSURE, USE GAUGE PRESSURE ONLY.



INSTALLATION AND OPERATING INSTRUCTIONS

INST.NO. W

PAGE.NO. 7

apart to avoid damage during transport. Shipping retainers must be removed before shaft is to be rotated. Pumps with retained seal faces will be specially marked and instructions from the seal manufacturer for retainer removal will be provided.

Mechanical seals have a stationary and a rotating sealing face. Commonly, these sealing rings are of carbon and ceramic material, brittle in nature, and easily damaged. As the sealing rings seat with the operation of the pump, a compatible wear pattern develops between the mating surfaces. To disassemble the mechanical seal after the wear pattern is established would necessitate the replacement of the rotating and stationary sealing elements. Do not replace only one component.

To insure the life and sealing characteristics of the mechanical seal, lubricating liquid must be circulated through the stuffing box. Clear, grit free liquid is necessary.

Special seal information and replacement seal elements should be provided by the seal manufacturer. Morris strongly recommends the stocking of replacement sealing elements.

CAUTION: DO NOT MAKE SHAFT ADJUSTMENTS ON MECHANICAL SEAL INSTALLATIONS, WITHOUT CONSULTING SEAL INSTRUCTIONS AND PUMP ASSEMBLY DRAWING.

E. PUMP START-UP

1. Bearing Lubrication: Bearing must have adequate lubrication. Engage external lubrication system. Consult "BEARING SECTION" of these instructions for specific information.
2. Shaft Rotation: The pump shaft must turn without any binding or rubbing. By manually turning the rotating element, only the uniform frictional drag of the bearings and the stuffing box should be sensed.
3. Correct Rotation of the Driver: The direction of rotation of the driver must be checked before it can be coupled with the pump. The direction of rotation of the pumps is indicated

in a prominent location. For pumps with impellers threaded on the shaft, reverse rotation would back the shaft from the impeller thread. Considerable damage may occur.

4. Lubricating Lines to Stuffing Box: Lubricating liquid must be flowing to the stuffing box before the pump is started. Both mechanical seals and packing require lubrication for continuous service.
5. Priming: The pump must be completely primed before operation.

F. WATER HAMMER

Water hammer is a high pressure surge within a closed pipe system, created by rapid change in the flow rate. Changes in the flow rate occur when there are sudden changes in pump speed. The most common cause is the sudden opening or closing of a valve or flow control device. Extensive damage to the pump and pipeline is a result of water hammer.

G. FREEZING

If the pump is exposed to below freezing temperatures, the liquid should be drained during idle periods.

H. LOCATING PROBLEMS

1. Conditions Leading to Insufficient or No Discharge
 - a. Insufficient speed.
 - b. Excessive discharge head.
 - c. Insufficient NPSH.
 - d. Worn pump components.
 - e. Incorrect direction of rotation.
 - f. Incomplete pump priming.
 - g. Impeller or discharge pipe clogged.
 - h. Pumpage viscosity too high.
2. Conditions Leading to Excessive Power Consumption
 - a. Excessive speed.
 - b. Pump operating at high horsepower area of the pump curve (off design point).
 - c. Mechanical binding or rubbing of rotating element.
 - d. Pumpage specific gravity and/or viscosity too high.

WARNING !

THIS UNIT MUST NEVER BE USED WITHOUT PRIOR INSTALLATION OF THE SAFETY GUARDS FOR ROTATING PARTS AS PRESCRIBED BY O. S. H. A.

OPERATION OF THIS PUMP WITH BOTH SUCTION AND DISCHARGE VALVES CLOSED FOR EVEN BRIEF PERIODS OF TIME IS AN UNACCEPTABLE AND DANGEROUS PRACTICE. IT CAN RAPIDLY LEAD TO A VIOLENT PUMP FAILURE.



INSTALLATION AND OPERATING INSTRUCTIONS

INST NO X-31

PAGE NO. 1

1/25/80
Rev. 8/21/81

"VM" CANTILEVER BEARING ASSEMBLY

This bearing assembly uses a pair of single row ball bearings in the lower radial bearing position and duplexed angular contact ball bearings at the upper end of the shaft to carry the radial and axial thrust loads. The pair of thrust bearings will carry both vertical up and vertical down thrust loads.

CLEARANCE ADJUSTMENT

The axial clearance for the suction side of the impeller is set by moving the thrust bearing housing up or down and holding the clearance by means of a shim stack between the thrust bearing housing and the bearing frame. BE SURE THE SHIMS ARE OF UNIFORM THICKNESS AND FREE FROM BURRS OR IRREGULARITIES THAT COULD MISALIGN THE BEARING HOUSING RELATIVE TO THE FRAME. A misaligned thrust bearing housing will shorten the thrust bearing life and may cause overheating of the bearings.

LUBRICATION

This bearing assembly was designed for grease lubrication. Always use a high quality bearing grease which is equal to:

MOBILUX #2 - Mobil Oil Company

Before the pump is started, one shot of grease should be added to the top grease fitting to lubricate the upper shaft seal. One shot of grease should also be added to the grease fitting just below the bearing housing shims to provide a seal between the bearing housing and frame.

The bearings were hand-packed with grease when the pump was assembled and will not require regreasing until 8 hours of running time. After 8 hours and at one-month intervals, add two shots of grease to each grease fitting.

Excessive amounts of grease will cause higher bearing temperatures because of churning. When this condition exists, adding more grease will only increase the bearing temperatures.

NORMAL BEARING TEMPERATURE

The running temperature for a bearing assembly depends on many factors


- (7) Loosen the set screws which hold the slinger (#2300) to the shaft, slide the slinger away from the radial bearing and press the radial bearings off the end of the shaft.

ASSEMBLY

- (1) Slide the slinger (#2300) and the thrust bearing housing (#801) to the mid-point of the maximum shaft diameter section.
- (2) Install the radial bearings (#900). An inner race spacer shim at least .003" thick is required between the inner races for any bearings that are not universal ground for duplexing. Position the slinger approximately 3/4" away from the bearings and secure with set screws.
- (3) Install the thrust bearings and secure the thrust and radial bearings with lockwashers and locknuts. Hand pack some grease in each bearing ball path.
- (4) Slide the thrust bearing housing (#801) into position and temporarily install the thrust bearing retainer (#804) without any shims, using two cap screws on opposite sides of retainer.
- (5) Measure the gap between the retainer and the bearing housing, remove the retainer and re-install the retainer with a shim stack that is .002" - .004" thicker than the measured gap. The shim stack will allow the thrust bearings to have a small axial clearance to accommodate thermal expansion in the bearings without developing a preload.
- (6) Carefully slide the shaft into the housing and temporarily secure in position with the shim stack and cap screws at the thrust bearing housing.
- (7) Slide the retainer (#904) into position and secure with the cap screws.
- (8) Slide the pipe column into position and bolt the top flange to the bearing frame.
- (9) Position the bearing frame on the floorplate and fasten them together with bolts.

NOTE "A":

AT ASSEMBLY MEASURE LENGTH "L"
AND INSTALL NECESSARY SHIMS TO
MAKE .002-.004 GAP AT "G".



NOTE "M":

AT ASSEMBLY SHIM HERE "A" REQ'D TO
LOCATE IMPELLER IN CASING.

X-31



INSTALLATION AND OPERATING INSTRUCTIONS

INST.NO. Y-110
PAGE.NO. 1

JC LIQUID END

GENERAL:


The JC liquid end can be furnished for horizontal and vertical pumps. The difference in the liquid end configuration is the stuffing box, where a throttle bushing is used for a vertical pump in place of the packing or mechanical seal used with the horizontal pump. The vertical pump may also have a slinger (#2300) at the end of the shaft sleeve.

IMPELLER CLEARANCE:

For the best efficiency and performance, the impeller should have a minimum clearance between the main vanes and the suction disc liner (#311). A gap of approximately .020" is usually sufficient to keep the impeller from rubbing when the pump is operating. If the impeller does rub, the gap should be increased slightly.

TO DISASSEMBLE THE LIQUID END


1. Drain the liquid from the pipe lines and remove the bolts which hold the discharge pipe to the casing (#100) and the suction pipe to the suction disc (#300).
2. Remove the bolts which secure the suction disc to the casing and pull the suction disc out of the casing fit. The suction disc liner is then pulled out of the casing fit.
3. With the shaft clamped, turn the impeller in the direction of normal rotation and unscrew from the shaft.
4. Remove the bolts which fasten the casing to the hub disc (#400) [and pipe column for vertical pumps]. Slide the casing off the hub disc fit. (The hub will separate from the pipe column with vertical pumps).
 - a. Remove the cap screws which hold the hub disc to the bearing frame (horizontal pumps) and slide the hub disc off the end of the shaft.
5. Pull the hook sleeve (#619) off the shaft and with vertical pumps remove the slinger (#2300) if present.
6. Remove the gland, packing, and seal cage or the throttle bushing from the stuffing box.



This drawing shows a throttle bushing in the stuffing box and the liquid end attached to a pipe column.

JC LIQUID END

Wood's 10M
WGC



ULTRA-V V-Belt Drives

- ULTIMATE
COMPACTNESS
- GREAT STRENGTH
- EXCEPTIONAL
SAVINGS

T. B. WOOD'S SONS COMPANY ■ Chambersburg, Pennsylvania 17201


T. B. WOOD'S CANADA LTD. ■ Stratford, Ontario N5A 6V6



SURE-GRIP SHEAVE FEATURES

ULTRA-V SHEAVE FEATURES

Wood's Ultra-V sheaves are constructed of fine grain, high tensile cast iron, and have been carefully engineered to assure maximum performance over a long life span. Behind each sheave is one of the most extensive engineering design and testing programs in the industry.




With the advent of higher V-belt ratings, Wood's engineers instituted additional careful test programs to ensure that each Wood's sheave would be capable of safely and dependably delivering the increased performance which was required by the new ratings. Wood's engineers, using a special strain gage test stand, subject sheaves to tension and compression stresses far in excess of those encountered in actual operation.

In another standard test procedure, Wood's sheaves are operated at extremely high speeds. Sheaves are selected from warehouse stocks and tested until they are burst by centrifugal force. Such destructive testing allows Wood's engineers to study the effects of construction and balance on sheave performance. The goal is to assure safe operation at normal speeds. Other continuing programs check product quality in the laboratory and on the manufacturing line.

For applications with special requirements, Wood's sheaves are also available on a made-to-order basis in either cast or ductile iron, and in Sure-Grip or bored-to-suit construction.

Wood's stock Ultra-V sheaves are available with the convenient Sure-Grip QD type bushing. To install and remove, these split, tapered bushings grip the shaft with the equivalent of a shrink fit. This tight holding power eliminates freezing and fretting corrosion between the shaft and the bore, assuring quick removal and interchangeability when necessary.

Stock sheaves are designed to carry the load of all belts shown in this catalog and other similar rated V-Belts. For special higher rated V-Belts, consult Wood's Engineering Department for recommendations.





We cast or stamp the maximum safe operating speed, in rpm, on all sheaves we manufacture.

Ultra-V and Ultra-V Band V-Belt Features



Ultra-V® Belts


Wood's Ultra-V belt transmits higher loads in less space than the very popular conventional (classical) V-belt. Three Ultra-V belt cross sections cover the same capacity range as the five conventional V-belt sections. Drive capacities from one thru 2000 horsepower are possible because modern advances in synthetic materials and innovations in design give these belts exceptional strength and increased capacity. Ultra-V cross sections are as much as 50% smaller than conventional cross sections, resulting in substantial reductions in drive widths. This lessens bearing loads and permits the use of smaller diameter sheaves and shorter center distances.



All **Ultra-V belts** are of premium grade construction and are oil and heat resisting and static dissipating. The belts permit speeds up to 10,000 fpm with the optimum capacities being in the 8000 fpm range. For speeds above 6500 fpm, the sheaves on the drive may require special balancing and/or construction.

Ultra-V belts have a greater relative sidewall area which increases their grip on the sheaves. Tensile members are located near the top to free the entire sidewall for compression and better gripping. Ultra-V belt construction also provides greater support for the tensile members. The load being carried by each tensile member is equalized because each is kept in alignment without sag. The lighter weight Ultra-V belts resist centrifugal force to provide more efficient power transmission at higher speeds.

Ultra-V® Band Belts




Wood's banded belts offer the benefits of multiple belts in a single, convenient, belt. The banded belts should be used where belt whip or turnover is a problem. They absorb shock and dampen vibration to provide extra protection to machinery. The banded belts have the same advantages as the multiple belts and offer the added feature of eliminating the need for matching belts on most drives. Banded belts are available from stock with 2, 3, 4 and 5 ribs for 3V and 5V and 3, 4, and 5 ribs for the 8V size.

Ultra-V Cog V-Belts

The **Ultra-V Cog** is a proven design with hundreds of drives already in service. **Ultra-V Cog** delivers an average of 30% more horsepower or up to double the belt life . . . a dramatic premium in power, performance and dependability . . . at no premium in price.

Ultra-V Cog raw edge belts can transmit more torque with less slippage than equivalent wrapped belts. When encountering heavy shock loads, the ordinary non-wrapped belt resists slippage and is subject to damaging stresses; a wrapped belt slips through the peak load, but may not recover, especially if tension is too low. Wood's **Ultra-V Cog** belts overcome this problem with a new concept in cog design. This design, teamed with time-proven rubber compounds and a two-ply fabric base, controls slippage, reduces belt temperature and stress and improves efficiency. The **Ultra-V Cog** belt's controlled slip through critical high torque conditions and quick return to full torque transmission ability at all times mean longer life and more dependable service.

The 3VX and 5VX raw edge **Ultra-V Cog** belts are completely interchangeable with regular Ultra-V belts but cannot be mixed on the same drive. For the time being, the 8V belts will continue to be available in the regular Ultra-V construction; that is, all Neoprene compounds and two-ply covers provides static dissipation and excellent resistance to heat and oil. Contact the factory for 8VX belt availability.



ULTRA-V BELT MATCHING STANDARDS



All Wood's Ultra-V belts are length coded at the factory at the time of manufacture. All belts made in recent years are length coded and the code symbol is stamped in a white square border [50]. The codes used could be one, two or three codes above or below the mid-point 50. For example: 47, 48, 49, 50, 51, 52 or 53. Wherever possible, the code symbols on a set of belts should be the same. However, some variation is permissible on longer belts. Refer to the following chart for the allowable variances:

Belt Length (inches)	Ultra-V Belts	
	Allowable Variance	See Example
Up to 180	Same Code	1
190 to 300	2 adjacent numbers	2
over 300	3 adjacent numbers	3

Example 1: When using 3V300 (30 inch) Ultra-V belts all the belts being used in a set should have the same matching code symbol. This could be code 50, 49 or 51, etc.

Example 2: For 5V2240 (224 inch) belts the matching code symbols could vary 2 adjacent numbers—49 and 50, 51 and 52, but not 49 and 51 for a matched set.

Example 3: For 5V3550 (355 inch) belts 3 adjacent code numbers can be used together: 47, 48 and 49; 49, 50 and 51; but not 47, 50 and 52.

Manufacturing tolerances are the principal reason for belt length variations. These tolerances are all being reduced wherever possible and the actual belt construction, molding and curing procedures will be more carefully controlled to produce belts of consistent length.

Wood's tradename for these belts will be "IsoBelt." All belts with the **IsoBelt** stamp in front of the regular branding need not be matched.



TENSIONING V-BELT DRIVES

Without exception, the most important factor in the successful operation of a V-belt drive is proper belt-tensioning. To achieve the long, trouble-free service associated with V-belt drives, belt tension must be sufficient to overcome slipping under maximum peak load. This could be either at start or during the work cycle. The amount of peak load will vary depending upon the character of the driven machine or drive system. To increase total tension, merely increase the center distance. Before attempting to tension any drive it is imperative that the sheaves be properly installed and aligned. If a V-belt slips it is too loose. Add to the tension by increasing the center distance. Never apply belt dressing as this will damage the belt and cause early failure.

GENERAL METHOD

The general method for tensioning V-belts should satisfy most drive requirements.

- Step 1: Reduce the center distance so that the belts may be placed over the sheaves and in the grooves without forcing them over the sides of the grooves. Arrange the belts so that both the top and bottom spans have about the same sag. Apply tension to the belts by increasing the center distance until the belts are snug. See figure 1




Figure 1

- Step 2: Operate the drive a few minutes to seat the belts in the sheave grooves. Observe the operation of the drive under its highest load condition (usually starting). A slight bowing of the slack side of the drive indicates proper tension. If the slack side remains taut during the peak load, the drive is too tight. Excessive bowing or slippage indicates insufficient tension. If the belts squeal as the motor comes on or at some subsequent peak load, they are not tight enough to deliver the torque demanded by the drive machine. The drive should be stopped and the belts tightened.
- Step 3: Check the tension on a new drive frequently during the first day by observing the slack side span. After a few days' operation the belts will seat themselves in the sheave grooves and it may become necessary to readjust so that the drive again shows a slight bow in the slack side.

FORCE DEFLECTION METHOD

This method should be used only for tensioning drives on which the grade of belt, rated belt capacity, service factor, design horsepower, etc. are known. If the drive has been designed in strict accordance with the procedures, instructions, and horsepower ratings in Wood's current catalog, the force deflection values are valid. However, if the drive was designed from editions dated prior to 1980 or using information other than that contained in these catalogs, excessive loads on bearings or excessive shaft deflections may result.

- Step 1: Install belts per Step 1 of General Method above. Measure span length (t) in inches as shown in figure 2, or calculate using formula.
- Step 2: From figure 2 the deflection height (h) is always $1/64$ " per inch of span length (t). For example, a 32" span length would require a deflection of $32/64$ " or $1/2$ ".
- Step 3: Determine the minimum, maximum, and initial recommended pounds force using table 1 or calculate based on the required Static Strand Tension (T_s). Note: The initial recommended force is used only for installing new belts which have not seated themselves into the sheave grooves and where initial belt stretch has not taken place.



TENSIONING V-BELT DRIVES




Figure 2

$$t = \sqrt{C^2 - \left(\frac{D-d}{2}\right)^2}$$

$$h = \frac{t}{64}$$

where t = Span length, inches
 C = Center distance, inches
 D = Larger sheave diameter, inches
 d = Smaller sheave diameter, inches

* Deflection height $h = \frac{1}{64}$ per inch of span

Step 4: Using a spring scale, apply a perpendicular force to any ONE of the belts at the mid point of the span as shown in figure 2. Compare this deflection force with the values found in Step 3.

- If the deflection force is below the minimum, the belts are too loose and the tension should be increased by increasing the center distance.
- If the deflection force is higher than the maximum, the belts are too tight and the tension should be decreased.

When new V-belts are installed on a drive the INITIAL tension will drop rapidly during the first few hours. Check tension frequently during the first 24 hours of operation. Subsequent retensioning should fall between the minimum and maximum force.

To determine the deflection distance from normal position, use a straightedge or stretch a cord from sheave to sheave to use as a reference line. On multiple-belt drives an adjacent undeflected belt can be used as a reference.

Minimum deflection force values shown in table 1 are based on assumed average static tensions for drives having multiple belts or more than one V-band, thus eliminating calculations. (For drives using only one belt or one V-band, deflection force must be determined by use of engineering formulas.)

Find the minimum recommended deflection force for the belt section and type based upon the small sheave diameter, speed and drive ratio. For intermediate sheave diameters and/or drive ratio combinations the minimum deflection force may be interpolated.

MAXIMUM Deflection Force = Minimum times 1.5
 INITIAL Deflection Force = Minimum times 2.0

For Ultra-V Band, Premium V-Band and Torque-Flex banded belts multiply the minimum deflection force from table 1 by the number of belts in the band. Where larger values make use of the Force Deflection Method impractical, use the Elongation Method to tension V-bands.

Table 1 Recommended Minimum Force Per Belt

Belt Section	Small Sheave		Drive Ratio				
	Speed Range	Dia.	1.0	1.5	2.0	4.0 & over	
Ultra-V	3V	1200-3600	2.85	2.0	2.4	2.6	3.0
		1200-3600	3.85	2.8	3.6	3.8	4.2
		1200-3600	4.75	3.8	4.2	4.4	4.8
		1200-3600	5.60	4.2	4.6	4.8	5.4
	5V	1200-3600	6.90	4.6	5.0	5.2	5.6
		900-1800	7.1	8.5	9.5	10	11
		900-1800	9.0	10	11	12	13
		900-1800	14.0	12	13	14	15
	8V	700-1200	21.2	14	15	16	17
		900-1800	12.5	18	21	23	25
		900-1800	14.0	21	23	24	28
		700-1500	17.0	24	26	28	30
Ultra-V Cog	700-1200	21.2	28	30	32	34	
	400-1000	24.8	31	32	34	36	
	3VX	1200-3600	2.20	2.2	2.5	2.7	3.0
		1200-3600	2.50	2.6	2.9	3.1	3.6
1200-3600		3.00	3.1	3.5	3.7	4.2	
1200-3600		4.12	3.9	4.3	4.5	5.1	
5VX	1200-3600	5.30	4.6	4.9	5.1	5.7	
	1200-3600	6.9	5.0	5.4	5.6	6.2	
	1200-3600	4.4	6.5	7.5	8.0	9.0	
	1200-3600	5.2	8.0	9.0	9.5	10	
900-1800	1200-3600	6.3	9.5	10	11	12	
	1200-3600	7.1	10	11	12	13	
	900-1800	9.0	12	13	14	15	
	900-1800	14.0	14	15	16	17	



SHEAVE-BUSHING

Installation Instructions

TO INSTALL:

1. Thoroughly inspect the bore of the mating part and the tapered surface of the bushing. Any paint, dirt, oil or grease must be removed.

IMPORTANT: DO NOT USE LUBRICANTS IN THIS INSTALLATION




Fig. 1 Standard Mounting

Fig. 2 Reverse Mounting

2. Assemble bushing into mating part as illustrated in Fig. 1 or 2. (Since either the standard or the reverse mounting assembly can be rotated so that the bushing flange is toward or away from the motor, four ways of mounting are obtainable.) Loosely insert the cap screws into assembly, but do not lubricate cap screw threads. (Note: Install M thru S bushings in the hub so that the two extra holes in the hub are located as far as possible from the bushing's saw cut.)
3. With key in keyseat of shaft, slide assembly to its desired position with cap screw heads to the outside, Fig. 3. (A few small sheaves may have to be installed with the cap screws on the inside.) If it is difficult to slide the bushing onto the shaft, wedge a screwdriver blade into the saw cut to overcome the tightness.




Fig. 3

4. Position the assembly on the shaft so the belts will be in alignment when installed. Tighten the capscrews evenly and progressively until obtaining the torque value listed in the table at right on each capscrew. There must be a gap between the bushing flange and mating hub when the installation is complete.

10M-74

TO REMOVE:

1. Loosen and remove cap screws.

Fig. 4



2. Insert cap screws (three in JA through J bushings, two in M through S bushings) in tapped removal holes and progressively tighten each one until mating part is loose on bushing, Fig. 4. (Exception: If mating part is installed with cap screw heads next to motor, with insufficient room to insert screws in tapped holes, loosen cap screws and use wedge between bushing flange and mating part.)

3. Remove mating part from bushing and, if necessary, bushing from shaft. If bushing won't slip off shaft, wedge screwdriver blade in saw cut to overcome tightness. See Fig. 5.



Fig. 5

SURE-GRIP BUSHINGS SCREW TIGHTENING INFORMATION


Tapered Bushing	Size & Thread of Cap Screw	Ft.-Lbs. To Apply With Torque Wrench	Wrench Length (Inches)	Wrench Pull (Lbs.)
QT	1/4 x 3/4	6	4	18
JA	No. 10-24	5	4	15
SH-SDS-SD	1/4-20	9	4	27
SK	5/16-18	15	6	30
SF	3/8-16	30	6	60
E	1/2-13	60	12	60
F	9/16-12	75	12	75
J	5/8-11	135	12	113
M	3/4-10	225	15	120
N	7/8-9	300	15	150
P	1-8	450	18	183
W	1 1/8-7	600	24	167
S	1 1/4-7	750	30	167

CAUTION: The tightening force on the screws is multiplied many times by the wedging action of the tapered surface. If extreme tightening force is applied, or if a lubricant is used, bursting pressures will be created in the hub of the mating part.

BALANCING STANDARDS



This chart shows the maximum speed limit (in rpm) for a standard statically balanced sheave of a given diameter and face width. To exceed this speed limit the sheave should also be dynamically balanced. This information can also be used for pulleys.



EXAMPLE: A 10" diameter 2" wide sheave or pulley should be dynamically balanced (balanced in two planes) at 3450 rpm and above. Below 3450 rpm a static balance (balanced in one plane) is sufficient.

NOTE: When belt speeds exceed 6500 feet per minute special ductile iron sheaves must be used.



V-BELT DRIVE MAINTENANCE

1. Check alignment of sheaves. Shafts should be parallel.
2. Maintain Uniform Tension. When idle, belts should appear snug; in motion, they have a slight sag on slack side.
3. Avoid Heat. Above 140 degrees F., rubber is overcured and belt life is shortened.
4. Keep drives well-ventilated. Avoid heat build-up.
5. Never mix belts on a drive. Use new belts of the same make.
6. Always use matched sets of belts.
7. Never use belt dressing.
8. Worn sheaves reduce belt life. Check sheaves frequently.
9. Oil Carefully. Excessive oil on belts causes rubber to swell and belts to fail, prematurely.
10. Never force belts onto sheaves. Release take-up.
11. Equalize slack before tightening. All on top or bottom.

TROUBLE... WHAT TO LOOK FOR HOW TO CORRECT IT

LOSS IN DRIVEN SPEED

Check for slip.

Shut drive down—test sheave temperature by feel. A slipping belt will heat sheave excessively.

Check for proper tension.

Check sheave diameter ratio with ratio of RPM's.

LOCALIZED WEAR

Check cross-section dimensions.

If narrow—pulley is spinning.

If full—internal breakdown with resultant swell.

UNEQUAL STRETCH

Unequal coefficient of friction.

Internal breaks.

Broken strength members.

EXCESSIVE ELONGATION

Check for overload. Check for internal breaks. Check amount of take-up since initial installation.

TRANSVERSE BOTTOM BREAK

If premature—check for small sheaves.

SEPARATION

Check for small pulleys or excessive tension, if premature.

OPENING OF ENVELOPE SEAMS

Check for oil or rubber solvent.

ABNORMAL ENVELOPE WEAR

Check for worn sheave, improper sheave angle, slip, heat, chemical fumes, obstructions or abrasive condition.

BELT SOFTENING OR SWELLING

Check for oil or rubber solvent.

BELT ENVELOPE HARDENING AND CRACKING

Check for excessive heat and chemical fumes.

ENGINEERING TESTING FACILITIES

MORRIS PUMPS, INC.

BALDWINVILLE, N. Y.

TEST REPORT

ON

TWO 4VJC-14 PUMPS

FOR

TEXAS MUNICIPAL POWER AGENCY

Customer P/O 1316

Morris Order M-22544-5

Testing Conducted by:

Edward Sesnie
Test Engineer
May 9 & 12, 1980

OBJECT

Determination of the relationship of total developed head, power input and efficiency to capacity at 1280 RPM.

DESIGN POINTS

Capacity (GPM)	800
TH (Ft. of water)	110
Speed (RPM)	1280

TEST EQUIPMENT

Test tank	60,000 gallon capacity
Speed Indicator	H. Packard pulse generator CMC pulse counter
Discharge Pressure Gauge	0 - 140 ft. water
Suction Pressure Gauge	Mercury column
Flowmeter	6" x 3" Venturi meter by Builders Iron Foundry
Torque Meter	4,000 in.lb. Lebow torque bar and a Lebow Model 7510 readout
Driver	100 HP Reliance D.C. motor

TEST PROCEDURE

The pumps were tested according to the code set forth by the Hydraulic Institute. Readings of discharge pressure, suction pressure, torque (% of bar total capacity), speed and capacity were taken simultaneously at equal increments. Data were recorded at 8 or more points, including the design points, with a small fluctuation (1%) in speed allowed from the desired speed.

From the recorded data, the total head for each point is computed by adding to the difference between suction and discharge pressure any velocity head correction required plus static gauge elevation corrections. Total head corrected (THC) for the desired speed is calculated from:

$$THC = TH \left(\frac{NC}{N} \right)^2$$

where NC = desired speed.

The flow is corrected for the desired speed by the relation

$$QC = Q \left(\frac{NC}{N} \right).$$

The corrected power input is calculated from the following relation:

$$BHPC = \frac{N \cdot R \cdot T}{63025} \left(\frac{NC}{N} \right)^3$$

where:

- R = Deflection of Torque Bar (in %)
 NC = Desired Speed (in RPM)
 N = Actual Speed (in RPM)
 T = Torque Bar Capacity (in pound-inches)
 [See page 1 for actual value]
 63025 = Conversion factor

Efficiency is calculated by the following formula:

$$E = \frac{THC \cdot QC}{3960 \cdot BHPC} (\%)$$

TEST RESULTS

The pumps were quiet and the mechanical operation excellent during the period of testing.

Test results are shown as follows:

<u>PUMP NO.</u>	<u>TEST NO.</u>	<u>CURVE NO.</u>
M-22544	7460	7460
M-22545	7461	7461

Edward Sesnie
 Edward Sesnie
 Test Engineer

ES:bg

UMP

IMP. HYD. NO. 496,3551
CAS. HYD. NO. 55,925 55


IMP. DIA. 1 1/2
NO. VANES 5

SPHERE 1.25 IN.

NO. 177.61
DATE 5/15/25
R.P.M.

CERTIFIED CORRECT

Edward Sesnie
Edward Sesnie
Test Engineer



LIQUID TEMP. H ₂ O AWR	S.G. — 1.0 H _a —	DRAWN — EAS 6-18-50	ORDER NO. M23095
--------------------------------------	--------------------------------	------------------------	------------------

MORRIS PUMPS, INC.
BALDWINVILLE, NEW YORK 13027

REF. CURVE NO. _____

UMP
AUC

IMP. HYD. NO. 493901
CAS. HYD. NO. 5579215

IMP. DIA. 1 1/2
NO. VANES 6


SPHERE
1.38 IN.

1230

R.P.M. NO. 4 20
DATE 5/9/50

CERTIFIED CORRECT

Edward Sesnie
Edward Sesnie
Test Engineer



NPSH - FT.

LIQUID TEMP. H₂O
APMB

S.G. - 1.0
H_a -

DRAWN - EAS
6-18-50

ORDER NO. A122577

MORRIS PUMPS, INC.
BALDWINVILLE, NEW YORK 13027

REF. CURVE NO. _____

ENGINEERING TESTING FACILITIES

MORRIS PUMPS, INC.

BALDWINVILLE, N. Y.

TEST REPORT

ON

TWO 10 VJC PUMPS

FOR

TEXAS MUNICIPAL POWER

Customer P/O 1316

Morris Order M-22546-7

Testing Conducted by:

Edward Sesnie
Test Engineer
June 23 & Aug. 12, 1980

OBJECT

Determination of the relationship of total developed head, power input and efficiency to capacity at 870 RPM.

DESIGN POINTS

Capacity (GPM)	5,000
TH (Ft. of water)	80
Speed (RPM)	870

TEST EQUIPMENT

Test tank	60,000 gallon capacity
Speed Indicator	H. Packard pulse generator CMC pulse counter
Discharge Pressure Gauge	0 - 140 ft. water
Suction Pressure Gauge	Mercury column Water column
Flowmeter	12 x 6 Venturi meter by Builders Iron Foundry
Torque Meter	12,000 in.lb. B.L.H. torque bar and a B.L.H. Model 350 readout
Driver	200 HP D.C. motor for perf. and customer's (belt driven) for vibration and mechanical check.

TEST PROCEDURE

The pumps were tested according to the code set forth by the Hydraulic Institute. Readings of discharge pressure, suction pressure, torque (% of bar total capacity), speed and capacity were taken simultaneously at equal increments. Data were recorded at 8 or more points, including the design points, with a small fluctuation (1%) in speed allowed from the desired speed. Vibration data were recorded over the operating range using customer's motor.

From the recorded data, the total head for each point is computed by adding to the difference between suction and discharge pressure any velocity head correction required plus static gauge elevation corrections. Total head corrected (THC) for the desired speed is calculated from:

$$THC = TH \left(\frac{NC}{N} \right)^2$$

where NC = desired speed.

The flow is corrected for the desired speed by the relation

$$QC = Q \left(\frac{NC}{N} \right).$$

The corrected power input is calculated from the following relation:

$$BHPC = \frac{N \cdot R \cdot T}{63025} \left(\frac{NC}{N} \right)^3$$

where:

R = Deflection of Torque Bar (in %)

NC = Desired Speed (in RPM)

N = Actual Speed (in RPM)

T = Torque Bar Capacity (in pound-inches)
[See page 1 for actual value]

63025 = Conversion factor

Efficiency is calculated by the following formula:

$$E = \frac{THC \cdot QC}{3960 \cdot BHPC} (\%)$$

TEST RESULTS

The pumps were quiet and the mechanical operation excellent during the period of testing.

Test results are shown as follows:

<u>PUMP NO.</u>	<u>TEST NO.</u>	<u>CURVE NO.</u>
M-22546	7465	B-12044
M-22547	7493	B-12045

Edward Sesnie
Edward Sesnie
Test Engineer

ES:bg

PUMP


IMP. HYD. NO. 500457
CAS. HYD. NO. 500457

IMP. D 28.0
NO. VANES 6

SPHERE
IN.

870

R.P.M.
NO. 1
DATE 8-12-80



CERTIFIED CORRECT
Edward Sesnie
Edward Sesnie
Test Engineer

LIQUID-TEMP. H₂O AMB. S.G. - 1.0 H_a - DRAWN - EHS 8-12-80 ORDER NO. M22547

MORRIS PUMPS, INC.
BALDWINVILLE, NEW YORK 13027

REF. CURVE NO. 7993

PUMP
WV10

IMP. HYD. NO. 560759
CAS. HYD. NO. 5608165

IMP. DIA. 2.0
NO. VA. 6


SPHERE
2.25 IN.

277

R.P.M. NO. B1
DATE 6-23-80

CERTIFIED CORRECT

Edward Sesnie
Edward Sesnie
Test Engineer



LIQUID TEMP. H₂O
AMB.

S.G. - 1.0
H_a -

DRAWN - EAS
6-23-80

ORDER NO. MBE546

MORRIS PUMPS, INC.
BALDWINVILLE, NEW YORK 13027

REF. CURVE NO. 7465

CUSTOMER ORDER NO. 49401	DATE 02/08/80	REQ. NO.	S.O. NO. 1M0493627
-----------------------------	------------------	----------	-----------------------

REFER TO THIS NUMBER
 IN ALL CORRESPONDENCE

SOLD TO: MORRIS PUMPS, INC.
 31 E GENESEE ST
 BALDWINVILLE N Y

- DATA PROVIDED WITH THIS TRANSMITTAL AND CERTIFICATION IS:
- FOR CUSTOMER APPROVAL BY DATE: _____
 Return of approval prints by the above date is required to assure scheduled shipment, delay in return and/or revision of approval prints may require shipment reschedule. Return approved D/S to data source.
 - FINAL, APPROVED FOR CONSTRUCTION OR INSTALLATION.
 - PRELIMINARY, ENGINEERING IS COMPLETED.
 - REVISED, SUPERSEDES DATA PREVIOUSLY ISSUED.
 - SEE REMARKS.

SHIP TO: SAME AS "SOLD TO" UNLESS SHOWN

DATA SOURCE: TRANSMITTAL AND CERTIFICATION ISSUED BY: RHW DATE 5/27/80 CK BY _____ DATE _____

ATHENS PLANT
 COLLINS INDUSTRIAL DRIVE
 ATHENS, GEORGIA 30601

*DATE PRINTED: 04/29/80

MOTOR OR GEN. DATA	ITEM A	USED FOR	USERS PLANT	MOTOR OR GEN. D/S: 602531-63
	QTY. 2	FRAME CODE 325T	50 HP	SERV. FA 1.70
	PH/HZ/VOLTS-WINDING 3/60 / 450	DUTY CONT	ENCLOSURE TEFC	TYPE PH
	BEARINGS BALL	MOUNTING & METHOD OF DRIVE F1 /DRCT	RAILS OR BASE	R.P.M. 1800
	ROTAT FROM OPP. DR. END REV	D-C FIELD EXCITATION	DOUBLE SHAFT EXTEN.	AMB./INSL. 40/B /BE
	REDUCER STYLE	CLASS	FRAME	PWR. CODE
BRAKE DATA	BRAKE TYPE	SIZE	RATING FT/LB	OUTPUT RPM
			DUTY	ASSEMBLY
			P.O.	MOTOR OR GEN. C/D: REDUCER OR AUX. D/S: BRAKE OR AUX. D/S: BLOWER MOTOR PH/HZ/VOLTS/HP

DATA FOR CONTROL

D-C MOTOR ARMATURE CURRENT: _____ AMPS

FIELD CHARACTERISTICS PER CURVE:

F₁-f₂ _____ MAX. AMPS _____ RPM

F₁₁-f₂₂ _____ MAX. AMPS _____ RPM

F₃-f₄ _____ MAX. AMPS _____ RPM

A-C MOTOR INFORMATION FOR SELECTION OF STARTER HEATERS:

CODE: F LOCKED AMPS: _____

F.L. CURRENT: 62.0 AMPS.

SPCL. IN-STAL-LATION FEAT. AND MISC. DATA

ADDITIONAL MOTOR OR GEN. DATA:
 LD LOC - STD
 FR CONST RGD

SPECIAL MARKS:
 M-22544-45

SPECIAL FEATURES:
 SPACE HEATERS 230V OPERATED ON 115
 GRD HOLE DN FOOT
 STAINLESS NAMEPLATE
 OVERSIZED CONDUIT BOX
 ROUTINE TEST WITH REPORTS

CERTIFIED DRAWINGS & DATA:
 DATE: _____ MOD.NO: _____
 DATE: _____ MOD.NO: _____
 DATE: _____ MOD.NO: _____
 DATE: _____ MOD.NO: _____

Motor Tag # 1-PM-014A-WSD
 1-PM-014B-WSD

JUN 2 1980

5 CERT D/S & TEST REPORTS TO
 CUST ATTN PURCHASING DEPT 1
 COPY TO 26363
 5 EA PERF CURVES AT 100

RE 1805511

CUSTOMER ORDER NO.	DATE	REQ. NO.	S.O. NO. 1M0493627
--------------------	------	----------	----------------------------------

REFER TO THIS NUMBER
IN ALL CORRESPONDENCE

SHIP TO: SAME AS "SOLD TO" UNLESS SHOWN	DATA PROVIDED WITH THIS TRANSMITTAL AND CERTIFICATION IS: <input type="checkbox"/> FOR CUSTOMER APPROVAL BY DATE: _____ Return of approval prints by the above date is required to assure scheduled shipment, delay in return and/or revision of approval prints may require shipment reschedule. Return approved D/S to data source. <input type="checkbox"/> FINAL, APPROVED FOR CONSTRUCTION OR INSTALLATION. <input type="checkbox"/> PRELIMINARY, ENGINEERING IS COMPLETED. <input type="checkbox"/> REVISED, SUPERSEDES DATA PREVIOUSLY ISSUED. <input type="checkbox"/> SEE REMARKS.
--	---

DATA SOURCE: TRANSMITTAL AND CERTIFICATION ISSUED BY: _____ DATE _____ CK BY _____ DATE _____

MOTOR OR GEN. DATA	ITEM	USED FOR				USERS PLANT			MOTOR OR GEN. D/S:
	QTY.	FRAME		SERV. FA	TYPE	R.P.M.		C BOX D/S	
	PH/HZ/VOLTS-WINDING		DUTY	ENCLOSURE	AMB./INSL.		PWR. CODE	MOTOR OR GEN. C/D:	
	BEARINGS	MOUNTING & METHOD OF DRIVE		RAILS OR BASE	MODEL NUMBER			REDUCER OR AUX. D/S:	
	ROTAT FROM OPP. DR. END		D-C FIELD EXCITATION			DOUBLE SHAFT EXTEN.		BRAKE OR AUX. D/S:	
	REDUCER STYLE	CLASS	FRAME	RATIO	OUTPUT RPM	ASSEMBLY	BLOWER MOTOR PH/HZ/VOLTS/HP		
B. DATA	BRAKE TYPE	SIZE	RATING	DUTY	P.O.				
			FT/LB						

DATA FOR CONTROL	D-C MOTOR ARMATURE CURRENT: _____ AMPS FIELD CHARACTERISTICS PER CURVE: _____ f ₁ -f ₂ _____ MAX. AMPS _____ RPM f ₁₁ -f ₂₂ _____ MAX. AMPS _____ RPM f ₃ -f ₄ _____ MAX. AMPS _____ RPM	A-C MOTOR INFORMATION FOR SELECTION OF STARTER HEATERS: CODE: _____ LOCKED AMPS: _____ F.L. CURRENT: _____ AMPS.
------------------	--	--

SPCL. INST. DATA	**CERTIFIED DRAWINGS & DATA CONTINUED** DATE: MOD.NO: PERCENT & 85 PERCENT VOLTS DATE: MOD.NO: ALLOWABLE CURRENT VS TIME DATE: MOD.NO: FOR RUNNING & STALLED CONDITI DATE: MOD.NO: RPMS AMPS FOR LIGHTEST & DATE: MOD.NO: HEAVIEST STARTING DUTY	
------------------	--	--

Motor Tag # 1-PM-014A-WSD
1-PM-014B-WSD

INDUCTION MOTOR SUBMITTAL DATA RECORD

Client _____ Project _____

Driven Equipment & Spec No. _____

MOTOR NAMEPLATE DATA: (Legibly stamped or engraved on a stainless steel nameplate)

Manufacturer RELIANCE ELECTRIC CO. Horsepower 50
 Full Load Amps 620 Service Factor 1.0 Full Load RPM 1770
 Voltage 460 Phase 3 Frequency 60
 Frame Size FB326T Type PB NEMA Code F
 Insulation Class B/BE NEMA Design B Time Rating CONT.
 Max. Amb., °C 40 Rise, °C 80 Inst. Book No. B3620
 Bearing No., Shaft End 35BC02XPP30A76 Bearing No., Other End 55B03XPP30A76
 Model No. _____ Serial No. 1M0493627

Miscellaneous: (Mfg. Std.) _____

Vertical Motors: Shaft Type (Hollow or Solid) _____

Maximum Downthrust _____ Maximum Upthrust _____

Horizontal Motors: Conduit Box (Right or Left, Facing Shaft) LEFT

Accessories Terminal Box (Right or Left, Facing Shaft) _____

Winding Temp. RTD's: No X Yes _____ Number _____

Bearing Temp. RTD's: No X Yes _____

Bearings: _____ Type _____ Lubrication _____

Inboard or Lower: _____ A/F _____ GREASE

Outboard or Upper: _____ A/F _____ GREASE

Locked Rotor Amperes and Power Factor 341.0 / 100%

SECONDS OF LOCKED ROTOR _____ Other _____

Motor@	Percent of rated voltage		
	85%	100%	110%
40°C	20	20	20
120°C	20	20	20
Maximum rotor temp. <u>N/A</u>			

Net Weight 480 Space Heater Rating 1160 W @ 115 V

Enclosure TEFC Minimum Terminal Voltage 414

Recommended method of motor protection _____ (to be attached on separate sheet)

THE FOLLOWING DATA IS NOT REQUIRED FOR FRACTIONAL - HP MOTORS:

Sound Pressure Level at 3' "A" scale 72

Sound Pressure Level at 3' Unweighted, in Octave Band:

1	2	3	4	5	6	7	8	9	10
-	64	71	62	71	63	57	46	-	-

WK² (Motor Only) 5.78 WK² (Motor Plus Driven Equipment) BY OTHERS _____

Design Air Flow, CFM N/A Stator Res., Ohms at 25°C 0.1857

Air Gap N/A Subtransient Reactance (X''d) N/A

Base: 100% Rated Voltage and 40°C Amb.	1/2 Load	3/4 Load	Rated Load
Amperes	37.4	48.7	62.0
Power Factor	70.4	79.8	83.4
Efficiency	89.8	90.4	90.5
Losses (in KW)	2.08	2.68	3.54
Hot Spot Iron Temp °C	N/A	N/A	128°C APPROX.
Hot Spot Copper Temp °C	N/A	N/A	130°C

Curve Numbers:

Allowable Current VS. Time, Running and Stalled SEE ATTACHED SK-34817-91

Calc. RPM & Amps VS. Time, Accelerating Lightest & Heaviest Loads SEE ATT. SK-34817-92

RPM VS. Torque & Current SEE ATTACHED SK-34817-90A, 90B

Motor Tag # 1-PM-014A-WSD & 1-PM-014B-WSD

DRAWN RET
 DATE 6-1-78
 CHECKED RMK
 APPROVED AFC

TIPPETT & GEE, INC.
 CONSULTING ENGINEERS
 ABILENE TEXAS

GIBBONS CREEK
 STEAM ELECTRIC STATION
 TEXAS MUNICIPAL POWER AGENCY

SH. NO.	REV.	DATE
8 of 8		
STANDARD NO.		
FM-7		

Motor Tag # 1-PM-014A-WSD & 1-PM-014B-WSD


REL. S.O. 1HQ493627
 FRAME 326T
 HP 50
 TYPE P
 PHASE/HERTZ 3/60

RPM 1770
 VOLTS 460
 AMPS 62
 DUTY CONT
 AMB°C/INSUL 40/B

S.F. 1.0
 NEMA DESIGN B
 CODE LETTER F
 ENCLOSURE TEFC
 E/S 590958


ROTOR 411289-30-PE
 TEST S.O. TYPICAL DATA
 TEST DATE ---
 STATOR RES. @ 25°C .1857
 OHMS (BETWEEN LINES)

SPEED-TORQUE AT 100% VOLTS, AND LOAD-TORQUE



SK-34817-90B

SPEED-TORQUE AT 85% VOLTS



SK-34817-90A

AMPERES SHOWN FOR _____ CONNECTION. IF OTHER VOLTAGE CONNECTIONS ARE AVAILABLE, THE AMPERES WILL VARY INVERSELY WITH THE RATED VOLTAGE.

RELIANCE
ELECTRIC
 CLEVELAND, OHIO 44117 U.S.A.

DR. BY CM LANDRYM
 CK. BY D.M. BYER
 APP. BY D.M. BYER
 DATE 05/22/80

A-C MOTOR
PERFORMANCE
CURVES

SK-34817-90A, 90B
 ISSUE DATE 05/22/80

RE 1572VB2 P. 1 U.S.A.

THERMAL LIMIT CURVE 62 FL AMPS RUN SK-34817-91

MOTOR INITIAL TEMPERATURE:
120°C FOR OVERLOAD
120°C FOR LOCKED-ROTOR

50 HP, 1-0-SF, CL B
3 PH, 60 HZ, 460 V
1770 RPM, TEFC, 326T FR

RELIANCE ELECTRIC CO.
REL. NO: 1M0493627
CUST. PO: 49401
CUST. FILE: M-22544-5

APPROVED: *David Byrd*
DATE: 05/22/80

TIME IN SEC.

% FULL LOAD CURRENT

OVERLOAD


LOCKED-ROTOR

Motor Tag # 1-PM-014A-WSD
1-PM-014B-WSD

46 5490

KE SEMI-LOGARITHMIC CYCLES X 10 DIVISIONS
KROFFEL & ESSER CO. MADE IN U.S.A.

05/15/80



REL. S.O. 1MQ493627
 FRAME 326T
 HP 50
 TYPE P
 PHASE/HERTZ 3/60


RPM 1770
 VOLTS 460
 AMPS 62
 DUTY CONT
 AMB°C/INSUL 40/B

S.F. 1.0
 NEMA DESIGN B
 CODE LETTER F
 ENCLOSURE TEFC
 E/S 590958


ROTOR 411289-30-PE
 TEST S.O. CALCULATED DATA
 TEST DATE ---
 STATOR RES. @ 25°C .1857
 OHMS (BETWEEN LINES)

CUST. PO: 49401
 CUST. FILE: M-22544-5

LOAD INERTIA REFLECTED TO MOTOR SHAFT: 3.79 LB.-FT.²
 LOAD TORQUE CURVE: SEE SK-34817-90B
 LOAD HORSEPOWER: HEAVIEST DUTY 36.2 HP
 LIGHTEST DUTY 17.4 HP



SK-34817-92B



Motor Tag # 1-PM-014A-WSD
 1-PM-014B-WSD

SK-34817-92A

AMPERES SHOWN FOR _____ CONNECTION. IF OTHER VOLTAGE CONNECTIONS ARE AVAILABLE, THE AMPERES WILL VARY INVERSELY WITH THE RATED VOLTAGE.

RELIANCE ELECTRIC
 CLEVELAND, OHIO 44117 U.S.A.

DR. BY CM LANDRUM
 CK. BY D.M. BYRD
 APP. BY D.M. BYRD
 DATE 05/22/80

A-C MOTOR PERFORMANCE CURVES


SK-34817-92A, 92B
 ISSUE DATE 05/22/80

U.S.A. RE 1672VBZ P

DUTY MASTER ALTERNATING CURRENT MOTORS

SQUIRREL-CAGE INDUCTION

ENCLOSURE: TOTALLY ENCLOSED - FAN COOLED
 MOUNTING: FOOT, ONE SIZE LARGER CONDUIT BOX
 FRAMES 182T THRU 365TS



DIMENSIONS ARE IN INCHES

FRAME	A	D(2)	E	G	H	J	O	P	AA	AB	AC	AF	BA	AE	K	T
182T-184T	8.50	4.50	3.75	.25	.44	.97	9.00	8.00	1.00	8.44	6.44	2.50	2.75	4.50	1.88	-
213T-215T	9.50	5.25	4.25	.25	.44	.75	10.44	10.38	1.25	9.12	7.12	2.50	3.50	5.25	1.88	2.00
254T-256T	11.50	6.25	5.00	.25	.56	1.19	12.16	11.78	1.50	11.19	8.56	3.19	4.25	6.25	2.62	1.62
284T-286TS	13.75	7.00	5.50	.62	.56	2.50	14.25	14.50	2.00	12.06	9.44	3.19	4.75	7.00	2.75	2.38
324T-326TS	15.50	8.00	6.25	.62	.69	2.75	16.25	16.50	3.00	15.69	11.62	4.25	5.25	8.00	3.12	2.38
364T-365TS	17.00	9.00	7.00	.88	.69	2.75	18.50	19.00	3.00	16.50	13.25	4.25	5.88	9.00	4.00	2.94
(1)																

FRAME	C	BS(4)	B	2F	BACKEND SHAFT AND KEYWAY				SQ. KEY	FRONT END SHAFT AND KEYWAY				SQ. KEY	WT.		
					N	N-W	U (3)	V		ES(Min)	FN	FN-FW	FU(3)			FV	FES(Min)
182T	14.69	2.25	5.50	4.50	2.94	2.75	1.1250	2.50	1.78	.25	3.19	2.25	.8750	2.00	1.41	19	50
184T	15.69	2.75	6.50	5.50	2.94	2.75	1.1250	2.50	1.78	.25	3.19	2.25	.8750	2.00	1.41	19	60
213T	17.75	2.75	6.50	5.50	3.56	3.38	1.3750	3.12	2.41	.31	3.75	2.75	1.1250	2.50	1.78	25	80
215T	19.12	3.50	8.00	7.00	3.56	3.38	1.3750	3.12	2.41	.31	3.75	2.75	1.1250	2.50	1.78	25	92
254T	22.75	4.12	9.75	8.25	4.25	4.00	1.6250	3.75	2.91	.38	4.62	3.38	1.3750	3.12	2.41	.31	150
256T	24.50	5.00	11.50	10.00	4.25	4.00	1.6250	3.75	2.91	.38	4.62	3.38	1.3750	3.12	2.41	.31	150
284T	25.94	4.75	11.50	9.50	4.88	4.62	1.875	4.38	3.28	.50	5.50	4.00	1.6250	3.75	2.91	.38	280
284TS	24.56	4.75	11.50	9.50	3.50	3.25	1.6250	3.00	1.91	.38	4.75	3.25	1.6250	3.00	1.91	.38	278
286T	27.44	5.50	13.00	11.00	4.88	4.62	1.875	4.38	3.28	.50	5.50	4.00	1.6250	3.75	2.91	.38	330
286TS	26.06	5.50	13.00	11.00	3.50	3.25	1.6250	3.00	1.91	.38	4.75	3.25	1.6250	3.00	1.91	.38	328
324T	28.94	5.25	13.25	10.50	5.50	5.25	2.125	5.00	3.91	.50	6.12	4.62	1.875	4.38	3.28	.50	430
324TS	27.44	5.25	13.25	10.50	4.00	3.75	1.875	3.50	2.03	.50	5.25	3.75	1.875	3.50	2.03	.50	427
326T	30.44	8.00	14.75	12.00	5.50	5.25	2.125	5.00	3.91	.50	6.12	4.62	1.875	4.38	3.28	.50	480
326TS	28.94	6.00	14.75	12.00	4.00	3.75	1.875	3.50	2.03	.50	5.25	3.75	1.875	3.50	2.03	.50	477
364T	33.44	6.12	15.25	11.25	6.12	5.88	2.375	5.62	4.28	.62	6.50	4.62	1.875	4.38	3.28	.50	650
364TS	31.31	6.12	15.25	11.25	4.00	3.75	1.875	3.50	2.03	.50	5.62	3.75	1.875	3.50	2.03	.50	644
365T	33.44	6.12	15.25	12.25	6.12	5.88	2.375	5.62	4.28	.62	6.50	5.25	1.875	5.00	3.28	.50	700
365TS	31.31	6.12	15.25	12.25	4.00	3.75	1.875	3.50	2.03	.50	5.62	3.75	1.875	4.00	2.03	.50	694
(1)																	

- (1) SPECIAL DIMENSIONS ON THIS LINE
- (2) "D" VARIES +.00, -.03 - 140T, +.00, -.06 - 400T - 440T
- (3) "U" & FU VARY UP TO 1.825 DIA. +.0000, -.0005
1.825 AND LARGER +.000, -.001
- (4) CENTERLINE OF FOOT MOUNTING HOLE TO CENTERLINE OF TERMINAL HOUSING.

CONDUIT BOX LOCATED ON OPPOSITE SIDE WHEN F-2, W-1, W-4, W-5, W-7, OR C-1 MOUNTING IS SPECIFIED. STANDARD DOUBLE SHAFT SUPPLIED ONLY WHEN SPECIFIED. IF MOUNTING CLEARANCE DETAILS ARE REQUIRED CONSULT FACTORY. MAXIMUM PERMISSIBLE SHAFT RUNOUT WHEN MEASURED AT END OF STD. SHAFT EXTENSION IS .002 T.I.R. UP TO AND INCLUDING 1.825 DIA. AND .003 T.I.R. 1.825 TO 8 INCH DIA.

Motor Tag # 1-PM-014A-WSD
 1-PM-014B-WSD

FRAME- _____ TYPE- _____ CERTIFIED FOR- _____
 ORDER- _____ ITEM- _____ HP- _____ RPM _____ PH- _____ HZ- _____ VOLTS _____
 RELIANCE SALES ORDER- _____ APPROVED BY- _____ DATE- _____

**RELIANCE
 ELECTRIC**
 CLEVELAND, OHIO 44117 U.S.A.

DR. BY: D. Mathews
 CR. BY: L. T. Fournier
 APP. BY: J. M. Pontzer
 DATE: 3-26-76

DIMENSION
 SHEET

602531-63
 ISSUE DATE SEPTEMBER 8, 1979

REISSUED FOR ADDITION OF CURVES

RELIANCE

ELECTRIC COMPANY

MOTOR DIVISION, CLEVELAND, OHIO 44117, U.S.A.

DATA TRANSMITTAL AND CERTIFICATION

CUSTOMER ORDER NO. 49604	DATE 02/08/80	REQ. NO.	S.O. NO. 1MA493733
-----------------------------	------------------	----------	-----------------------

REFER TO THIS NUMBER IN ALL CORRESPONDENCE

LD O:
MORRIS PUMPS, INC.
31 E. GENESEE ST.
BALDWINVILLE, N. Y. 13027

DATA PROVIDED WITH THIS TRANSMITTAL AND CERTIFICATION IS:

FOR CUSTOMER APPROVAL BY DATE: _____
Return of approval prints by the above date is required to assure scheduled shipment, delay in return and/or revision of approval prints may require shipment reschedule. Return approved D/S to data source.

FINAL, APPROVED FOR CONSTRUCTION OR INSTALLATION.

PRELIMINARY, ENGINEERING IS COMPLETED.

REVISED, SUPERSEDES DATA PREVIOUSLY ISSUED.

SEE REMARKS.

HIP O:
SAME AS "SOLD TO" UNLESS SHOWN

TA JRC: TRANSMITTAL AND CERTIFICATION ISSUED BY: RHW DATE 5/27/80 CK BY _____ DATE _____
ATHENS PLANT
COLLINS INDUSTRIAL DRIVE
ATHENS, GEORGIA 30601

ITEM A	USED FOR					USERS PLANT	MOTOR OR GEN. D/S: 604990-89
QTY. 2	FRAME 447T	OOEB 200	SERV. FA HP 1.00	TYPE PB	R.P.M. 1800	C BOX D/S	
PH/HZ/VOLTS-WINDING 3/60/460	DUTY CONT	ENCLOSURE TEFC	AMB./INSL. 40 B/BE	PWR. CODE	MOTOR OR GEN. C/D:		
BEARINGS BALL	MOUNTING & METHOD OF DRIVE F1/ DRCT	RAILS OR BASE	MODEL NUMBER		REDUCER OR AUX. D/S:		
ROTAT FROM OPP. DR. END REV		D-C FIELD EXCITATION		DOUBLE SHAFT EXTEN.		BRAKE OR AUX. D/S:	
REDUCER STYLE	CLASS	FRAME	RATIO	OUTPUT RPM	ASSEMBLY	BLOWER MOTOR PH/HZ/VOLTS/HP	
TA JRC: BRAKE TYPE	SIZE	RATING FT/LB	DUTY	P.O.			

TA JRC: D-C MOTOR ARMATURE CURRENT: _____ AMPS

FIELD CHARACTERISTICS PER CURVE: _____

F₁-F₂ _____ MAX. AMPS _____ RPM

F₁₁-F₂₂ _____ MAX. AMPS _____ RPM

F₃-F₄ _____ MAX. AMPS _____ RPM

A-C MOTOR INFORMATION FOR SELECTION OF STARTER HEATERS:

CODE: F LOCKED AMPS: _____

F.L. CURRENT: 220 AMPS.

CL. N. AL. A. ON AT. ND SC. JA

ADDITIONAL MOTOR OR GEN DATA:
LD LOC - STD
FR CONST RGD
SPECL C/B REQUIRED
AUX C/B REQUIRED

SPECIAL MARKS:
M22546-47

SPECIAL FEATURES:
230V SPACE HTRS OPERATED ON 115/1/60
GROUND HOLE IN FOOT
85 DBA AT 1 METER
OVERSIZED CONDUIT BOX
SEPARATE CONDUIT BOX
STAINLESS NAMEPLATE
ROUTINE TEST W/REPORTS

JUN 2 1980

Motor Tag # 1-PM-023A-WSD
1-PM-023B-WSD

CERTIFIED DRAWINGS & DATA:

5 CERT D/S P/L TEST REPORTS TO CUST ATTN W CLAPP 1 COPY TO 26363 5 COPIES EA PERF CURVES AT 100% & 85% ALLOWABLE CURRENT VS TIME FOR RUNNING & STALL CONDITION RPMS VS AMPS FOR LIGHTEST & HEAVIEST STARTING DUTY

INDUCTION MOTOR SUBMITTAL DATA RECORD

Client _____ Project _____

Driven Equipment & Spec No. _____
 MOTOR NAMEPLATE DATA: (Legibly stamped or engraved on a stainless steel nameplate)

Manufacturer RELIANCE ELECTRIC CO. Horsepower 200
 Full Load Amps 220 Service Factor 1.0 Full Load RPM 1785
 Voltage 460 Phase 3 Frequency 60
 Frame Size EB447T Type PR NEMA Code F
 Insulation Class B/BE NEMA Design B Time Rating CONT
 Max. Amb., °C 40 Rise, °C 80 Inst. Book No. B3620
 Bearing No., Shaft End 40BC03XPP30A26 Bearing No., Other End 110RUC02M30X26
 Model No. _____ Serial No. 1MA493733

Miscellaneous: (Mfg. Std.) _____

Vertical Motors: Shaft Type (Hollow or Solid) _____

Maximum Downthrust _____ Maximum Upthrust _____

Horizontal Motors: Conduit Box (Right or Left, Facing Shaft) LEFT

Accessories Terminal Box (Right or Left, Facing Shaft) LEFT

Winding Temp. RTD's: No X Yes _____ Number _____

Bearing Temp. RTD's: No X Yes _____

Bearings: _____ Type _____ Lubrication _____

Inboard or Lower: _____ BALL GREASE

Outboard or Upper: _____ BALL GREASE

Locked Rotor Amperes and Power Factor 1300 / 24.9%

Other _____

SECONDS OF LOCKED ROTOR			
Motor@	Percent of rated voltage		
	85%	100%	110%
40°C	20	20	20
120°C	20	20	20
Maximum rotor temp. <u>N/A</u>			

Net Weight 1500 ± Space Heater Rating 293.0 W

Enclosure TIPC Minimum Terminal Voltage 414

Recommended method of motor protection _____ (to be attached on separate sheet)

THE FOLLOWING DATA IS NOT REQUIRED FOR FRACTIONAL - HP MOTORS:

Sound Pressure Level at 3' "A" scale 80

Sound Pressure Level at 3' Unweighted, in Octave Band:

1	2	3	4	5	6	7	8	9	10
<u>66</u>	<u>76</u>	<u>77</u>	<u>78</u>	<u>76</u>	<u>69</u>	<u>71</u>	<u>61</u>	-	-

WK² (Motor Only) 520 WK² (Motor Plus Driven Equipment) BY OTHERS

Design Air Flow, CFM N/A Stator Res., Ohms at 25°C 0.246

Air Gap N/A Subtransient Reactance (X'd) N/A

Base: 100% Rated Voltage and 40°C Amb.	1/2 Load	3/4 Load	Rated Load
Amperes	<u>1240</u>	<u>1730</u>	<u>2250</u>
Power Factor	<u>83.0</u>	<u>87.4</u>	<u>90.1</u>
Efficiency	<u>91.2</u>	<u>92.8</u>	<u>93.2</u>
Losses (in KW)	<u>6.56</u>	<u>8.06</u>	<u>10.14</u>
Hot Spot Iron Temp °C	<u>N/A</u>	<u>N/A</u>	<u>128°C APPROX.</u>
Hot Spot Copper Temp °C	<u>N/A</u>	<u>N/A</u>	<u>130°C</u>

Curve Numbers:

Allowable Current VS. Time, Running and Stalled SEE ATTACHED SK-34817-94

Calc. RPM & Amps VS. Time, Accelerating Lightest & Heaviest Loads SEE ATTACHED

RPM VS. Torque & Current SEE ATTACHED SK-34817-93A, 93B

Motor Tag # 1-PM-023A-WSD & 1-PM-023B-WSD



DRAWN <u>RET</u> DATE <u>6-1-76</u> CHECKED <u>RMK</u> APPROVED <u>AFC</u>	TIPPETT & GEE, INC. CONSULTING ENGINEERS ABILENE TEXAS	GIBBONS CREEK STEAM ELECTRIC STATION TEXAS MUNICIPAL POWER AGENCY	SH NO.	REV.	DATE
			8 of 8		
			STANDARD NO. EM-7		

REL. S.O. 1 MA493733
 FRAME 447T
 HP 200
 TYPE P
 PHASE/HERTZ 3/60

RPM 1785
 VOLTS 460
 AMPS 220
 DUTY CONT
 AMB°C/INSUL 40/B

S.F. 1.0
 NEMA DESIGN B
 CODE LETTER G
 ENCLOSURE TEFC
 E/S 501814

ROTOR 414957-37-NE
 TEST S.O. TYPICAL DATA
 TEST DATE ---
 STATOR RES. @ 25°C .0209
 OHMS (BETWEEN LINES)



AMPERES SHOWN FOR CONNECTION. IF OTHER VOLTAGE CONNECTIONS ARE AVAILABLE, THE AMPERES WILL VARY INVERSELY WITH THE RATED VOLTAGE.

RELIANCE
ELECTRIC
 CLEVELAND, OHIO 44117 U.S.A.

DR. BY CM LANDRUM
 CK. BY D.M. RYER
 APP. BY P.M. RYER
 DATE 05/22/80

A-C MOTOR
 PERFORMANCE SK-34817-93A, 93B
 CURVES ISSUE DATE 05/22/80

46 5490

RE SEMILOGARITHMIC CYCLES X 70 DIVISIONS
KUPFER & ESCHER CO. MADE IN U.S.A.

THERMAL LIMIT CURVE 219 FL-AMPS RUN SK-34817-94

MOTOR INITIAL TEMPERATURE:
120°C FOR OVERLOAD
120°C FOR LOCKED-ROTOR

200 HP, 1.0 SF, CL B
3 PH, 60 HZ, 460 V
1785 RPM, TEFC, 44T FR

RELIANCE ELECTRIC CO.
REL. SO: JMA493733
CUST. PD: 49604
CUST. FILE: M22544-7

APPROVED: *David Boyd*
DATE: 05/22/80

TIME IN SEC.


OVERLOAD

LOCKED-ROTOR

Motor Tag # 1-PM-023A-WSD
1-PM-023B-WSD

% FULL LOAD CURRENT

05/15/80



REL. S.O. 11A 4937 33
 FRAME 447T
 HP 200
 TYPE P
 PHASE/HERTZ 3/60



RPM 1785
 VOLTS 460
 AMPS 220
 DUTY CONT
 AMB°C/INSUL 40/B

S.F. 1.0
 NEMA DESIGN B
 CODE LETTER G
 ENCLOSURE TEFC
 E/S 501814

ROTOR 414957-37-NE
 TEST S.O. CALCULATED DATA
 TEST DATE ---
 STATOR RES. @ 25°C .0209
 OHMS (BETWEEN LINES)

CUST. NO. 49604
 CUST. FILE # M-22544-7

LOAD INERTIA REFLECTED TO MOTOR SHAFT 19.7 LB. FT.²
 LOAD TORQUE CURVE: SEE SK-34817-93B
 LOAD HORSEPOWER HEAVIEST DUTY 144 HP
 LIGHTEST DUTY 64.7 HP



AMPERES SHOWN FOR _____ CONNECTION. IF OTHER VOLTAGE CONNECTIONS ARE AVAILABLE, THE AMPERES WILL VARY INVERSELY WITH THE RATED VOLTAGE.

RELIANCE
ELECTRIC
 CLEVELAND, OHIO 44117 U.S.A.

DR. BY CM LANDRUM
 CK. BY J.M.P.
 APP. BY D.M.P.
 DATE 05/23/80

A-C MOTOR
PERFORMANCE SK-34817-95A, 95B
CURVES ISSUE DATE 05/22/80

S.A.
 RE 1572VB2

DUTY MASTER ALTERNATING CURRENT MOTORS


SQUIRREL-CAGE INDUCTION

ENCLOSURE: TOTALLY ENCLOSED
MOUNTING: FOOT

MOUNTING: FAN COOLED

AUXILIARY CONDUIT BOX

FRAMES 445T THRU 449TS ABOVE NEMA RATINGS



DIMENSIONS ARE IN INCHES

FRAME	DUTY	A	D(2)	E	G	H	J	O	P	BA	K	T
445T	Belted	21.00	11.00	9.00	1.12	.81	3.25	23.62	25.00	7.50	3.25	3.25
445TS	Coupled	21.00	11.00	9.00	1.12	.81	3.25	23.62	25.00	7.50	3.25	3.25
447T	Belted	21.00	11.00	9.00	1.12	.81	3.25	24.25	25.00	7.50	3.25	3.25
447TS	Coupled	21.00	11.00	9.00	1.12	.81	3.25	24.25	25.00	7.50	3.25	3.25
449T	Belted	21.00	11.00	9.00	1.12	.81	3.25	24.25	25.00	7.50	3.25	3.25
449TS	Coupled	21.00	11.00	9.00	1.12	.81	3.25	24.25	25.00	7.50	3.25	3.25



FRAME	C	BS	B	2F	BACK END SHAFT & KEY					FRONT END SHAFT & KEY					WEIGHT		
					N	N-W	U (3)	V	LGTH	SO. KEY	FN	FN-FW	FU(3)	FV		LGTH	SO. KEY
445T	44.82	8.25	19.00	16.50	8.50	8.50	3.375	8.25	6.91	.875	8.88	5.88	2.375	5.62	4.28	.625	1500
445TS	40.88	8.25	19.00	16.50	4.75	4.75	2.375	4.50	3.03	.625	7.75	4.75	2.375	4.50	3.03	.625	1890
447T	48.12	10.00	22.50	20.00	8.50	8.50	3.375	8.25	6.91	.875	8.88	5.88	2.375	5.62	4.28	.625	1890
447TS	44.38	10.00	22.50	20.00	4.75	4.75	2.375	4.50	3.03	.625	7.75	4.75	2.375	4.50	3.03	.625	2228
449T	53.12	12.50	27.50	25.00	8.50	8.50	3.375	8.25	6.91	.875	8.88	5.88	2.375	5.62	4.28	.625	2228
449TS	49.38	12.50	27.50	25.00	4.75	4.75	2.375	4.50	3.03	.625	7.75	4.75	2.375	4.50	3.03	.625	2228



MAXIMUM FULL LOAD AMPERES	AA (5) PIPE TAP	REF. ONLY CONDUIT BOX
201	4	76870-B
335	5	76870-D
600	6	76870-A

SPACE HEATER C/BOX			
FRAME	LX	PX	AAX
445	11.12	15.50	1.00
447	12.88	15.50	1.00
449	15.38	15.50	1.00



FRAME	(5) AA	AE	STANDARD			CORR. PROOF (4)		
			AB	AC	AF	AB	AC	AF
445T		11.00	22.50	17.25	7.00	22.75	17.50	7.00
445TS	REFER	11.00	22.50	17.25	7.00	22.75	17.50	7.00
447T	TO	11.00	22.50	17.25	7.00	22.75	17.50	7.00
447TS	NOTE	11.00	22.50	17.25	7.00	22.75	17.50	7.00
449T	(5)	11.00	22.50	17.25	7.00	22.75	17.50	7.00
449TS		11.00	22.50	17.25	7.00	22.75	17.50	7.00



Motor Tag # 1-PM-023A-WSD
1-PM-023B-WSD

- (1) SPECIAL DIMENSIONS ON THIS LINE
- (2) "D" VARIES +.00 -.06
- (3) "U" AND "FU" VARY +.000 -.001
- (4) CORROSION PROOF CONDUIT BOX SUPPLIED ONLY WHEN SPECIFIED
- (5) "AA" VARIES WITH FULL LOAD AMPS. PER TABLE ABOVE

CONDUIT BOX LOCATED ON OPPOSITE SIDE WHEN F-2, W-1, W-4, W-5, W-7, OR C-1 MOUNTING IS SPECIFIED. STANDARD DOUBLE SHAFT SUPPLIED ONLY WHEN SPECIFIED. IF MOUNTING CLEARANCE DETAILS ARE REQUIRED CONSULT FACTORY. MAXIMUM PERMISSIBLE SHAFT RUNOUT WHEN MEASURED AT END OF STD. SHAFT EXTENSION IS .003 T.I.R. TO 5 INCH DIA.

FRAME _____ TYPE _____ CERTIFIED FOR _____
 ORDER _____ ITEM _____ HP _____ RPM _____ PH _____ HZ _____ VOLTS _____
 RELIANCE SALES ORDER _____ APPROVED BY _____ DATE _____

983VD7 Printed in U.S.A.




DR BY *J. Anderson*
 CK BY *J. J. F. ...*
 APP BY *C. J. ...*

DIMENSION SHEET



604990-89

ISSUE DATE DECEMBER 5, 1978



Motor Tag # 1 - PM-014A-WSD
1 - PM-014B-WSD
1 - PM-023A-WSD
1 - PM-023B-WSD

INSTALLATION, OPERATION AND CARE OF
RELIANCE
STANDARD INTEGRAL HORSEPOWER INDUCTION MOTORS
(180 - 449 FRAMES)



IMPORTANT: It is important that these instructions be studied by the men installing and operating this equipment. Read thoroughly before starting. Keep these instructions for future reference.

TABLE OF CONTENTS

	Page
RECEIVING AND HANDLING	
Acceptance	3
Storage	3
Unpacking	3
Waranty	3
INSTALLATION	
Inspection	4
Location	4
Lifting Means	4
Mounting	4
Drive	4
Rotating Parts	5
Wiring	5
Grounding	5
Starting	5
Drain Plugs	5
Rotation	6
Temperature Rise	6
Test For General Condition	6
Initial Lubrication	6
OPERATION	6
MAINTENANCE	7
Disassembly	7
Removing Brackets and Rotor	7
Removing and Replacing Ball Bearings	7
Reassembly	7
LUBRICATION OF ANTI-FRICTION BEARINGS	8
Recommended Lubricant	8
Lubrication Frequency	8
Roller Bearings	8
Ball Bearings	8
Lubrication Procedure	8
Recommended Volume	8
TYPICAL ANTI-FRICTION BEARING CONSTRUCTION	9
REPLACEMENT BEARINGS	9
PARTS IDENTIFICATION DRAWING	10
TOTAL SERVICE PROGRAMS	11
Renewal Parts	11
New Parts Guarantee	11
Additional Literature	11

TOTAL SERVICE PROGRAMS

Reliance Electric can provide a wide range of maintenance programs to help you reduce downtime, improve productivity and increase profits. Capabilities include:

- Electrical and Mechanical Start-Up Service
- Electrical Preventive Maintenance
- Mechanical Preventive Maintenance
- Vibration Analysis
- Mobile Van Repair Service
- Balancing and Alignment Service
- Maintenance Schools
- 24-Hour Technical Support
- Modernization Service

For more information contact your local Reliance Electric Sales Office or write:

Reliance Electric Company
Technical Services
24701 Euclid Avenue
Cleveland, Ohio 44117

RENEWAL PARTS

An adequate stock of factory-made renewal parts is an integral part of a sound maintenance program to protect against costly downtime.

Parts can be obtained from your nearest Reliance parts distributor, or directly from the Reliance factory. When ordering parts for which a part number is not available, give complete description of part and purchase order number, serial number, model number, etc., of the equipment on which the part is used.

A detailed parts list, which gives Reliance recommendations for spare parts that should be stocked for your equipment, can be ordered from:

1. Nearest Reliance Electric Sales Office
2. Nearest Reliance Electric Distributor
3. Reliance Electric Renewal Parts, Cleveland, Ohio

Be sure to include complete nameplate data — purchase order number, serial number, rating, etc. — for your equipment when ordering the spare parts list.

NEW PARTS GUARANTEE

New parts sold by the Company are warranted to be of the kind and quality contracted for and to be free of defects in material and workmanship for a period of one year from the date of shipment by the Company.

If within this period the Company receives from the Buyer written notice of any alleged defect in any such part and if the part is found not to be in conformity with this warranty (the Buyer having provided the Company a reasonable opportunity to perform any appropriate tests thereon) the Company will, at its option and expense, either repair the same or supply a replacement therefore.

The Company, under either option, shall have the right to require the Buyer to deliver the part for this purpose to a designated service center and the Buyer shall pay all charges for inbound and outbound transportation and for services of any kind, diagnostic or otherwise, excepting only the direct and actual cost of repair or replacement as provided above.

The company's liability under this warranty or any other warranty whether expressed or implied in law or fact shall be limited to the repair or replacement of defective material and workmanship and in no event shall it be liable for consequential or indirect damages.

ADDITIONAL LITERATURE

Additional literature covering the maintenance of a-c motors can be obtained from the Reliance Electric Services Division. Requests should be submitted through your nearest Reliance Electric Sales Office.

RECEIVING AND HANDLING

ACCEPTANCE

Thoroughly inspect the equipment before accepting shipment from the transportation company. If any of the goods called for in the bill of lading or express receipt are damaged or the quantity is short, do not accept them until the freight or express agent makes an appropriate notation on your freight bill or express receipt. If any concealed loss or damage is discovered later, notify your freight or express agent at once and request him to make an inspection. We will be very happy to assist you in collecting claims for loss or damage in shipment; however, this willingness on our part does not remove the transportation company's responsibility in reimbursing you for collection of claims or replacement of material. Claims for loss or damage in shipment must not be deducted from the Reliance invoice, nor should payment of the Reliance invoice be withheld awaiting adjustment of such claims, as the carrier guarantees safe delivery.

If considerable damage has been incurred and the situation is urgent, contact the nearest Reliance District Office for assistance. Please keep a written record of all communications.

STORAGE – DUTY MASTER A-C MOTORS

Storage requirements for motors under negotiated extended warranty are listed below. When a negotiated extended warranty is in effect, these extended storage requirements must be followed to allow the submission of a valid warranty claim.

1. The motors, if not mounted, are to be stored in the original containers in a clean, dry, protected warehouse.
2. The storage area is to be free from any vibration and from extremes in temperature.
3. Bearings
 - a. Ball & Roller (anti-friction) The bearings are to be fully greased at the time of going into extended storage. Motor shafts are to be rotated manually every 6 months and additional grease added purging some of that in cavity. Grease in the bearings is to be purged at the time of removal from storage, making sure that an ample supply of fresh grease is in each grease cavity.
 - b. Sleeve (oil lub) The bearings are tested using an oil containing a rust inhibitor. Prior to shipment the oil is drained. If motor is stored more than one month the oil reservoirs must be refilled to the indicated level with the specified lubricant. (See Instruction Manual) The shaft should be rotated by hand every month at least 10 to 15 revolutions to assure that an oil film is on the shaft and bearing surfaces.
4. All drains to be fully operable while in storage, and/or the drain plugs removed. The motors must be stored so that the drain is at the lowest point. All breathers and automatic "T" drains must be operable to allow

breathing at points other than through the bearing fits.

5. All units equipped with heaters are to have the heaters connected if storage conditions in any way simulate or approach atmospheric conditions experienced in operation.
6. Windings to be megged at the time equipment is put in storage. At the time of removal from storage, the resistance reading must not have dropped more than 50% from the initial reading. Any drop below this point necessitates electrical or mechanical drying. Where a large quantity of motors is stored, an inspection or sampling should be made by removing the end brackets and visually inspecting for the presence of water in the grease or rust on the bearing. If present, replace the bearings and relubricate.
7. All external parts and motors subjected to corrosion should be protected by some corrosive resistant coating.
8. Where motors are not stored in the original containers, but are removed and mounted on other pieces of machinery, the mounting must be such that the drains and breathers are fully operable. In this respect, the drains must be kept at the lowest point in the motor and/or the drain plugs removed so that all condensation can automatically drain out.
9. All other storage conditions apply, including rotation of motor shafts. Where such conditions cannot be met, then the equipment must be treated the same as if it were mounted in its normal position, and all protective devices such as heaters, breathers, and drains fully operable.

UNPACKING

After unpacking and inspection to see that all parts are in good condition, turn the shaft by hand to be sure there are no obstructions to free rotation. Equipment which has been in storage for sometime should be tested and relubricated prior to being put into service. Refer to "Test for General Condition" and "Lubrication" for procedure to be performed after extended storage.

Equipment with roller bearings is shipped with a shaft block at the opposite pulley end. In removing the shaft block, be sure to replace the bolts which are used to hold the shaft block in place during shipment.

WARRANTY

The Reliance Electric Company warrants workmanship and materials on this motor for a period of one year from date of shipment from the Reliance factory. In every case concerning warranty, contact the nearest Reliance Sales Office or authorized Reliance Service Shop.

INSTALLATION

INSPECTION

After the motor is unpacked, examine the nameplate data to see that it agrees with the power circuit to which it is to be connected. The motor is guaranteed to operate successfully with frequency not more than 5% and voltage

not more than 10% above or below the nameplate data, or combined variation of voltage and frequency of not more than 10% above or below nameplate data. Efficiency, power factor and current may vary from nameplate data.

TABLE 2. General Effect of Voltage and Frequency Variation on Induction-motor Characteristics

Variation	Starting and max running torque	Syn-chronous speed	% slip	Full-load speed	Efficiency			Power factor			Full-load current	Starting current	Temp rise, full load	Max overload capacity	Magnetic noise—no load in particular
					Full load	3/4 load	1/2 load	Full load	3/4 load	1/2 load					
Voltage variation:															
120% voltage	Increase 44%	No change	Decrease 30%	Increase 1.5%	Small increase	Decrease ½–2 points	Decrease 7-20 points	Decrease 5-15 points	Decrease 10-30 points	Decrease 15-40 points	Decrease 11%	Increase 25%	Decrease 5-6°C	Increase 44%	Noticeable increase
110% voltage	Increase 21%	No change	Decrease 17%	Increase 1%	Increase ½–1 point	Practically no change	Decrease 1-2 points	Decrease 3 points	Decrease 4 points	Decrease 5-6 points	Decrease 7%	Increase 10-12%	Decrease 3-4°C	Increase 21%	Increase slightly
Function of voltage	(Voltage) 2	Constant	1 (voltage) 2	(Synchronous speed slip)								Voltage		(Voltage) 2	
90% Voltage	Decrease 19%	No change	Increase 23%	Decrease 1%	Decrease 2 points	Practically no change	Increase 1-2 points	Increase 1 point	Increase 2-3 points	Increase 4-5 points	Increase 11%	Decrease 10-12%	Increase 6-7°C	Decrease 19%	Decrease slightly
Frequency variation:															
105% frequency	Decrease 10%	Increase 5%	Practically no change	Increase 5%	Slight increase	Slight increase	Slight increase	Slight increase	Slight increase	Slight increase	Decrease slightly	Decrease 5-6%	Decrease slightly	Decrease slightly	Decrease slightly
Function of frequency	1 (frequency) 2	Frequency		(Synchronous speed slip)								1 frequency			
95% frequency	Increase 11%	Decrease 5%	Practically no change	Decrease 5%	Slight decrease	Slight decrease	Slight decrease	Slight decrease	Slight decrease	Slight decrease	Increase slightly	Increase 5-6%	Increase slightly	Increase slightly	Increase slightly

NOTE: This table shows general effects, which will vary somewhat for specific ratings.

LOCATION

The motor should be installed in a location compatible with the motor enclosure and specified ambient.

LIFTING MEANS

WARNING — WHEN A LIFTING MEANS IS PROVIDED FOR HANDLING THE MOTOR OR GENERATOR, IT SHOULD NOT BE USED TO LIFT THE MOTOR OR GENERATOR PLUS ADDITIONAL EQUIPMENT SUCH AS GEARS, PUMPS, COMPRESSORS, OR OTHER DRIVEN EQUIPMENT. In the case of assemblies on a common base, any lifting means provided on the motor or generator should not be used to lift the assembly and base out, rather, the assembly should be lifted by a sling around the base or by other lifting means provided on the base. In all cases, care should be taken to assure lifting in the direction intended in the design of the lifting means. Likewise, precautions should be taken to prevent hazardous overloads due to deceleration, acceleration or shock forces.

MOUNTING

Mount the motor on a foundation sufficiently rigid to prevent excessive vibration. Ball-bearing motors may be mounted with the feet at any angle. After carefully aligning the motor with the driven unit, bolt securely in place.

DRIVE

The pulley, sprocket, or gear used in the drive should be located on the shaft as close to the shaft shoulder as possible. Heat to install. Driving a unit on the shaft will damage the bearings.

Belt Drive: Align the pulleys so that the belt will run true; tighten the belt just enough to prevent slippage, any tighter will cause premature bearing failure. If possible, the lower side of the belt should be the driving side.

INSTALLATION (Cont'd)

Chain Drive: Mount the sprocket on the shaft as close to the bracket as possible. Align the sprockets so that the chain will run true. Avoid excessive chain tension.

Gear Drive and Direct Connection: Accurate alignment is very essential. Secure the motor and driven unit rigidly to the base.

ROTATING PARTS

WARNING – ROTATING PARTS, SUCH AS COUPLINGS, PULLEYS, EXTERNAL FANS, AND UNUSED SHAFT EXTENSIONS, SHOULD BE PERMANENTLY GUARDED AGAINST ACCIDENTAL CONTACT WITH HANDS OR CLOTHING. THIS IS PARTICULARLY IMPORTANT WHERE THE PARTS HAVE SURFACE IRREGULARITIES SUCH AS KEYS, KEYWAYS OR SET SCREWS. SOME SATISFACTORY METHODS OF GUARDING ARE:

1. Covering the machine and associated rotating parts with structural or decorative parts of the driven or driving equipment.
2. Providing covers for the rotating parts. The openings in or at the edges of such covers should not be over 1/2 inch wide (3/4 inch if the rotating parts are more than 4 inches from the opening) in the direction, usually above and to the side, from which contact is to be expected. In other directions where other stationary parts, such as a sub-base provide partial guarding, somewhat wider openings may be used. Covers should be sufficiently rigid to maintain adequate guarding in normal service.

WIRING

Connect the motor to the power supply according to the diagram on the motor nameplate. For most 230 and 460 volt motors, nine leads are brought out from the stator windings so that the motor may be connected for either 230 or 460 volts.

GROUNDING

WARNING – THE FRAMES AND OTHER METAL EXTERIORS OF MOTORS AND GENERATORS (EXCEPT FOR INSULATED PEDESTAL BEARINGS) USUALLY SHOULD BE GROUNDED TO LIMIT THEIR POTENTIAL TO GROUND IN THE EVENT OF ACCIDENTAL CONNECTION OR CONTACT BETWEEN LIVE ELECTRICAL PARTS AND THE METAL EXTERIORS. See the *National Electrical Code*, Article 430 for information on grounding of motors, Article 445 for grounding of generators, and Article 250 for general information on grounding. In making the ground connection, the installer should make certain that there is a solid and permanent metallic connection between the ground point, the motor or generator terminal housing, and the motor or generator frame. A common method of providing a ground is through a grounded metallic conduit system.

Motors with resilient cushion rings are usually supplied with a bonding conductor across the resilient member. Some motors are supplied with the bonding conductor on the concealed side of the cushion ring to protect the bond from damage. Motors with bonded cushion rings should usually be grounded at the time of installation in accordance with the above recommendations for making ground connections. When motors with bonded cushion rings are used in multimotor installations employing group fusing or group protection, the bonding of the cushion ring should be checked to determine that it is adequate for the rating of the branch circuit overcurrent protective device being used.

There are applications where grounding the exterior parts of a motor or generator may result in greater hazard by increasing the possibility of a person in the area simultaneously contacting ground and some other nearby live electrical part of other ungrounded electrical equipment. In portable equipment it is difficult to be sure that a positive ground connection is maintained as the equipment is moved, and providing a grounding conductor may lead to a false sense of security. When careful consideration of the hazards involved in a particular application indicate the machine frames should not be grounded or when unusual operating conditions dictate that a grounded frame cannot be used, the installer should make sure the machine is permanently and effectively insulated from ground. In those installations where the machine frame is insulated from ground, it is recommended that appropriate warning labels or signs be placed on or in the area of the equipment by the installer.

STARTING

WARNING – BEFORE STARTING MOTOR, REMOVE ALL UNUSED SHAFT KEYS AND LOOSE ROTATING PARTS TO PREVENT THEM FROM FLYING OFF.

When starting the motor, check the following items:

1. The rotor should turn freely when disconnected from the load.
2. Driven machine should be unloaded when first starting the motor.

The motor should run smoothly with little noise. If the motor should fail to start and produces a decided hum, it may be that the load is too great for the motor or that it has been connected improperly. Shut down immediately and investigate for trouble.

DRAIN PLUGS

If motor is totally enclosed fan-cooled or non-ventilated it is recommended that condensation drain plugs be removed. These are located in the lower portion of the end-shields. Totally enclosed fan-cooled "XT" motors are equipped with automatic drains which should be left in place as received.

INSTALLATION (Cont'd)

ROTATION

To reverse the direction of rotation, disconnect from power source and interchange any two of the three line leads for three phase motors.

TEMPERATURE RISE

Under normal operating conditions, with the motor applied in accordance with the nameplate rating, the temperature rise will not exceed the proper limits. Always use a thermometer to determine the heating of a motor. The hand is not reliable in determining whether or not the motor is too hot.

TEST FOR GENERAL CONDITION

If the motor has been in storage for an extensive period

or has been subjected to adverse moisture conditions, it is best to check the insulation resistance of the stator winding with a megohmmeter.

If the resistance is lower than one megohm the windings should be dried in one of the two following ways:

1. Bake in oven at temperatures not exceeding 90°C. until insulation resistance becomes constant.
2. With rotor locked, apply low voltage and gradually increase current through windings until temperature measured with thermometer reaches 194°F. Do not exceed this temperature.

INITIAL LUBRICATION

"Reliance motors are shipped from the factory with the bearings properly packed with grease and ready to operate. Where the unit has been subjected to extended storage (6 months or more) the bearings should be relubricated prior to starting."

OPERATION

Due to the inherent characteristics of insulating materials, abnormally high temperatures shorten the operating life of electrical apparatus. The total temperature, not the temperature rise, should be the measure of safe operation. The class of insulation determines the maximum safe operating temperature. Aging of insulation occurs at an accelerated rate at abnormally high temperatures. A general rule for gauging the effect of excessive heat is that for each 10°C. rise in temperature above the maximum limit for the insulation, the life of the insulation is halved.

Unbalanced voltage or single-phase operation of poly-phase machines may cause excessive heating and ultimate failure. It requires only a slight unbalance of voltage applied to a polyphase motor to cause large unbalance currents and resultant overheating.

Periodic checks of phase voltage, frequency and power consumption of a motor while in operation are recommended; such checks assure the correctness of frequency and voltage applied to the motor and yield an indication of the load offered by the apparatus which the motor drives. Comparisons of this data with previous no-load and full-load power demands will give an indication of the performance of the complete machine. Any serious deviations should be investigated and corrected.

Stator troubles can usually be traced to one of the following causes:

Worn bearings	Operating single phase
Moisture	Poor insulation
Overloading	Oil and dirt

Dust and dirt are usually contributing factors. Some forms of dust are highly conductive and contribute materially to insulation breakdown. The effect of dust on the motor temperature through restriction of ventilation is a principal reason for keeping the windings clean.

Squirrel-cage rotors are rugged and, in general, give little trouble. The first symptom of a defective rotor is lack of torque. This may cause a slowing down in speed accompanied by a growling noise or perhaps failure to start the load.

This is caused by an open or high resistance joint in the rotor bar circuit. Such a condition can generally be detected by looking for evidence of localized heating.

Rotating parts, such as couplings, pulleys, internal-external fans and unused shaft extensions should be permanently guarded against accidental contact with hands or clothing.

MAINTENANCE

The fundamental principle of electrical maintenance is **KEEP THE APPARATUS CLEAN AND DRY**. This requires periodic inspection of the motor, the frequency depending upon the type of motor and the service.

The following should be checked at regular intervals:

1. Windings should be dry and free of dust, grease, oil, and dirt. Windings may be cleaned by suction cleaners or by wiping. Nozzles on suction type cleaners should be non-metallic. Gummy deposits of dirt and grease may be removed by using a commercially available low volatile solvent. **WARNING – DO NOT USE GASOLINE OR OTHER INFLAMMABLE SOLVENTS.**
2. Terminal connections, assembly screws, bolts and nuts should be tight. They may loosen if motor is not securely bolted and tends to vibrate.
3. Insulation resistance of motors in service should be checked periodically at approximately the same temperature and humidity conditions to determine possible deterioration of the insulation. When such measurements at regular intervals indicate a wide variation, the cause should be determined. Motor should be reconditioned if the motor has been subjected to excessive moisture, or by re-winding or re-insulating if necessary. Enclosed motors require very little attention. Be sure that external air chamber of fan-cooled motors does not become clogged with foreign material which will restrict passage of air.

DISASSEMBLY

If it becomes necessary to disassemble the motor, care should be taken not to damage the stator windings as the insulation may be injured by improper or rough handling. Precautions to keep bearings clean should be exercised.

Before removing either end shield:

1. Disconnect motor from power source. Tag the leads to insure proper reconnection.

2. Remove motor from mounting base.

3. Make end brackets relative to position on frame so they can be easily replaced.

REMOVING BRACKETS AND ROTOR

4. Remove bearing cartridge nuts or screws. (If used)
5. Remove front end bracket bolts.
6. Pull bracket.
7. Remove back end bracket in same manner.
8. Remove rotor.

REMOVING AND REPLACING BALL BEARINGS

BEARINGS SHOULD NOT BE REMOVED UNLESS THEY ARE TO BE REPLACED. WHEN REMOVAL IS NECESSARY, USE A BEARING PULLER. A BEARING PULLER MAY BE RIGGED BY USING A METAL PLATE, WITH HOLES DRILLED TO MATCH THE TAPPED HOLES IN THE INNER CAP. USE CARE TO KEEP THE PRESSURE EQUAL TO PREVENT BREAKING THE CAP.

TO INSTALL A BEARING, HEAT THE BEARING IN AN OVEN AT 250°F. THIS WILL EXPAND THE INNER RACE, ALLOWING IT TO SLIP OVER THE BEARING SEAT. ALL BEARINGS MUST BE REPLACED WITH THE IDENTICAL PART USED BY RELIANCE. IN MANY CASES SPECIAL BEARINGS ARE USED WHICH CANNOT BE IDENTIFIED BY MARKINGS ON BEARING. THE MAJORITY OF BEARINGS USED NOW HAVE A C3 INTERNAL LOOSENESS.

REASSEMBLY

Follow reverse procedure as outlined for Disassembly. Having marked the brackets in the original position, replace as marked.

LUBRICATION OF ANTI-FRICTION BEARINGS

This motor has been properly lubricated at the time of manufacture and it is not necessary to lubricate at time of installation. When the motor has been in storage for a period of six months or more, lubricate before starting.

Lubrication of anti-friction bearings should be done as a part of a planned maintenance schedule. The Recommended Lubrication Interval should be used as a guide to establish this schedule.

Cleanliness is important in lubrication. Any grease used to lubricate anti-friction bearings should be fresh and free from contamination. Similarly, care should be taken to properly clean the grease inlet area of the motor to prevent grease contamination.

RECOMMENDED LUBRICANT

For motors operating in ambient temperatures shown below, use the following lubricant or its equal:

OPERATING TEMP. —25°C (—150°F) to 50°C (120°F)

CHEVRON OIL SRI NO. 2
 SHELL OIL CO. DOLIUM R
 TEXACO INC. PREMIUM RB

MINIMUM STARTING TEMPERATURE —75°C (—100°F)

SHELL OIL CO. AEROSHELL #7

WARNING:

Mixing lubricants is not recommended due to possible incompatibility. If it is desired to change lubricant, follow instructions for lubrication and repeat lubrication a second time after 100 hours of service. Care must be taken to look for signs of lubricant incompatibility, such as extreme soupiness visible from the grease relief area.

LUBRICATION FREQUENCY

Standard Conditions:	Eight hours per day, normal or light loading, clean, @ 40°C (100°F) maximum ambient.
Severe Conditions:	Twenty-four hour per day operation or shock loading, vibration, or in dirt or dust @ 40-50°C (100-120°F) ambient
Extreme Conditions:	Heavy shock or vibration, or dust.

ROLLER BEARINGS

For Roller Bearings divide the time periods by 2.

BALL BEARINGS

Horsepower	Standard Conditions	Severe Conditions	Extreme Conditions
1 thru 7½ 1800 RPM and slower	3 Years	1 Year	6 Months
10 thru 75 1800 RPM and slower	2 Years	6 to 12 mos.	3 Months
100 and greater 1800 RPM and slower	1 Year	6 Months	1 to 3 Months
All over 1800 RPM	6 Months	3 Months	1 Month

LUBRICATION PROCEDURE


Reliance anti-friction bearings may be lubricated with the motor running or stationary. Stationary with the motor warm is preferred.

1. Locate the grease inlet, clean the area and replace the pipe plug with a grease fitting, if the motor is not equipped with grease fittings.
2. Add the Recommended Volume of the Recommended Lubricant using a hand operated grease gun.
3. Run the motor for two hours.
4. Replace the pipe plug in grease inlet.

RECOMMENDED VOLUME

Frame Size	Standard Conditions	Severe Conditions	Extreme Conditions
182 thru 215	1.0 Cu. In.	0.75 Cu. In.	0.5 Cu. In.
254 thru 286	2.0 Cu. In.	1.5 Cu. In.	1.0 Cu. In.
324 thru 365	3.0 Cu. In.	2.0 Cu. In.	1.5 Cu. In.
404 thru 449	4.0 Cu. In.	3.0 Cu. In.	2.0 Cu. In.

PLS CONSTRUCTION PROVIDES LONG LIFE FOR BEARINGS AND MOTOR



Cooler Bearing Operating Temperatures — Open bearing (non-shielded) construction (1) minimizes friction, allowing cooler bearing operation.

Positive Lubrication/Relubrication in any Mounting Position — Exclusive grease channeling window (2), with minimum grease path entry (3), channels grease directly into bearing track and avoids premature relief out shaft bore or drain plug.

Minimizes Corrosion — Small clearance on either side of grease window uniformly distributes grease to both inboard and outboard reservoirs (4) to protect bearing surfaces

during motor storage, long idle times and start-up. Bearing system is completely greased during motor assembly.

Restricts Inboard Contaminants — Inner bearing cap (5) with anti-churning vanes (6) and close running shaft tolerance (7) minimizes contaminant entry into bearings, and grease migration into motor.


Prohibits Overgreasing During Lubrication/Relubrication — Grease relief port (8) accurately indicates completion of lubrication/relubrication. (If port is plugged during lubrication, PLS design will relieve grease along the shaft (9)).

REPLACEMENT BEARINGS

Your maintenance program will not be complete without including spare bearings. It must be remembered that the bearing is a wearable component and therefore must eventually be replaced. To insure that you are able to maintain original operation, we recommend the purchase of spares directly from Reliance.

All bearings used in Reliance motors are subject to exact specifications and tests necessary to satisfy performance requirements. In this manner, it is possible to duplicate your present bearing. Markings on the bearing do not indicate complete specifications.

PARTS IDENTIFICATION DRAWING



FIND NO.	PART DESCRIPTION
1	FRAME
2	STATOR
3	ROTOR
4	BACKEND BRACKET
5	FRONTEND BRACKET
6	SHAFT
7	BACKEND BALL BEARING
8	BACKEND INNER CAP
9	FRONTEND BALL BEARING
10	FRONTEND INNER CAP
11	WAVE WASHER, FRONTEND
12	FAN COVER
13	OUTER FAN

FIND NO.	PART DESCRIPTION
14	FRONT END BRACKET BOLTS
15	FAN COVER BOLTS
16	EYEBOLT
17	CONDUIT BOX
18	FAN CLAMP
19	GREASE ENTRY
20	CONDENSATION DRAIN
21	KEY
22	SLINGER
23	BACKEND CAP BOLTS

**Sludge Pond Study, Gibbons Creek Steam Electric Station,
Grimes County, Texas,
Job No. D-76602-52, NFS/National Soil Services, Inc.
October 21, 1983.**

NFS SERVICES, INC.
CONSULTING ENGINEERS

P.O. BOX 24596
DALLAS, TEXAS 75224
4087 SHILLING WAY
214-330-9211 (Office) 214-330-8953 (Telecopy)

(Formerly National Soil Services)

October 21, 1983
Job No. D-76602-52

Texas Municipal Power Agency
P. O. Box 7000
Bryan, Texas 77805

Attention: Mr. John Turlak

REC'D TMPA

OCT 21 1983

AM 7 8 9 10 11 12 1 2 3 4 5 6 PM

SLUDGE POND STUDY
GIBBONS CREEK STEAM ELECTRIC STATION
GRIMES COUNTY, TEXAS

Gentlemen:

This letter presents the results of our detailed evaluation of the requirements for slurry wall containment of the above-noted pond. Our initial cost estimates and recommendations, as related to both a slurry wall and an artificial liner, were submitted in our September 16, 1983 letter.

Field and Laboratory Investigations

Subsurface exploration along the proposed slurry wall alignment consisted of seven undisturbed sample borings drilled at 200 to 250-foot intervals to a depth of 50 feet. Continuous samples were obtained in the upper 30 feet. The borings were drilled by Soil Mechanics Incorporated during the period September 27-29, 1983.

The soil samples were reviewed by Mr. Darryl Carlson, Senior Geologist for NFS Services, Inc. Samples were classified visually by Mr. Carlson with notations made as to degree of fissuring and moisture conditions. Fracture surfaces were tested with litmus paper to determine pH. Additionally, pH determinations were made in the laboratory by Soil Mechanics Incorporated to provide data regarding the natural pH of the soils. In general, the pH testing proved to be inconclusive with respect to tracking movements of contaminants.

Geologic Assessment

A boring plan (Plate 1) and a soil profile (Plate 2) are attached to this letter. As indicated on Plate 2, the fill portion of the dike embankment, ranging from about one foot to 12 feet, is made up of clays and sandy clays.

A Recent/Pleistocene-aged terrace deposit is present beneath the fill and overlies the Eocene-aged Jackson Group. Soils in the former deposit consist of sandy clay and clayey sand with gravel. Thickness of the deposit ranges from a minimum of four feet at boring location SDP-2 to a maximum of approximately 15 feet at boring location SDP-5. The contact with the underlying Jackson Group is an undulating surface.

Soils of the Eocene-aged Jackson Group underlie the Recent/Pleistocene terrace deposit and are present to below completion depths of the borings. Grade on the undulating upper surface ranges from Elev 261 to Elev 270. Soil types consist of clay, sandy clay, silty clay, clayey silt, clayey sand, silty sand, lignite and occasional thin seams of sandstone.

Clays, sandy clays and lignites in the Jackson Group are extensively fractured throughout the depths penetrated by the borings. Free moisture was observed on some fracture surfaces in the lignite stratum. Fracture surfaces within the upper 20 feet are all generally stained by iron oxide which has been deposited from groundwater. The area of staining represents a zone of water table fluctuation.

Apparent dip of strata in the Jackson Group is on the order of 260 feet per mile in a southwesterly direction, and is based on correlation of the persistent lignite stratum shown on Plate 2. Clays are generally present above the lignite except in the vicinity of boring SDP-7. At this location, approximately 25 feet of clayey sand and silty sand overlie the lignite.

Seepage Conditions

Approximate grade of the pond bottom (Elev 260) is shown on Plate 2 by a dashed line. Soils present along the dike slopes and in the bottom of the pond consist of clay fill, Recent/Pleistocene-aged sandy clay and clayey sand and Eocene-aged clay, sandy clay, and clayey sand.

Soils with the greatest potential for seepage would be clayey sands in the Recent/Pleistocene-aged deposit and the fractured clays in the Eocene aged-Jackson Group. Based on the available subsurface data and visual observations, the seepage has a nearly horizontal flow pattern through the lower part of the dike in the Recent/Pleistocene and Eocene formations. Seepage from the pond bottom is not considered a problem inasmuch as the reworked and recompacted clay bottom has been protected by accumulated surface water runoff during the approximate four-year interval between the pond completion and commencement of operation.

As outlined in our September 16, 1983 letter, the two available methods for providing containment of the pond are the installation of an artificial liner and construction of a slurry wall. Findings from this detailed evaluation of the requirements for slurry wall construction indicate the general absence of an identifiable, continuous aquitard into which the slurry wall may be tied. Nonetheless, it is our judgment that a 40-foot-deep slurry wall installed along the top of the dike would effectively contain the pond by elimination of the present horizontal flow pattern and by creation of vertical flow gradients in the foundation clay strata. Based on our findings, the slurry wall should be constructed around the entire perimeter of the pond.

Updated Cost Estimates

As reported in our September 16, 1983 letter, the cost of an artificial liner is estimated to range from \$246,000 to \$283,000, depending upon the type of liner material installed and exclusive of the costs of dewatering the pond, removing accumulated sludges, and placing a protective soil cover over the installed liner.

The revised cost estimate for a 40-foot-deep slurry wall around the pond perimeter is \$310,000, based on perimeter distance of 2,500 feet and the use of bottom ash for backfilling the trenches. The bottom ash backfill was initially suggested by Mr. Pradeep Tipnis of TMPA. Results of a sieve analysis performed on a representative sample of bottom ash in our on-site laboratory showed 90 percent passing the one-half-inch sieve and 4.6 percent passing the No. 200 sieve. While this gradation is somewhat coarse for use as slurry trench backfill, the bottom ash is brittle and could be broken down to produce additional fines through movement of a tracked construction vehicle prior to placement in the trench.

Conclusions and Recommendations

Based on the findings from this study, the estimated cost for the slurry wall construction is \$310,000 as compared to the range of \$246,000 to 283,000 estimated for installation of an artificial liner. Assuming that costs associated with transferring the contents of the sludge pond to another pond, removing accumulated sludges from the pond bottom and placing any desired soil cover over the artificial liner (Note: part or all of this work may be accomplished by plant personnel and it is assumed that these costs will be determined by TMPA) do not exceed the cost difference between above-stated estimated costs for the slurry wall and artificial liner, we recommend that an artificial liner be used to provide containment of the sludge pond.

Texas Municipal Power Agency
Attention: Mt. John Turlak

4.


October 21, 1983
Job No. D-76602-52

In our judgment, the composite 36-mil Hypalon/30-mil PVC liner, which is normally less expensive than an all Hypalon liner and is estimated to have an installed cost of \$246,000, will be satisfactory for this installation. We will be pleased to furnish you with any additional data that you may request regarding liner material, installation procedures, etc.

Please call us if there are any questions or if we may be of additional assistance.

Very truly yours,

NFS SERVICES, INC.



Gary G. LaFrance, P. E.
Manager of Engineering


GGL/lcr
Encl.

cc: Tippett & Gee, Inc.
Attention: Mr. Larry Webb, P. E.

PLANT P.R.#2

Approx. NORTH

Note: Adjust boring locations in field to avoid sluice pipes



REC HOPPER
 @ 83 887 285
 N 360 550 ON
 AN AZIMUTH
 OF 8 21° 30' W
 TOP @ EL 282.0

PLATE

CHAIN RIP RAP

STORAGE

CONVEYOR

PRIMARY BREAKER

CONVEYOR

C-22

DELETE CONVEYOR C-22

SDP-2

SDP-3

SDP-4

SDP-5

SDP-1

SDP-6

SDP-7

255'

255'

255'

250'

250'

200'

200'

4

3

1

16

265.01

270

260

270

270

280

260

270

260

270

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

260

270

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

280

NORTH SIDE

EAST SIDE

SOUTH SIDE

SDP-1

SDP-2


SDP-3

SDP-4


SDP-5

SDP-6

SDP-7



3.9 pH of Soil Sample determined in Lab



Scale: 1" = 100' Hor
1" = 10' Vert

SLUDGE POND
GENERALIZED SOILS
CONDITIONS



NFS SERVICES, INC.
CONSULTING ENGINEERS

Jim Shultz

P.O. BOX 24596
DALLAS, TEXAS 75224
4087 SHILLING WAY
214-330-9211 (Office) 214-330-8953 (Telecopy)

(Formerly National Soil Services)

September 16, 1983
Job No. D-76602-52

Texas Municipal Power Agency
P. O. Box 7000
Bryan, Texas 77805

Attention: Mr. John Turlak

REC'D TMPA

SEP 20 1983

AM 7 8 9 10 11 12 1 2 3 4 5 6 PM

SLUDGE POND STUDY
GIBBONS CREEK STEAM ELECTRIC STATION
GRIMES COUNTY, TEXAS

Gentlemen:

This letter will provide confirmation of the cost estimates and recommendations presented to you on September 12, 1983 via the telephone conference call between Messrs. John Turlak of TMPA, Larry Webb of Tippett & Gee, and Gary LaFrance of NFS Services, Inc. These cost estimates and recommendations pertain to remedial work required for containment of the existing sludge pond. A preliminary assessment of the pond leakage was made at the September 6, 1983 meeting held at the plant site. At that time, it was concurred that NFS and T & G would jointly develop cost estimates and recommendations for alternate containment methods using an artificial liner and a slurry wall.

Cost estimates for installation of an artificial liner and a slurry wall are presented as follows:

A. Artificial Liner

1. Assumptions

- a.) The liner will be required over the entire pond area (total area of bottom and slopes is about 350,000 square feet).

- b.) The liner installation will require pumping the contents of the pond to a nearby ash pond, removing and disposing of accumulated sludge solids in the bottom of the pond, stripping sludge-contaminated soils, backfilling irregularities over the pond bottom, scarifying and sterilizing the subgrade, and installing a gas vent system. This cost estimate does not include provisions for pumping and removing sludge nor for the cost of any protective soil cover that may be required for cleaning out the pond at a later date.
- c.) Two liner types were evaluated:
(1) 36-mil Hypalon; and (2) a composite liner consisting of 36-mil Hypalon on the slopes and 30-mil PVC over the bottom area. Based on recent experience, material costs are estimated to be \$0.55 per square foot for the Hypalon and \$0.35 per square foot for the PVC. Installation costs for either the 36-mil all Hypalon liner or the composite Hypalon/PVC liner is estimated to be \$0.10 per square foot.

2. Estimated Total Cost for 36-Mil Hypalon Liner

a.) Subgrade Preparation (includes stripping, backfilling, scarifying and sterilizing, and installing gas vents)	\$ 58,000.00
b.) Material Cost (36-Mil Hypalon)	190,000.00
c.) Installation Cost	<u>35,000.00</u>
Estimated Total Cost	\$ 283,000.00

3. Estimated Total Cost of Composite 36-Mil Hypalon and 30-Mil PVC Liner

a.) Subgrade Preparation	\$ 58,000.00
--------------------------	--------------

b.) Material Cost

36-Mil Hypalon	86,000.00
30-Mil PVC	67,000.00

c.) Installation Cost	<u>35,000.00</u>
-----------------------	------------------

Estimated Total Cost \$ 246,000.00

156,360.00
191,428.00
547,700.00
350,000.00

B. Slurry Wall

1. Assumptions

- a.) The slurry wall will extend around three sides of the pond with an estimated total length of 1,300 lineal feet. Required depth of the slurry wall is expected to range from 30 to 40 feet. Average thickness of the slurry wall is estimated to be 2.5 feet. Estimated unit cost for slurry wall construction is \$3.00 per square foot.
- b.) Sand backfill will be required for the trenches. In-place cost of the sand is estimated to be \$3.75 per cubic yard.
- c.) A geotechnical investigation, consisting of about seven 50-foot-deep borings, laboratory soil tests and engineering analyses will be required and can be expected to cost about \$10,000.00. A similar study will not be needed for the artificial liner alternate. The cost of the geotechnical investigation has not been included in the cost estimate for the slurry wall construction.

2. Estimated Total Cost for 40-Foot-Deep Slurry Wall

a.) Basic Slurry Wall Construction	\$ 156,000.00
b.) Sand Backfill	19,000.00
c.) Reshape and Revegetate Slopes	<u>5,000.00</u>

Estimated Total Cost \$ 180,000.00

Texas Municipal Power Agency
Attention: Mr. John Turlak

4.

September 16, 1983
Job No. D-76602-52

3. Estimated Total Cost for 30-Foot-Deep Slurry Wall

a.) Basic Slurry Wall Construction	\$ 117,000.00
b.) Sand Backfill	14,000.00
c.) Reshape and Revegetate Slopes	<u>5,000.00</u>

Estimated Total Cost \$ 136,000.00

With respect to the slurry wall construction, Mr. Larry Webb noted that the contractor may prefer to remove and then later replace the upper one to two feet of the top of the dike in order to increase the width of the work area from the present 20 feet to about 30 feet. If this is not done, the more restricted work space may result in an increase in unit cost of slurry wall construction from about \$3.00 per square foot to \$4.00 per square foot.

Based on the foregoing construction cost estimates, it is apparent that an artificial liner, whether all Hypalon or a composite liner of 36-mil Hypalon and 30-mil PVC, should be considerably more expensive than construction of a slurry wall for containment of the sludge pond. It is recommended that the sludge pond study proceed by obtaining the necessary subsurface exploration to permit detailed evaluation of the requirements for the slurry wall construction. Enclosed with this letter are Plates 1 and 2 which present a recommended plan of borings and a listing of subsurface data needed from the borings.

Please call us if there are any questions.

Very truly yours,

NFS SERVICES, INC.



Gary G. LaFrance, P. E.
Manager of Engineering


GGL/sf
Encl.

cc: Tippet & Gee, Inc.
Attention: Mr. Larry Webb, P. E.

PLANT R.R.#2

Approx. NORTH

Note: Adjust boring locations in field to avoid sluice pipes.



116 REC HOPPER
 @ 89 857 285
 N 369 530 ON
 AN AZIMUTH
 OF 8 21° 30' W
 TOP @ EL 282.0

STORM

CONVEYORS

PRIMARY BREAKER

PLATE

CONVEYORS

CHAIN-

RIP RAP

16

C-22

DELETE
CULVERT
C-22

4

3

1

SLUDGE POND STUDY

GIBBONS CR. SES

1. Drill seven borings, SDP-1 thru SDP-7, to a depth of 50 feet.
2. Take continuous 3" diameter Shelby tube or Pitcher barrel samples in upper 30 feet. Take Shelby tube or Pitcher barrel samples @ 5' intervals below a depth of 30 feet.
3. A soils engineer or geologist should log all samples in the field and should be present at the drill rig during the drilling and sampling work.
4. In addition to the usual data appearing on a boring log, the soils engineer or geologist should record details concerning loss of drill water, in-situ fissures in clay (depth and orientation, stained surfaces, etc.), and depth and thickness of sand seams.
5. Preserve representative undisturbed samples from each sampling interval in a waxed container. Also, obtain a pint-sized jar sample from the same sampling interval.
6. Grout completed boreholes with a cement-bentonite grout mixture.

SOIL MECHANICS INCORPORATED

FOUNDATION EXPLORATION AND TESTING SERVICES

206 NORTH SIMS • P. O. BOX 672 • BRYAN, TEXAS • 77806-0672

John Turtak

Jim Skaults

TELEPHONE (409) 822-8810 / 822-3767

LETTER OF TRANSMITTAL

TO: Texas Municipal Power Agency
Attn: Mr. Pradeep Tipnis
P.O. Box 7000
Bryan, TX 77805

REC'D TMPA

OCT 5 1983

AM 7 8 9 10 11 12 1 2 3 4 5 6 PM

A

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas SMI PROJECT NO. 283-202

We are sending you 2 copies of the following:

Pages	Dated	Item	Pages	Dated	Item
		Concrete Compressive Strength			Summary of Laboratory Test Data
		Concrete Batch Plant Report	6	9-27-83	Boring Logs
		Concrete Field Report	8	9-28-83	Boring Logs
		In-place Density Test Report	1	9-30-83	Boring Log
		Mechanical Analysis	3		Boring Logs - Monitor Wells
		Optimum Moisture/Density Relationship	1		Monitor Well Location Sketch

Signed: *Ligh Ann Capps*
Ligh Ann Capps

Date: October 3, 1983

REMARKS:

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas

BORING NO: SDP-1
 LOCATION: As directed by Client
 BORING TYPE: 4 1/2" Rotary
 GROUND ELEV: 280'±

CLIENT: TEXAS MUNICIPAL POWER AGENCY
 DATE: 9-27-83 PROJECT NO: 283-202
 DRILLER: Anderson SOIL TECHNICIAN: Huff

Depth in Feet	Sample Type & No.	Penetrometer Reading, 1st	Blows / Foot	Legend				
				<input type="checkbox"/> - Shelby Tube Sample	<input checked="" type="checkbox"/> - Standard Penetration Test Sample	<input checked="" type="checkbox"/> - No Recovery	J-Jar	
DESCRIPTION OF STRATUM								
	2468			Topsoil, tan silty fine sand with roots				2'
	2469	4+		Hard tan and gray clay, fill				
5	2470	4+		Hard tan and gray clay with red clay streaks, fill				
	2471	4+		Hard tan clay				
	2472	4+		Hard brown clay to 8'2"				
10	2472	2.75		Very stiff gray sandy clay with gravel and sand pockets				
	2473	2.0		Stiff to very stiff tan sandy clay with gravel and sand pockets				
	2474	1.75		Stiff tan and gray sandy clay				
15	2475	4.0		Hard gray sandy clay with tan clay layer at 15.75'				16'
	2476	3.5		Very stiff brown clay with lignite seams, laminated and jointed				
	2476	2.5		Very stiff brown silty clay with organic clay layer and cemented sand nodules				20'
20	2477	2.5						
	2478	4+		Hard tan silty clay				
	2479	4+		Hard gray clay with iron stains and sand pockets				
25	2480	4+		Hard gray clay with iron stains, laminated and jointed				
	2481	4+		Hard gray clay with iron stains, laminated and jointed				
	2482	4+		Hard gray silty clay with iron stains and gypsum seams				
30								
	2483	4+		Hard gray clay with gypsum seam at 33'3", laminated and jointed				37'±
35								
	2484	2.0		Stiff gray sandy clay-clayey sand				42'±
40								
	2485	2.0		Alternating layers of gray sandy clay and clayey sand				
45								

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas

BORING NO: SDP-1
 LOCATION: As directed by Client
 BORING TYPE: 4 1/2" Rotary
 GROUND ELEV: 280'±

CLIENT: TEXAS MUNICIPAL POWER AGENCY
 DATE: 9-27-83 PROJECT NO: 283-202
 DRILLER: Anderson SOIL TECHNICIAN: Huff

Depth in Feet	Sample Type & Sample No.	Penetrometer Reading, tsf	Blows / Foot	DESCRIPTION OF STRATUM
				<input type="checkbox"/> - Shelby Tube Sample <input checked="" type="checkbox"/> - Standard Penetration Test Sample <input type="checkbox"/> - No Recovery J-Jar
				DESCRIPTION OF STRATUM
				Alternating layers of gray sandy clay and clayey sand 47.5'
50	X 2486		58	Very dense gray sand <div style="text-align: center;"> <hr style="width: 20%; margin: 0 auto;"/> Bottom at 50' </div>
55				
60				
65				
				Boring filled with cement-bentonite grout upon completion of drilling.

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge
Disposal Pond, Carlos, Texas

BORING NO: SDP-2

LOCATION: As directed by
Client

CLIENT: TEXAS MUNICIPAL POWER AGENCY

BORING TYPE: 4 1/2" Rotary

DATE: 9-27-83

PROJECT NO: 283-202

GROUND ELEV: 280'±

DRILLER: Anderson

SOIL TECHNICIAN: Huff

Depth in Feet	Sample Type & Sample No.	Penetrometer Reading, tsf	Blows / Foot	<input type="checkbox"/> - Shelby Tube Sample <input checked="" type="checkbox"/> - Standard Penetration Test Sample <input type="checkbox"/> - No Recovery J-Jar			
				DESCRIPTION OF STRATUM			
	2448					Topsoil, tan silty fine sand with roots	2'
	2449	4+				Hard tan and gray clay with sand streaks, fill	
5	2450	4+				Hard tan and gray clay and sandy clay with sand streaks, fill	
	2451	4+				Hard gray clay with sand and clay pockets, fill	
	2452	2.25				Very stiff red and gray sandy clay with tan sand pockets	
10	2453	2.75 4+				Very stiff to hard red and gray sandy clay	
	2454	4+				Hard gray sandy clay, jointed	
15	2455	4+				Hard gray clay	15.5'
	2456	2.0				Brown lignitic clay, jointed Very stiff brown clay with trace of lignite, laminated and jointed	
	2457	3.0				Very stiff reddish brown silty clay, laminated and jointed	
20	2458	4+				Hard reddish brown silty clay with iron ore layer at 21'10"	
	2459	4+				Hard brown clay	22'7"
	2460	4+				Hard black lignite	
25	2461	4+				Hard black lignite	25'
	2462	4+				Hard gray silty clay, laminated	
	2463	4+				Hard gray silty clay, laminated	
30							
	2464	4+				Hard gray sandy clay with 2" sandstone layer at 33', laminated	
35							
	2465	4+				Cemented sand seam at 38' Hard gray clay with cemented sand seams	38.75'
40						Sand	40.5'
	2466	4+				Hard gray sandy clay with trace of lignite	
45							

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas

BORING NO: SDP-2
 LOCATION: As directed by Client

CLIENT: TEXAS MUNICIPAL POWER AGENCY

DATE: 9-27-83

PROJECT NO: 283-202

BORING TYPE: 4 1/2" Rotary

DRILLER: Anderson

SOIL TECHNICIAN: Huff

GROUND ELEV: 280'±

Depth in Feet	Sample Type & Sample No.	Penetrometer Reading, 'sf	Blows / Foot	DESCRIPTION OF STRATUM
				47.5'
50	X 2467		50 8"	Very dense gray sand <div style="text-align: center;"> <hr style="width: 20%; margin: 0 auto;"/> Bottom at 50' </div>
55				
60				
65				
				Boring filled with cement-bentonite grout upon completion of drilling

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas

BORING NO: SDP-3
 LOCATION: As directed by Client
 BORING TYPE: 4 1/2" Rotary
 GROUND ELEV: 280'±

CLIENT: TEXAS MUNICIPAL POWER AGENCY
 DATE: 9-27-83
 PROJECT NO: 283-202
 DRILLER: Anderson
 SOIL TECHNICIAN: Huff

Depth in Feet	Sample Type & No.	Penetrometer Reading, tsf	Blows / Foot	Legend				DESCRIPTION OF STRATUM
				<input type="checkbox"/> - Shelby Tube Sample	<input checked="" type="checkbox"/> - Standard Penetration Test Sample	<input checked="" type="checkbox"/> - No Recovery	J-Jar	
	2487							Topsoil, tan silty fine sand with roots 2'
	2488	4+						Hard gray clay with tan clay streaks and calcareous nodules
5	2489	4+						Hard tan and gray sandy clay with sand pockets and gravel, fill
	2490	4+						Hard tan and gray sandy clay with trace of gravel
	2491	4+						Hard tan and gray sandy clay with occasional sand pockets and gravel
10	2492	4+						Hard tan and gray sandy clay with organic material, jointed
	2493	4+						Hard tan clay with organic material at 11'8", jointed Hard tan clay with iron stains and lignite streaks, laminated and jointed 14'
15	2494	2.0 4+						Stiff to hard brown silty clay with trace of lignite, laminated and jointed
	2495	1.5 4+						Stiff brown silty clay with trace of lignite 17' Hard tan clay
	2496	4+						Hard tan clay with iron ore seams, jointed 20'
20	2497	2.5 4+						Stiff brown lignitic clay, laminated and jointed 21' Hard tan clay with iron ore seams, laminated and jointed 22'
	2498	4+						Hard brown lignitic clay, laminated and jointed
	2499	3.5 4+						Very stiff dark brown lignitic clay at 23', laminated, jointed Hard brown lignitic clay, laminated and jointed
25	2500	4+						Hard brown lignitic clay, laminated and jointed 28'
	2501	4+						Hard black lignite
30								Gray sandy clay 32'
	2502	4+						Hard gray sandy clay
35								
	2503	4+						Hard gray sandy clay, laminated
40								
	2504	2.0						Cemented sand seam at 43' Stiff gray sandy clay with sand pockets and cemented sand nodules
45								

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas

BORING NO: SDP-3
 LOCATION: As directed by Client

CLIENT: TEXAS MUNICIPAL POWER AGENCY
 DATE: 9-27-83

PROJECT NO: 283-202

BORING TYPE: 4 1/2" Rotary
 GROUND ELEV: 280'±

DRILLER: Anderson

SOIL TECHNICIAN: Dean

Depth in Feet	Sample Type & Sample No.	Penetrometer Reading, tsf	Blows / Foot	<input type="checkbox"/> - Shelby Tube Sample <input checked="" type="checkbox"/> - Standard Penetration Test Sample <input checked="" type="checkbox"/> - No Recovery J-Jar	DESCRIPTION OF STRATUM
50	2505	4+			Hard gray sandy clay <hr style="width: 50%; margin: 0 auto;"/> Bottom at 50'
55					
60					
65					
					Boring filled with cement-bentonite grout upon completion of drilling

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas

BORING NO: SDP-4
 LOCATION: As directed by Client
 BORING TYPE: 4 1/2" Rotary
 GROUND ELEV: 280'±

CLIENT: TEXAS MUNICIPAL POWER AGENCY
 DATE: 9-28-83 PROJECT NO: 283-202
 DRILLER: Anderson SOIL TECHNICIAN: Huff

Depth in Feet	Sample Type & Sample No.	Penetrometer Reading, ftsf	Blows / Foot	<input type="checkbox"/> - Shelby Tube Sample <input checked="" type="checkbox"/> - Standard Penetration Test Sample <input type="checkbox"/> - No Recovery J-Jar			
				DESCRIPTION OF STRATUM			
	2506	3.0		Topsoil, tan silty fine sand _____ 10"			
				Very stiff tan clay			
	2507	4.0		Hard tan sandy clay with trace of lignite and gravel, fill			
5	2508	2.0		Stiff tan and gray sandy clay with gravel and 1" sand layer at 5'			
	2509	4+		Hard red and gray sandy clay			
	2510	2.5		Very stiff tan and gray sandy clay with clayey sand pockets			
10	2511	2.0		Very stiff tan and gray sandy clay with clayey sand pockets and trace of organic			
	2512	2.5		Very stiff tan and gray sandy clay with gravel, cemented sand nodules and tan sand pockets			
15	2513	2.5		Very stiff tan and gray sandy clay			
		4+		Hard tan clay with sand nodules at 15'			
	2514	4+		Hard tan clay with iron stains _____ 17'10"			
				Hard brown clay			
20	2515	2.5		Very stiff brown clay			
		4+		Hard brown lignitic clay at 19', laminated and jointed _____ 20'			
	2516	4+		Hard tan clay with iron stain streaks, jointed			
	2517	4+		Hard tan clay with iron stain streaks, jointed			
25	2518	4+		Hard tan clay with iron stain streaks, jointed _____ 25'8"			
				Hard brown lignitic clay, jointed			
	2519	4+		Alternating 4-in. layers of brown lignitic clay and tan clay with iron stains, jointed			
	2520	4+		Hard tan clay			
30				Hard brown lignitic clay at 28.5', laminated and jointed			
	2521	4+		Hard brown lignitic clay, laminated and jointed _____ 35'			
35				Lignite _____ 38'			
40	2522	4+		Hard gray silty clay with trace of lignite			
45	2523	4+		Hard gray sandy clay with cemented sand seams			

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas

BORING NO: SDP-4
 LOCATION: As directed by Client
 BORING TYPE: 4 1/2" Rotary
 GROUND ELEV: 280'±

CLIENT: TEXAS MUNICIPAL POWER AGENCY
 DATE: 9-28-83
 DRILLER: Anderson
 PROJECT NO: 283-202
 SOIL TECHNICIAN: Huff

Depth in Feet	Sample Type & Sample No.	Penetrometer Reading, r/sf	Blows / Foot	<input type="checkbox"/> - Shelby Tube Sample <input checked="" type="checkbox"/> - Standard Penetration Test Sample <input type="checkbox"/> - No Recovery J-Jar		
				DESCRIPTION OF STRATUM		
50	2524	4+		Hard gray sandy clay _____ Bottom at 50'		
55						
60						
65						
				Boring filled with cement-bentonite grout upon completion of drilling		

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge
Disposal Pond, Carlos, Texas

BORING NO: SDP-5
LOCATION: As directed by
Client
BORING TYPE: 4 1/2" Rotary
GROUND ELEV: 280'±

CLIENT: TEXAS MUNICIPAL POWER AGENCY

DATE: 9-28-83

PROJECT NO: 283-202

DRILLER: Anderson

SOIL TECHNICIAN: Huff

Depth in Feet	Sample Type & No.	Penetrometer Reading, fsf	Blows / Foot	<input type="checkbox"/> - Shelby Tube Sample <input checked="" type="checkbox"/> - Standard Penetration Test Sample <input checked="" type="checkbox"/> - No Recovery J-Jar			
				DESCRIPTION OF STRATUM			
	2525			<u>Topsoil, tan silty fine sand</u> _____ <u>1"</u> Tan, red and gray sandy clay with sand nodules and pockets			
	2526	3.5		Very stiff tan and gray sandy clay with cemented sand pockets <u>4'±</u>			
5	2527			Sandstone layers _____ <u>6'±</u>			
	2528	2.5		Very stiff tan and gray sandy clay with sand nodules			
	2529	1.0		Plastic tan, red and gray sandy clay			
10	2530	2.5		Very stiff gray sandy clay			
	2531	3.75		Very stiff gray sandy clay with sand nodules and decayed organic material			
15	2532	3.0 4+		Very stiff gray sandy clay with sand nodules Hard tan sandy clay with iron stains at 15'			
	2533	4+		Hard tan and gray clay with iron nodules and streaks, jointed			
	2534	4+		Hard tan and gray clay with iron nodules and streaks, laminated and jointed			
20	2535	4+		Hard tan sandy clay with iron stains			
	2536	4+		<u>Hard tan clay, laminated and jointed</u> _____ <u>23.5'</u> <u>Hard brown clay, laminated and jointed</u> _____ <u>24'</u>			
25	2537	4+		Hard black lignite, laminated and jointed			
	2538	4+		Hard black lignite, laminated and jointed			
30	2539	4+		<u>Hard black lignite, laminated and jointed</u> _____ <u>29.5'</u> Clay			
	2540	4+		Hard green clay, jointed _____ <u>37'±</u>			
40	2541	4+		<u>Hard black lignite, laminated and jointed</u> _____ <u>39.5'±</u>			
45	2542	4+		Hard gray silty clay, laminated and jointed			

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas

BORING NO: SDP-5
 LOCATION: As directed by Client
 BORING TYPE: 4 1/2" Rotary
 GROUND ELEV: 280'±

CLIENT: TEXAS MUNICIPAL POWER AGENCY
 DATE: 9-28-83 PROJECT NO: 283-202
 DRILLER: Anderson SOIL TECHNICIAN: Huff

Depth in Feet	Sample Type & Sample No.	Penetrometer Reading, tsf	Blows / Foot	<input type="checkbox"/> - Shelby Tube Sample <input checked="" type="checkbox"/> - Standard Penetration Test Sample <input type="checkbox"/> - No Recovery J-Jar	DESCRIPTION OF STRATUM
					Lignite from 48 to 49' 49'
50					Sandstone layer <div style="text-align: center; margin-top: 10px;"> <hr style="width: 50%; margin: 0 auto;"/> Bottom at 50' </div>
55					
60					
65					
					Boring filled with cement-bentonite grout upon completion of drilling

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas

BORING NO: SDP-6
 LOCATION: As directed by Client
 BORING TYPE: 4 1/2" Rotary
 GROUND ELEV: 280'±

CLIENT: TEXAS MUNICIPAL POWER AGENCY
 DATE: 9-28-83 PROJECT NO: 283-202
 DRILLER: Anderson SOIL TECHNICIAN: Huff

Depth in Feet	Sample Type & Sample No.	Penetrometer Reading, f/sf	Blows / Foot	Legend				DESCRIPTION OF STRATUM
				■ - Shelby Tube Sample	☒ - Standard Penetration Test Sample	☑ - No Recovery	J-Jar	
	2544	4+						Topsoil, tan silty fine sand _____ 4"
								Hard tan sandy clay
	2545	2.5						Very stiff tan sandy clay with sand pockets and iron stains
5	2546	2.5						Very stiff tan sandy clay with sand pockets and iron stains
	2547	3.75						Very stiff tan sandy clay to clay
	2548	2.5						Very stiff tan sandy clay to clay
10	2549	1.5						Tan and red sandy clay with gravel and sand pockets at 9'
		4+						Stiff tan and red sandy clay with gravel and sand pockets
	2550	4+						Hard gray clay with iron ore pockets, jointed at 10'8"
	2551	4+						Hard tan and gray clay with iron stains, jointed
15	2552	4+						Hard tan clay with iron stains and decayed vegetation, jointed
	2553	4+						Hard tan clay with iron stains and decayed vegetation, jointed 18'
	2554	4+						Alternating 5-in. layers of brown lignitic clay, laminated and jointed and brown sandy clay
20	2555	4+						Hard brown lignitic clay, laminated and jointed _____ 20.5'
	2556	4+						Hard tan clay, jointed
	2557	4+						Hard tan clay, jointed
	2558	4+						Hard gray clay with small sand seams, jointed at 22.5'
25	2559	4+						Hard gray clay with yellow seams, jointed
	2560	4+						Hard gray clay, jointed with 3" layer of brown lignitic clay at 25'
	2561	4+						Hard gray clay, jointed with 6" brown lignitic clay layer at 28'
30								_____ 32.5'
	2562	4+						Lignitic clay
35	2563	4+						Hard brown lignitic clay, laminated and jointed with 3" gray sandy clay layer at 34'
								_____ 37'±
40	2564	4+						Hard gray clay with cemented sand seams, laminated
	2565	4+						Hard dark gray lignitic clay _____ 43'3"
45	2566	4+						Black lignite _____ 44.5'

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas

BORING NO: SDP-6
 LOCATION: As directed by Client
 BORING TYPE: 4 1/2" Rotary
 GROUND ELEV: 280'±

CLIENT: TEXAS MUNICIPAL POWER AGENCY
 DATE: 9-28-83 PROJECT NO: 283-202
 DRILLER: Anderson SOIL TECHNICIAN: Huff

Depth in Feet	Sample Type & Sample No.	Penetrometer Reading, 1st	Blows / Foot	<input type="checkbox"/> - Shelby Tube Sample <input checked="" type="checkbox"/> - Standard Penetration Test Sample <input checked="" type="checkbox"/> - No Recovery J-Jar	DESCRIPTION OF STRATUM
50	2562	4+			Hard gray silty clay, laminated <div style="text-align: center; margin-left: 100px;"> <hr style="width: 50%; border: 0.5px solid black;"/> Bottom at 50' </div>
55					
60					
65					
					Boring filled with cement-bentonite grout upon completion of drilling

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas
 CLIENT: TEXAS MUNICIPAL POWER AGENCY
 DATE: 9-28,29-83
 DRILLER: Anderson

BORING NO: SDP-7
 LOCATION: As directed by Client
 BORING TYPE: 4 1/2" Rotary
 GROUND ELEV: 280'±

Depth in Feet	Sample Type & Sample No.	Penetrometer Reading, f/sf	Blows / Foot	Legend			
				■ - Shelby Tube Sample	☒ - Standard Penetration Test Sample	☑ - No Recovery	J-Jar
DESCRIPTION OF STRATUM							
	2563	3.75		Topsoil, tan silty fine sand _____ 6"			
				Very stiff gray sandy clay			
	2564	3.5		Very stiff tan and gray sandy clay with gray sand pocket at 3.5', fill			
5	2565	1.5 3.75		Stiff to very stiff tan and gray sandy clay			
	2566	3.5		Very stiff tan and gray sandy clay with sand nodules and organic material			
	2567	4.0		Hard tan and gray clay with gray clay pockets, fill			
10	2568	4+		Hard tan and gray clay with gravel and sand pockets			
	2569	4+		Hard tan clay with sandstone nodules			
15	2570	3.0		Very stiff tan and gray sandy clay _____ 15'			
				Gray clayey sand			
	2571	3.0		Gray and red clayey sand _____ 16.5'			
				Very stiff gray clay			
	2572	4+		Hard tan sandy clay _____ 18.5'			
20				Hard brown clay _____ 20'			
	2573	4+		Hard gray sandy clay			
	2574	4+		Hard gray sandy clay with organic streaks, jointed			
25	2575	2.25		Very stiff gray sandy clay			
	2576	2.25		Very stiff gray sandy clay _____ 28'			
	2577			Gray sandy clay-clayey sand			
30							
	2578	3.5		Very stiff gray sandy clay-clayey sand			
35							
	2579			Gray clayey sand with 1/2" layer of brown clayey sand at 39.5'			
40							
	2580	2.0		Gray clayey sand _____ 44.5'			
45				Very stiff gray sandy clay layer with tan sand layer at 45' and 4" layers of brown organic material			

BORING LOG

PROJECT: Gibbons Creek S.E.S. Facility Sludge Disposal Pond, Carlos, Texas

BORING NO: SDP-7

LOCATION: As directed by Client

CLIENT: TEXAS MUNICIPAL POWER AGENCY

DATE: 9-28,29-83

PROJECT NO: 283-202

BORING TYPE: 4 1/2" Rotary

DRILLER: Anderson


SOIL TECHNICIAN: Huff

GROUND ELEV: 280'±


Depth in Feet	Sample Type & Sample No.	Penetrometer Reading, 'fsf	Blows / Foot	DESCRIPTION OF STRATUM
50	2581			<p>Alternating layers of sandstone and gray sandy clay</p> <p style="text-align: center;">----- Bottom at 50'</p>
55				
60				
65				
				<p>Boring filled with cement-bentonite grout upon completion of drilling</p>

**Sections, Site-Grading, Gibbons Creek S.E.S. Unit No. 1,
Texas Municipal Power Agency, Drawing No. C-230-003,
Tippet & Gee, Inc., April 21, 1977, revised October 28, 1977.**


Environmental Resources Management
206 East 9th Street, Suite 1700
Austin, Texas 78701
(512) 459-4700




1 SECTION - SITE GRADING @ ASH DISPOSAL PONDS




2 SECTION - SITE GRADING @ ASH DISPOSAL PONDS




3 SECTION - SITE GRADING @ ASH DISPOSAL PONDS



4 SECTION - SITE GRADING @ ASH DISPOSAL PONDS



5 SECTION - SITE GRADING @ ASH DISPOSAL PONDS



6 SECTION - SITE GRADING @ ASH DISPOSAL PONDS

NOTES

REV.	DATE	BY	DESCRIPTION
A	12/21/77	JLW	ADDED 30' OF PIPE TO SEC. 4 & 11' OF PIPE TO SEC. 5

SCALE 1"=20'
 DRAWN JLW
 DATE 12-21-77
 CHECKED WGH
 APPROVED WGH, JLW



TIPPETT & GEE, INC.
 CONSULTING ENGINEERS
 ABILENE TEXAS


GIBBONS CREEK S.E.S.
 UNIT NO. 1
 TEXAS MUNICIPAL POWER
 AGENCY

SECTIONS
 SITE GRADING

JOB NO.	REV.
GC-1022	A
DRAWING NO.	C-2

**Plant Site Layout, Gibbons Creek S.E.S. Unit No. 1,
Texas Municipal Power Agency, Drawing No. C-230-001,
Tippet & Gee, Inc.
April 21, 1977, revised May 14, 1978.**

NOTE:
 MAXIMUM PROBABLE FLOOD STAGE - 254.5'
 TOP OF CONSERVATION STORAGE - 245.0'
 AVERAGE OPERATING LEVEL - 243.5'
 NORMAL LOW OPERATING LEVEL - 240.0'
 MINIMUM OPERATING LEVEL - 234.5'



REV	DATE	BY	DESCRIPTION
1	8-28-76	KTC	ADDED CULVERTS C-25A, C-15, C-16, RELOCATED WATER LINE & FENCE.

REV	DATE	BY	DESCRIPTION
2	8-28-76	KTC	REVISED ORIENTATION OF SEC. MARKERS 3, 4, 5 & 6.
3	8-28-76	KTC	ADDED AREA TO SWITTY YARD CHANGED COORDINATE OF C.W. LINE TO LOC. OF FENCE LINE.
4	8-28-76	KTC	REVISED STATIONING OF SEC. 15 AND CONTIGUOUS AREAS UNDER SEPARATE CONTRACT.
5	8-28-76	KTC	RELOCATED CULVERT C-15 TO LOC. OF DISCONNECTED ROAD & ADDED 20' WIDE CONC. DRIVEWAY.
6	8-28-76	KTC	RELOCATED CULVERT C-15 TO LOC. OF DISCONNECTED ROAD & ADDED 20' WIDE CONC. DRIVEWAY.
7	8-28-76	KTC	RELOCATED CULVERT C-15 TO LOC. OF DISCONNECTED ROAD & ADDED 20' WIDE CONC. DRIVEWAY.
8	8-28-76	KTC	RELOCATED CULVERT C-15 TO LOC. OF DISCONNECTED ROAD & ADDED 20' WIDE CONC. DRIVEWAY.
9	8-28-76	KTC	RELOCATED CULVERT C-15 TO LOC. OF DISCONNECTED ROAD & ADDED 20' WIDE CONC. DRIVEWAY.

SCALE: 1" = 200'

DATE: 8-28-76

CHECKED: [Signature]

APPROVED: [Signature]


TIPPETT & GEE, INC.
 CONSULTING ENGINEERS
 ABILENE, TEXAS

GIBBONS CREEK S.E.S.
 UNIT NO. 1
 TARRANT MUNICIPAL POWER AGENCY


PLANT SITE LAYOUT

JOB NO. GC-1022
 REV. E
 DRAWING NUMBER C-230-00


**Ash Ponds - Drop Inlets & Culvert Plans & Sections,
Gibbons Creek S.E.S. Unit No. 1,
Texas Municipal Power Agency, Drawing No. 15-C-235,
Tippet & Gee, Inc.
January 16, 1979, revised August 16, 1979.**




1 KEY PLAN - ASH PONDS
NO SCALE




2 PLAN - DROP INLET @ ASH DISPOSAL POND (2 THUS)
SCALE: 1/8" = 1'-0"




3 PLAN - BOX CULVERTS (TYPE A - 2 THUS AS NOTED, TYPE B - 2 THUS AS SHOWN)
SCALE: 1/8" = 1'-0"




4 SECTION - DROP INLET
SCALE: 1/8" = 1'-0"




5 SECTION - DROP INLET
SCALE: 1/8" = 1'-0"




6 SECTION - ACID TANK @ DROP INLET
SCALE: 1/8" = 1'-0"




7 TRASH SCREEN GUIDE (1 PER INLET)
SCALE: 1/8" = 1'-0"




8 TRASH SCREEN (4 THUS)
SCALE: 1/8" = 1'-0"




9A SECTION - TRASH SCREEN
SCALE: 1/8" = 1'-0"




9B SECTION - TRASH SCREEN
SCALE: 1/8" = 1'-0"



SECTION
SCALE: 1/8" = 1'-0"




12 STOP LOG DETAILS (4 THUS, AS SHOWN, FOR DROP INLETS)
SCALE: 1/8" = 1'-0"




13 SECTION
SCALE: 1/8" = 1'-0"

14 SECTION
SCALE: 1/8" = 1'-0"



15 SECTION
SCALE: 1/8" = 1'-0"



10 STOP LOG GUIDE (2 PER INLET, 4 THUS)
SCALE: 1/8" = 1'-0"

NOTES

NO.	REVISION	DATE	BY	CHECKED	APPROVED
1	ISSUED FOR CONSTRUCTION	1-16-77

NO.	REVISION	DATE	BY	CHECKED	APPROVED
1	ISSUED FOR CONSTRUCTION	1-16-77




TIPPETT & GEE, INC.
CONSULTING ENGINEERS
ABILENE TEXAS

OSBORN CREEK S.E.S.
UNIT NO. 1
TEXAS MUNICIPAL POWER
AGENCY


ASH PONDS - DROP INLETS
& CULVERT PLANS &
SECTIONS

JOB NO.	REV.
90-1200	1
DRAWING NUMBER	
18-C-235	


**Ash Ponds - Drop Inlets & Culvert Sections & Details,
Gibbons Creek S.E.S. Unit No. 1, Texas Municipal Power
Agency, Drawing No. 15-C-236,
Tippet & Gee, Inc.
June 1, 1979, revised June 25, 1981.**




20 SECTION - BOX CULVERTS
15-C-233 SCALE: 1/4" = 1'-0"



21 SECTION BOX-CULVERTS
15-C-233 SCALE: 1/4" = 1'-0"



22 STOP LOG GUIDE
SCALE: 1/4" = 1'-0"




23 STOP LOG DETAILS (THIS, AS SHOWN, FOR BOX CULVERTS)
SCALE: 1/4" = 1'-0"

RELEASE FOR CONSTRUCTION

247

NO.	REVISION	DESCRIPTION
1	REVISION	ISSUED FOR CONSTRUCTION - NO CHANGES FROM ORIGINAL
2	REVISION	ISSUED TO CORRECT DIMENSIONS AT DETAILS SITES

SCALE	AS NOTED
DRAWN	D.T.L.
DATE	10-1-77
CHECKED	L.W.
APPROVED	S.A.D.



TIPPETT & GEE, INC.
CONSULTING ENGINEERS
ABILENE TEXAS

GIBBONS CREEK S.E.S.
UNIT NO. 1
TEXAS MUNICIPAL POWER
AGENCY

ASH PONDS - DROP INLETS & CULVERT SECTIONS & DETAILS

JOB NO.	REV.
80-1800	2
DRAWING NUMBER	15-C-236

DRAWING NUMBER



DRAWING NUMBER

DRAWING NUMBER

DRAWING NUMBER
15-C-236 R.2

**FGD Area Plan, Concrete Paving Additions, Drawing No. 15-C-
215, Texas Municipal Power Agency,
May 5, 1988, Last Revised November 17, 1989.**

Environmental Resources Management
206 East 9th Street, Suite 1700
Austin, Texas 78701
(512) 459-4700




WAS DWG NO. SK-15-C-004

REV	DATE	BY	DESCRIPTION
1	12-10-00	WMS	REVISED & REDRAWN
2	1/17/01	WMS	REVISED DRAWING #1 FOR T.O. PKG # 149

REV	DATE	BY	DESCRIPTION
1	12-10-00	WMS	REVISED & REDRAWN
2	1/17/01	WMS	REVISED DRAWING #1 FOR T.O. PKG # 149

SCALE 1/4" = 1'-0"
 DRAWN WMS
 DEPT. PWR. ENGRG.
 DATE 3-5-00
 CHECKED
 APPROVED




TEXAS MUNICIPAL POWER AGENCY
 SERVING THE CITIES OF
 BRYAN • DENTON • GARLAND • GREENVILLE
FGD AREA PLAN
CONCRETE PAVING ADDITIONS

JOB NO.	REV
	2
DRAWING NO.	15-C-215

**Sludge Pond, Gibbons Creek S.E.S. Unit No. 1, Texas
Municipal Power Agency, Drawing No. 11-C-019.3, Texas
Municipal Power Agency,
February 15, 2000.**

Environmental Resources Management
206 East 9th Street, Suite 1700
Austin, Texas 78701
(512) 459-4700



NOTES
 North / south dimensions scaled from drawing
 East to west dimensions, at approximately elevation 280'-0", measured on 2/15/00

REV	DATE	BY	DESCRIPTION

SCALE N/A
 REVISED BY Homer R.
 DATE 2/15/00
 CHECKED hdr
 APPROVED B. Lane

SLUDGE POND

GIBBONS CREEK S.E.S.
 UNIT NO. 1
 TEXAS MUNICIPAL POWER
 AGENCY



FOR SURVEY INFORMATION.

JOB NO.	REV.
ABN 809	0
DRAWING NUMBER	
11-C-19.1	


**Scrubber Refurbishment Project 19-C-264, Dewatering Area
Paving, Drawing No 19-C-254, URS,
April 2, 2009, Revised June 1, 2011.**

Environmental Resources Management
206 East 9th Street, Suite 1700
Austin, Texas 78701
(512) 459-4700


- NOTES:
1. FOR STANDARD CONCRETE NOTES SEE DWG 19-C-101.
 2. FOR GUARD RAIL AND BOLLARD SEE DWG 19-C-263.
 3. FOR PAVING DETAILS SEE DWG 19-C-105.



DETAIL 1
SCALE: 1/32"=1'-0"




DETAIL 2
SCALE: 1/32"=1'-0"



RECORD COPY

REV	DATE	DESCRIPTION	BY	CHK	APP	REV	DATE	DESCRIPTION	BY	CHK	APP
-	-	-	-	-	-	-	-	-	-	-	-
4	6/1/11	RECORD COPY	-	-	-	-	-	-	-	-	-
-	9/3/10	IFC: REVISED DETAIL NUMBER FROM 2 TO 1 AND ADDED EXIST EJ	-	-	-	-	-	-	-	-	-
-	8/20/10	IFC: ADDED CONDENSER FND & REFERENCE SPTS AREA DWG	-	-	-	-	-	-	-	-	-
-	4/9/10	IFC: HOLD FOR WMTS EQUIP FND & DELETED MAINTENANCE ROOM PER WMTS-0101 PROJ #40819248	-	-	-	-	-	-	-	-	-
0	03/22/10	ISSUE FOR CONSTRUCTION	-	-	-	-	-	-	-	-	-

AUSTIN, TEXAS URS TEXAS REGISTRATION NO. F-3162 JOB NO. 40819148	SCALE 1/16"=1'-0" DRAWN CAT DEPT. CIVIL DATE 4/2/09 CHECKED RB APPROVED IC
--	---




TEXAS MUNICIPAL POWER AGENCY
 PROUDLY SERVING THE TEXAS CITIES OF
 BRYAN - DENTON - GARLAND - GREENVILLE

**SCRUBBER REFRUBISHMENT PROJECT
 DEWATERING AREA
 PAVING**

ABN NO.	REV.
-	4
DRAWING NO.	
19-C-264	

**TMPA Water Balance Diagram, ERM Drawing No 10-C-301,
September 24, 2010, Revised by Texas Municipal
Power Agency,
August 15, 2013.**



REV	DATE	BY	APP	DESCRIPTION	REV	DATE	BY	APP	DESCRIPTION
1	02/17/2016	PR	KW	REVISED PER RED LINE, ABN 1626					

SCALE	SIZE	DATE
N.T.S.	D	08-15-13

DEPT.	CHECKED	APPROVED
PWRPR	JF	JF

PROPERTY OF TMPA	
ABN NO. 13443	REV 1
DRAWING NO. 10-C-301	

NOTE: 1. This drawing was provided by ERM (Environmental Resource Management), September 24, 2010

**NWS 1978 - Hydrometeorological Report No. 51,
Probable Maximum Precipitation Estimates,
United States East of the 105th Meridian,
National Oceanic and Atmospheric Administration, June 1978.**

Environmental Resources Management
206 East 9th Street, Suite 1700
Austin, Texas 78701
(512) 459-4700

HYDROMETEOROLOGICAL REPORT NO. 51

**Probable Maximum Precipitation Estimates, United States
East of the 105th Meridian**

**U.S. DEPARTMENT OF COMMERCE
NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION
U.S. DEPARTMENT OF THE ARMY
CORPS OF ENGINEERS**

**Washington, D C
June 1978**

HYDROMETEOROLOGICAL REPORTS

- *No 1 Maximum possible precipitation over the Ompompanoosuc Basin above Union Village, Vt 1943
- *No 2 Maximum possible precipitation over the Ohio River Basin above Pittsburgh, Pa 1942
- *No 3 Maximum possible precipitation over the Sacramento Basin of California 1943
- *No 4 Maximum possible precipitation over the Panama Canal Basin 1943
- *No 5 Thunderstorm rainfall 1947
- *No 6 A preliminary report on the probable occurrence of excessive precipitation over Fort Supply Basin, Okla 1938
- *No 7 Worst probable meteorological condition on Mill Creek, Butler and Hamilton Counties, Ohio 1937 (Unpublished) Supplement, 1938
- *No 8 A hydrometeorological analysis of possible maximum precipitation over St Francis River Basin above Wappapello, Mo 1938
- *No 9 A report on the possible occurrence of maximum precipitation over White River Basin above Mud Mountain Dam site, Wash 1939
- *No 10 Maximum possible rainfall over the Arkansas River Basin above Caddoa, Colo 1939 Supplement, 1939
- *No 11 A preliminary report on the maximum possible precipitation over the Dorena, Cottage Grove, and Fern Ridge Basins in the Willamette Basin, Oreg 1939
- *No 12 Maximum possible precipitation over the Red River Basin above Denison, Tex 1939
- *No 13 A report on the maximum possible precipitation over Cherry Creek Basin in Colorado 1940
- *No 14 The frequency of flood-producing rainfall over the Pajaro River Basin in California 1940
- *No 15 A report on depth-frequency relations of thunderstorm rainfall on the Sevier Basin, Utah 1941
- *No 16 A preliminary report on the maximum possible precipitation over the Potomac and Rappahannock River Basins 1943
- *No 17 Maximum possible precipitation over the Pecos Basin of New Mexico 1944 (Unpublished)
- *No 18 Tentative estimates of maximum possible flood-producing meteorological conditions in the Columbia River Basin 1945
- *No 19 Preliminary report on depth-duration-frequency characteristics of precipitation over the Muskingum Basin for 1- to 9-week periods 1945
- *No 20 An estimate of maximum possible flood-producing meteorological conditions in the Missouri River Basin above Garrison Dam site 1945
- *No 21 A hydrometeorological study of the Los Angeles area 1939
- *No 21A Preliminary report on maximum possible precipitation, Los Angeles area, California 1944
- *No 21B Revised report on maximum possible precipitation, Los Angeles area, California 1945
- *No 22 An estimate of maximum possible flood-producing meteorological conditions in the Missouri River Basin between Garrison and Fort Randall 1946
- *No 23 Generalized estimates of maximum possible precipitation over the United States east of the 105th meridian, for areas of 10,200, and 500 square miles 1947
- *No 24 Maximum possible precipitation over the San Joaquin Basin, California 1947
- *No 25 Representative 12-hour dewpoints in major United States storms east of the Continental Divide 1947
- *No 25A Representative 12-hour dewpoints in major United States storms east of the Continental Divide 2d edition 1949
- *No 26 Analysis of winds over Lake Okeechobee during tropical storm of August 26-27, 1949 1951
- *No 27 Estimate of maximum possible precipitation, Rio Grande Basin, Fort Quitman to Zapata 1951
- *No 28 Generalized estimate of maximum possible precipitation over New England and New York 1952
- *No 29 Seasonal variation of the standard project storm for areas of 200 and 1,000 square miles east of 105th meridian 1953
- *No 30 Meteorology of floods at St Louis 1953 (Unpublished)
- *No 31 Analysis and synthesis of hurricane wind patterns over Lake Okeechobee, Florida 1954
- *No 32 Characteristics of United States hurricanes pertinent to levee design for Lake Okeechobee, Florida 1954
- No 33 Seasonal variation of the probable maximum precipitation east of the 105th meridian for areas from 10 to 1,000 square miles and durations of 6, 12, 24, and 48 hours 1956
- No 34 Meteorology of flood-producing storms in the Mississippi River Basin 1956
- No 35 Meteorology of hypothetical flood sequences in the Mississippi River Basin 1959
- *No 36 Interim report--probable maximum precipitation in California 1961 Also available is a supplement, dated October 1969
- No 37 Meteorology of hydrologically critical storms in California 1962
- No 38 Meteorology of flood-producing storms in the Ohio River Basin 1961
- No 39 Probable maximum precipitation in the Hawaiian Islands 1963
- No 40 Probable maximum precipitation, Susquehanna River drainage above Harrisburg, Pa 1965
- No 41 Probable maximum and TVA precipitation over the Tennessee River Basin above Chattanooga 1965
- No 42 Meteorological conditions for the probable maximum flood on the Yukon River above Rampart, Alaska 1966
- No 43 Probable maximum precipitation, Northwest States 1966
- No 44 Probable maximum precipitation over South Platte River, Colorado, and Minnesota River, Minnesota 1969

*Out of print

(Continued on inside back cover)

U.S. DEPARTMENT OF COMMERCE
NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION

U.S. DEPARTMENT OF THE ARMY
CORPS OF ENGINEERS

HYDROMETEOROLOGICAL REPORT NO. 51

**Probable Maximum Precipitation Estimates, United States
East of the 105th Meridian**

Prepared by
Louis C. Schreiner and John T. Riedel
Hydrometeorological Branch
Office of Hydrology
National Weather Service

WASHINGTON, D.C.
June 1978

Reprinted August 1980

CONTENTS

	Page
Abstract.....	1
1. Introduction.....	1
1.1. Background.....	1
1.2. Assignment.....	1
1.3. Definition of PMP.....	2
1.4. Scope.....	2
1.4.1. Generalized vs. individual drainage estimates.....	2
1.4.2. Stippled regions on PMP maps.....	3
1.5. Application of drainage PMP values.....	3
2. Approach to generalized PMP.....	3
2.1. Introduction.....	3
2.2. Basic data.....	4
2.2.1. Sources.....	4
2.2.2. Variation in rainfall data with duration and area size..	6
2.2.3. Point rainfall vs. 10-mi ² (26-km ²) average rainfall.....	7
2.3. Moisture maximization.....	7
2.3.1. Definition - concept.....	7
2.3.2. Atmospheric moisture.....	8
2.3.3. Representative storm dew point.....	8
2.3.4. Maximum dew point.....	9
2.3.5. Moisture adjustment.....	9
2.3.6. Elevation and barrier considerations.....	9
2.4. Transposition.....	10
2.4.1. Definition.....	10
2.4.2. Transposition limits.....	10
2.4.3. Transposition adjustment.....	11
2.4.4. Distance-from-coast adjustment for tropical storm rainfall.....	11
2.4.5. Large-area rainfall adjustment in the gentle upslope region.....	11
2.4.6. Example of storm adjustments.....	14
3. Details of analysis.....	16
3.1. Minimum envelopes.....	16
3.2. Special problems.....	26
3.2.1. Introduction.....	26
3.2.2. Adjustments greater than 50 percent.....	28
3.2.3. Colorado storm May 30-31, 1935.....	28
3.2.4. Smethport, Pa. storm July 17-18, 1942.....	28
3.2.5. Yankeetown, Fla. storm September 3-7, 1950.....	29
3.3. Consistency checks.....	30
3.3.1. Introduction.....	30
3.3.2. Variation of incremental PMP with area size.....	31
3.3.3. Consistency in depth-area-duration relations.....	32

	Page
3.3.4. Cross section checks.....	32
3.3.5. Rainfall difference check.....	32
3.3.6. Rainfall ratio check.....	32
3.3.7. PMP maps.....	38
4. Evaluation of generalized PMP charts.....	38
4.1. Degree of envelopment.....	38
4.2. Use of PMP for all durations in one PMP storm.....	40
4.2.1. Introduction.....	40
4.2.2. Storm commonality test.....	40
5. Use of PMP charts.....	42
Acknowledgments.....	43
References.....	44
Appendix -- Maximum observed areal precipitation for important storms.....	78

TABLES

1. Number of analyzed storms, east of the 105th meridian, with areal rainfall depths for indicated area sizes and durations.....	6
2. Example of computations of moisture maximization and transposition adjustments.....	17
3. Example of total storm adjustments.....	18
4. Storms that give moisture maximized rainfall within 10 percent of PMP for at least one area size and duration.....	39
5. Exceptions to "storm commonality".....	42

FIGURES

1. Location of storms.....	5
2. Distance-from-coast adjustment for transposing tropical storm rainfall.....	12
3. Gentle upslope region.....	13
4. Example of data used for storm adjustments.....	15

	Page
5. Envelopment of 24-hr observed storm rainfall (in.) in place of occurrence for 10,000 mi ² (25,900 km ²).....	20
6. Envelopment of 24-hr moisture maximized storm rainfall (in.) in place of occurrence for 10,000 mi ² (25,900 km ²).....	21
7. Envelopment of greatest average monthly precipitation (in.) for State climatic divisions (1931-60).....	22
8. Envelopment of greatest average weekly precipitation (in.) for State climatic divisions (1906-35).....	24
9. Envelopment of the greatest 24-hr station precipitation (in.) within each State climatic division (through 1970).....	25
10. Example of minimum smooth envelope of moisture maximized rainfall, in place and transposed.....	27
11. Adopted transposition adjustment along the Atlantic coast for the Yankeetown, Fla. storm, September 3-7, 1950.....	31
12. Example of depth-duration smoothing.....	33
13. Example of depth-area smoothing.....	34
14. Example of cross-section smoothing--constant duration.....	35
15. Example of cross-section smoothing--constant area.....	36
16. Example of checks of durational differences in PMP.....	37
17. Regions for storm commonality tests.....	41
18. All-season PMP (in.) for 6 hr 10 mi ² (26 km ²).....	48
19. All-season PMP (in.) for 12 hr 10 mi ² (26 km ²).....	49
20. All-season PMP (in.) for 24 hr 10 mi ² (26 km ²).....	50
21. All-season PMP (in.) for 48 hr 10 mi ² (26 km ²).....	51
22. All-season PMP (in.) for 72 hr 10 mi ² (26 km ²).....	52
23. All-season PMP (in.) for 6 hr 200 mi ² (518 km ²).....	53
24. All-season PMP (in.) for 12 hr 200 mi ² (518 km ²).....	54
25. All-season PMP (in.) for 24 hr 200 mi ² (518 km ²).....	55

	Page
26. All-season PMP (in.) for 48 hr 200 mi ² (518 km ²).....	56
27. All-season PMP (in.) for 72 hr 200 mi ² (518 km ²).....	57
28. All-season PMP (in.) for 6 hr 1,000 mi ² (2,590 km ²).....	58
29. All-season PMP (in.) for 12 hr 1,000 mi ² (2,590 km ²).....	59
30. All-season PMP (in.) for 24 hr 1,000 mi ² (2,590 km ²).....	60
31. All-season PMP (in.) for 48 hr 1,000 mi ² (2,590 km ²).....	61
32. All-season PMP (in.) for 72 hr 1,000 mi ² (2,590 km ²).....	62
33. All-season PMP (in.) for 6 hr 5,000 mi ² (12,950 km ²).....	63
34. All-season PMP (in.) for 12 hr 5,000 mi ² (12,950 km ²).....	64
35. All-season PMP (in.) for 24 hr 5,000 mi ² (12,950 km ²).....	65
36. All-season PMP (in.) for 48 hr 5,000 mi ² (12,950 km ²).....	66
37. All-season PMP (in.) for 72 hr 5,000 mi ² (12,950 km ²).....	67
38. All-season PMP (in.) for 6 hr 10,000 mi ² (25,900 km ²).....	68
39. All-season PMP (in.) for 12 hr 10,000 mi ² (25,900 km ²).....	69
40. All-season PMP (in.) for 24 hr 10,000 mi ² (25,900 km ²).....	70
41. All-season PMP (in.) for 48 hr 10,000 mi ² (25,900 km ²).....	71
42. All-season PMP (in.) for 72 hr 10,000 mi ² (25,900 km ²).....	72
43. All-season PMP (in.) for 6 hr 20,000 mi ² (51,800 km ²).....	73
44. All-season PMP (in.) for 12 hr 20,000 mi ² (51,800 km ²).....	74
45. All-season PMP (in.) for 24 hr 20,000 mi ² (51,800 km ²).....	75
46. All-season PMP (in.) for 48 hr 20,000 mi ² (51,800 km ²).....	76
47. All-season PMP (in.) for 72 hr 20,000 mi ² (51,800 km ²).....	77

PROBABLE MAXIMUM PRECIPITATION ESTIMATES, UNITED STATES EAST OF THE 105TH MERIDIAN

Louis C. Schreiner and John T. Riedel
Office of Hydrology
NOAA, National Weather Service, Silver Spring, Md.

ABSTRACT. Generalized estimates of Probable Maximum Precipitation, the greatest rainfall rates for specified durations theoretically possible, are presented for the United States east of the 105th meridian. They are all-season estimates, that is, the greatest for any time of year, for drainages from 10 to 20,000 mi² (26 to 51,800 km²) for durations of 6 to 72 hours. Details of the procedures and methods used for developing these estimates are described.

1. INTRODUCTION

1.1 Background

Generalized charts setting the level of all-season Probable Maximum Precipitation (PMP) for drainages up to 1,000 mi² (2,590 km²), covering the United States east of the 105th meridian, have been available since 1947 (U.S. Weather Bureau 1947) and the seasonal variation since 1956 (Riedel et al. 1956). These studies have been used extensively by the Corps of Engineers, other Federal agencies, State and local governments, private engineers and meteorologists. Because of increased interest in projects involving large drainages, it was found necessary to extend estimates to areas greater than 1,000 mi² (2,590 km²). At the same time, it was necessary to revise the small area, less than 1,000 mi² (2,590 km²) study in order to appropriately consider all important historical storms; for example, the Yankeetown, Fla. storm of September 3-7, 1950. The areal depths for this storm were not available when the 1956 study was prepared.

1.2 Assignment

Discussions concerning the need for the generalized PMP charts for large areas were held at a meeting with representatives of the Office of the Chief, Corps of Engineers, at Phoenix, Ariz., May 17-20, 1971. Authorization for the revision of the previous small-area study and coordination of the results with the extension to larger areas stemmed from a meeting with representatives of the Office of the Chief, Corps of Engineers at Silver Spring, Md., September 19, 1974.

1.3 Definition of PMP

PMP is defined as "the theoretically greatest depth of precipitation for a given duration that is physically possible over a particular drainage area at a certain time of year," (American Meteorological Society 1959). In consideration of our limited knowledge of the complicated processes and interrelationships in storms, PMP values are identified as estimates.

Another definition of PMP more operational in concept is "the steps followed by hydrometeorologists in arriving at the answers supplied to engineers for hydrological design purposes" (WMO 1973). This definition leads to answers deemed adequate by competent meteorologists and engineers and judged as meeting the requirements of a design criterion.

1.4 Scope

This study can be used to determine drainage average all-season PMP for any drainage from 10 to 20,000 mi² (26 to 51,800 km²) in area for durations of 6 to 72 hours in the United States east of the 105th meridian. In northern portions of the region, all-season PMP may not yield the probable maximum flood. Critical spring soil conditions with snow on the ground, in combination with spring season PMP values, may yield greater flood peaks.

1.4.1 Generalized vs. Individual Drainage Estimates

The PMP values of this study are termed generalized estimates. By this we mean isolines of PMP are given on a map allowing determination of average PMP for any drainage.

Through the years, the Hydrometeorological Branch has determined PMP estimates for individual drainages. This was done: (a) if generalized PMP studies were not available, (b) for drainages larger in size than covered by available generalized PMP studies, or (c) for drainages such as in the Appalachians, where detailed studies indicated orographic effects would yield PMP estimates significantly different from those determined from available generalized PMP charts. Some of the more substantive studies have been published. The more recent ones cover drainages of the Red River of the North and Souris River (Riedel 1973), the Colorado and Minnesota Rivers (Riedel et al. 1969), the Tennessee River (Schwarz 1965, and Schwarz and Helfert 1969) and the Susquehanna River (Goodyear and Riedel 1965). These and other unpublished individual drainage PMP estimates made by the Hydrometeorological Branch may take precedence over estimates obtained from generalized PMP studies of this report because the individual drainage studies take into account orographic features that are smoothed out in this study. On the other hand, due to passage of time, individual drainage studies will not necessarily include recent storm data and advances in meteorological concepts. It is not practical to evaluate all the individual drainage PMP estimates at this time. We suggest a decision be made on a case-by-case basis as needed.

1.4.2 Stippled Regions on PMP Maps

The generalized PMP maps (figs. 18-47) are stippled in two regions, (a) the Appalachian Mountains extending from Georgia to Maine and (b) a strip between the 103rd and 105th meridian. This stippling outlines areas within which the generalized PMP estimates might be deficient because detailed terrain effects have not been evaluated.

In developing the maps of PMP, it was sometimes necessary to transpose storms to and from higher terrain. Determination of storm transposition limits (section 2.4.2) took into account topography homogeneity in a general sense, thereby avoiding major topographic considerations. However, regional analysis required definition across mountains such as the Appalachians. For such regions, the assumption was made that the reduced height of the column of moisture available for processing (section 2.3.2) at higher elevations is compensated by intensification from steeper terrain slopes.

In contrast to the use of these simplifying assumptions, studies of PMP covering portions of the Western States (U.S. Weather Bureau 1961, 1966, and Hansen et al. 1977) and the Tennessee River drainage (Schwarz and Helfert 1969) do take into account detailed terrain effects. A laminar flow orographic precipitation computation model, useful in some regions where cool-season precipitation is of greatest concern, gives detailed definition for some of the Western States. For the Tennessee River drainage, nonorographic PMP was adjusted for terrain effects by consideration of numerous different rain-fall criteria, taking into account meteorological aspects of critical storms of record.

We expect future studies of the Hydrometeorological Branch will involve detailed generalized studies covering the stippled regions. Until these studies are completed, we suggest that major projects within the stippled regions be considered on a case-by-case basis as the need arises.

1.5 Application of Drainage PMP Values

The results of this study are drainage average PMP depths for the designated durations (6 to 72 hours) without specifying a time sequence for occurrence of 6-hr incremental PMP values. A companion report (Hansen and Schreiner) to this study covers methods for spatially distributing the most important 6-hr PMP increments. It also gives meteorological reasonable time sequences of the 6-hr PMP increments from the beginning of the PMP storm. Additionally, shape and orientation of isohyetal patterns are discussed.

2. APPROACH TO GENERALIZED PMP

2.1 Introduction

The basic approach used in developing PMP estimates has been described in numerous publications (WMO 1973, Wiesner 1970, WMO 1969a, Paulhus and Gilman 1953, and U.S. Weather Bureau 1960). The first reference contains

the most comprehensive discussion. For nonorographic regions, the approach may be briefly summarized by three operations on observed areal storm precipitation: moisture maximization, transposition, and envelopment.

Moisture maximization consists of increasing the storm precipitation to a value that is consistent with the maximum moisture in the atmosphere for the storm location and month of occurrence.

Transposition means relocating storm precipitation within a region that is homogeneous relative to terrain and meteorological features important to the particular storm rainfall. Transposition greatly increases the available data for evaluating the rainfall potential for a drainage.

Envelopment is smoothly interpolating between the maxima from a group of values for different durations and/or areas. Such smooth enveloping curves in many cases may give greater values for some durations or area sizes than obtained from only moisture maximization and transposition. In addition, envelopment over a region entails smooth geographic variation of moisture maximized and transposed rainfall values obtained from numerous storms. Such smoothing compensates for the random occurrence of large rainfalls, in that a drainage may not have experienced equally efficient precipitation mechanisms for all pertinent durations and sizes of areas. Envelopment also gives regionally consistent mapped values; unless differences can be explained meteorologically or topographically, anomalies should be avoided. Methods of envelopment applied in this report are explained in section 3.

2.2 Basic Data

2.2.1 Sources

The basic data for this study are maximum observed areal precipitation depths for various durations. These data are developed by a standardized depth-area-duration (D-A-D) analysis of point precipitation amounts. The procedure used for D-A-D analysis can be found in several publications (WMO 1969b and U.S. Weather Bureau 1946).

For the United States, over 500 storms have been so analyzed, and the pertinent data, that is, the maximum areal depths, have been published (Corps of Engineers, U.S. Army 1945-). Canada has made similar analysis for over 400 storms (Atmospheric Environment Service 1961-). Some of the Canadian storms were useful in the present study. Storm rainfalls from these sources were augmented by unofficial storm D-A-D values developed by the Hydro-meteorological Branch or found in the literature (Shipe and Riedel 1976).

The appendix chronologically lists observed rainfall depths for the important storms of this study. These were most influential in setting the level of PMP for at least one combination of area size and duration. Figure 1 shows the locations of these storms along with other storms discussed in the text. Storms mentioned in the text, listed in the appendix, or shown in various figures are identified by a storm index number. In the text, this number is in parenthesis following reference to the storm. For storms




Figure 1.--Location of storms. [Storms of appendix (section 2.2.1), others mentioned in text (sections 2.4.5 and 3.2.3), and those within 10 percent of PMP (section 4.1)]

shown in figures or listed in the appendix, a storm assignment number is also given. This number is either assigned by the Corps of Engineers (for U.S. storms) or the Atmospheric Environment Service (for Canadian storms). Those storms without a storm assignment number refer to unofficial rainfall data accumulated by the Hydrometeorological Branch.

2.2.2 Variation in Rainfall Data with Duration and Area Size

Table 1 shows the number of United States storms east of the 105th meridian, for which areal rainfall depths have been analyzed for listed area sizes and durations.

Table 1.--Number of analyzed storms east of the 105th meridian, with areal rainfall depths for indicated area sizes and durations.

Area		Duration (hr)				
mi ²	(km ²)	6	12	24	48	72
10	(26)	496	482	456	356	187
200	(518)	521	508	483	376	201
1,000	(2,590)	567	555	533	419	234
5,000	(12,950)	528	526	517	417	262
10,000	(25,900)	489	489	486	406	263
20,000	(51,800)	396	396	396	351	242

One would expect a decrease in basic data with increasing area size and increasing duration. With respect to duration, it is easy to show that the storms that last 6 or 12 hours are much more numerous than storms that last beyond 12 hours. Similarly, we know that many storms cover only a small area, e.g., summer thunderstorms.

There are several reasons why table 1 does not fully show this variation. There has been more need for maximum precipitation criteria over small areas, i.e., drainages less than 1,000 mi² (2,590 km²); therefore, analysis of storms covering these areas has been emphasized. In the construction of table 1, a storm was not counted if the rainfall ceased to increase with increasing duration. Often for large-area storms, the small-area precipitation is concentrated in a shorter duration than the total storm period. This permits more values to be listed for large areas and long durations.

Another reason for the variation shown in table 1 is that a special effort was made to augment basic data for areas of 1,000 mi² (2,590 km²) and larger, particularly in regions with few analyzed storms. In the effort to obtain additional storm data, short-cut procedures were used, such as using only recording raingages for determining the time variation of rainfall. If recording raingages are well spaced, the results are quite similar to those

obtained by standard procedures (WMO 1969b and U.S. Weather Bureau 1946). A few of these additional storms were important in setting the general level of PMP.

2.2.3 Point Rainfall vs. 10-mi² (26-km²) Average Rainfall

This study estimates PMP for drainage sizes down to 10 mi² (26 km²). The basic data (Corps of Engineers, U.S. Army 1945-) often use point rainfall as 10-mi² (26-km²) rainfall in D-A-D analyses. This is done in order to at least partially compensate for the slim chance of "catching" the most intense rainfall in any storm. The question may then be raised as to whether PMP for areas less than 10 mi² (26 km²) would be greater than the 10-mi² (26-km²) values of this report. This is answered by the fact that with few exceptions the critical values establishing the PMP magnitude for 10 mi² (26-km²) average rainfalls rather than single station amounts. This indicates that PMP for areas smaller than 10 mi² (26 km²) would be greater than the 10-mi² (26-km²) values in this report.

2.3 Moisture Maximization

2.3.1 Definition - Concept

Moisture maximization refers to the process of increasing storm rainfall depths for the storm location and season, for higher atmospheric moisture than was available in the actual storm.

Significant precipitation results from lifting moist air. Processes causing this lifting, associated with horizontal convergence, have been described in numerous texts. Various attempts at developing a model that will reproduce extreme rainfalls are hampered by the lack of sufficient data within storms to adequately check the magnitudes of horizontal convergence, vertical motion, and other parameters. Since measurements of these parameters during severe storms are not readily obtainable, the solution has been to use extreme record storm rainfalls as an indirect measure of parameters, other than moisture, that are important to such events.

We thus adjust storms of record to the equivalent of what would have occurred with maximum moisture and make the following assumption: The sample of extreme storms is sufficiently large so that near optimum "mechanism" (or efficiency) has occurred. By "mechanism" is meant a combined measure of all the important parameters to rainfall production, except moisture. The assumption thus circumvents a quantitative evaluation of "mechanism" and results in increasing storm rainfall occurring with assumed near optimum "mechanism" by an adjustment for maximum moisture.

In our use of the term mechanism, we do not include lifting by terrain. For PMP studies in the Western States, augmentation or depletion by terrain is taken in account (U.S. Weather Bureau 1966, and Hansen et al. 1977). Over most of the region of the present study the terrain effect is small. Sections 1.4.2 and 2.4.5 discuss how the more important terrain features were considered.

2.3.2 Atmospheric Moisture

The best measure of atmospheric moisture can be obtained from radiosonde observations. Soundings, giving the variation of moisture with height, are available for about 100 stations in the United States for 20 years. However, radiosonde data alone cannot be used for several reasons. First, many extreme storms occurred before the radiosonde network was established. Second, the radiosonde network is much too sparse to detect narrow tongues of moisture (Schwarz 1967) that are important to many storms. The solution is to use surface dew points, which are observed at many stations, as indices to atmospheric moisture. A saturated pseudo-adiabatic atmosphere is assumed, tied to surface dew points, which fixes the moisture and its distribution with height in the atmosphere. Tests have shown that the moisture thus computed is an adequate approximation to atmospheric moisture in major storms or for high dew point situations (Miller 1963).

Two dew points are required for moisture maximization. One is the dew point representative of moisture inflow during the storm. The other is the maximum dew point for the same location and time of year as the storm. Both storm and maximum dew points are reduced pseudo-adiabatically to 1000 mb (100 kPa) in order to normalize for differences in station elevations.

The measure of atmospheric moisture used is precipitable water (w_p). This is the depth of water vapor condensed into liquid in a column of air of unit cross section. For a saturated pseudo-adiabatic atmosphere, tables have been prepared (U.S. Weather Bureau 1951) giving w_p values based on 1000-mb (100-kPa) dew points.

Both storm and maximum dew points are usually taken as the highest value persisting for 12 hours. Instantaneous extreme dew point measurements may not be representative of inflow moisture over a significant time period. Also, taken over a duration, the effect of possible erroneous instantaneous dew point values is reduced.

The depth of precipitable water to use for adjustments was considered (U.S. Weather Bureau 1947) in a convergence storm model. Formation of cumulus clouds suggested division of the model into 3 layers; the lower inflow layer, the center with vertical motion, and the upper or outflow layer. It was found that the moisture adjustment did not change appreciably when various different proportional heights were assumed for these 3 layers. It was also determined that the height of the model [whether 400 or 200 mb (40 or 20 kPa)] did not materially change the moisture adjustment. Tests also indicated that the moisture adjustment is basically the same whether total w_p or effective w_p is used. The effective w_p is the inflow layer w_p minus the outflow layer w_p .

2.3.3 Representative Storm Dew Point

Dew points are selected in the warm moist air flowing into the storm. Both distance and direction of the dew points from the rainfall center are recorded. An average dew point value from several stations is considered to give

the best estimate. Care must be used to ensure that dew point observations are taken only within the moist tongue involved in the heavy precipitation (Schwarz 1967). The time sequence of dew points from each station is reduced to 1000 mb (100 kPa) before averaging. After averaging, the highest persisting 12-hr value is selected.

2.3.4 Maximum Dew Point

Maximum dew points are generally the highest dew points observed for a given location and time of year. These dew points are based on seasonal and regional envelopes of maximum observed surface dew points that have persisted for 12 hours, reduced to 1000 mb (100 kPa) at many stations (Environmental Data Service 1968).

We adjust the storm to the maximum dew point 15 days from the storm date into the warmer season except for cases accompanied by unusually cold air judged to be dynamically significant to the rainfalls. Moisture maximization adjustments are increased by up to 10 percent due to the 15-day transposition.

2.3.5 Moisture Adjustment

Moisture maximization is accomplished by multiplying observed rainfall by the moisture adjustment, which is the ratio of w_p for the maximum 1000-mb (100-kPa) 12-hr persisting dew point to the w_p for the storm 1000-mb (100-kPa) 12-hr persisting dew point. This maximization expressed mathematically is:

$$P \times \frac{w_p \text{ Maximum}}{w_p \text{ Storm}} = \text{moisture-adjusted rainfall}$$

where P = observed rainfall

w_p = precipitable water. Maximum refers to enveloping highest observed w_p and Storm refers to storm w_p .
(Both dew points are for the same location.)

2.3.6 Elevation and Barrier Considerations

Where there is a significant mountain barrier between the moisture source and rain location, or the rain occurs at a high elevation, a refinement to the moisture adjustment is usually applied. In such cases, mean elevation of the barrier ridge, or elevation of the rainfall rather than the 1000-mb (100-kPa) surface, is used as the base of the column of moisture. Section 2.4.5 discusses refinements to the moisture adjustment applied to large-area storms transposed in the gentle upslope region. Section 1.4.2 discussed the extent of orographic considerations used in this study. The location of representative storm dew points (usually toward a coast and at lower elevations) and restrictions to storm transposition (section 2.4.2) generally eliminated the need for using elevations in the moisture adjustment.

2.4 Transposition

2.4.1 Definition

Transposition means relocating isohyetal patterns of storm precipitation within a region that is homogeneous relative to terrain and meteorological features important to the particular storm rainfall under concern.

2.4.2 Transposition Limits

Topography is one of the more important controls on limits to storm transposition. If observed rainfall patterns show correspondence with underlying terrain features, or indicate triggering of rainfall by slopes, transposition should be limited to areas of similar terrain. Identification of broadscale meteorological features is important, e.g., surface and upper air high and low pressure centers that are associated with the storm, and how they interact to produce the rainfall. Also useful in determining transposition limits are storm isohyetal charts, weather maps, storm tracks and rainfalls of record for the type of storm under consideration, and topographic charts.

The more important guidelines to storm transposition for this study were:

- a. Transposition was not permitted across the generalized Appalachian Mountain ridge.
- b. Tropical storm rainfall centers were not transposed farther away from nor closer to the coast without an additional adjustment (section 2.4.4).
- c. In regions of large elevation differences, transpositions were restricted to a narrow elevation band (usually within 1000 ft (305 m) of the elevation of the storm center).
- d. Eastward limits to transposition of storms located in Central United States were the first major western upslopes of the Appalachians.
- e. Westward transposition limits of storms located in Central United States were related to elevation. This varied from storm-to-storm but in most cases the 3000- or 4000-ft (915- or 1220-m) contour.
- f. Southern limits to transposition were generally not defined since other storms located farther south usually provided higher rainfall values.
- g. Northward limits were not defined if they extended beyond the Canadian border (the limits of the study region).

2.4.3 Transposition Adjustment

The transposition adjustment applied to relocated rainfall values is the ratio of w_p for the maximum 12-hr persisting dew point for the transposed location to that of the storm in place. The maximum dew point is for the same distance and direction from the transposed location as the storm representative dew point is from the storm location (section 2.3.3).

2.4.4 Distance-From-Coast Adjustment for Tropical Storm Rainfall

The general decrease in tropical storm rainfall with distance inland is well known. It is attributed to the difficulty of maintaining the same rainfall intensity as distance from the moisture source increases, and the deterioration of the tropical circulation with increasing distance inland. The usual transposition methods (section 2.4.3) provide little or no decrease in tropical storm rainfall when such storms are transposed farther inland. This is because the maximum 1000-mb (100-kPa) 12-hr persisting dew point charts (Environmental Data Service 1968) for the tropical storm season show little or no variation for up to approximately 550 mi (885 km) inland from the gulf coast. Therefore, an adjustment for distance from the coast was determined specifically for tropical storms when they were transposed inland.

A study (Schwarz 1965) developed a relation showing the decrease in tropical rainfall with distance [coast to 300 n.mi. (556 km)] inland. The relation was based on both observed and moisture-maximized tropical rainfall data for several area sizes and durations. Figure 2 shows this variation along with its extension for distances farther inland (solid line). The extension used additional data of the same type as used by Schwarz. Another relation derived from the same type of data (Schoner 1968) is shown by the dashed line. We have adopted Schwarz's relation with the extension for use in the present study. It shows no decrease in rainfall for the first 50 n.mi. (93 km) inland from the gulf coast, a smooth decrease to 80 percent at 205 n.mi. (380 km) inland, and 55 percent at 400 n.mi. (740 km) inland.

We applied the adjustment for distance from the coast to tropical storm rainfall (all area sizes and durations) transposed within the region where the maximum persisting 12-hr 1000-mb (100-kPa) dew point temperature charts (Environmental Data Service 1968) indicate no variation. When transposing rainfalls nearer to the coast, the values are increased. In the same way, they are decreased when transposed farther inland.

2.4.5 Large-Area Rainfall Adjustment in the Gentle Upslope Region

This report did not apply an elevation adjustment when transposing storms within limited differences in elevation (section 2.3.6). However, in the gently rising terrain west of the Mississippi River to the generalized initial steep slopes in the western portion of the study region (fig. 3) patterns of tentative PMP were not consistent with patterns in the guidance material discussed in section 3.1. The guidance material indicated a greater decrease in areal rainfall toward the west in the gentle upslope region.




Figure 2.--Distance-from-coast adjustment for transposing tropical storm rainfall.




Figure 3.--Gentle upslope region.

Storm Rainfall (Corps of Engineers, U.S. Army 1945-) in the gentle upslope region was analyzed regionally. In this analysis the data were stratified and adjusted to eliminate variations due to distance from the moisture source and moisture availability in the record storms. The results showed a significant decrease toward the west in both the extremes of record and the averages of the three greatest values. Stratification of the rainfall by area size showed a decided trend toward greater decrease for large-area rainfall than for small.

The greater decrease for large-area rainfall can be the result of several factors. For small areas, a narrow band of inflowing moisture from the Gulf of Mexico can be important to extreme rainfalls. The intense center of the June 14-17, 1965 storm (No. 96) was associated with such a moisture band (Schwarz 1967). For larger areas, the broader and more persistent moisture bands are much more difficult to maintain, particularly into higher elevations of the gentle upslope region. Another factor of importance is the scattering of small hills and ridges throughout the region. These stimulate local rainfalls that are important to small-area storms. The decrease in available moisture with increasing elevation in the gentle upslope region is thus more important for large-area rainfalls.

With the evidence from rainfall data of various kinds and meteorological analyses within the gentle upslope region, we decreased large-area rainfalls when transposing to higher elevations and increased them when transposing to lower elevations. Storm depths for 1,000 mi² (2,590 km²) or less were not adjusted.

The adjustment is based on the variation in precipitable water with height in the atmosphere for the maximum 12-hr persisting dew point in the storm location and in the transposed location. The adjustment ranges between 6 and 10 percent per 1,000 ft (305 m) change in elevation, depending on the elevation of the storm and the maximum dew point. This adjustment was applied to rainfall for all area sizes greater than 1,000 mi² (2,590 km²). Any discontinuity introduced in PMP at 1,000 mi² (2,590 km²) was eliminated by the various consistency checks (see section 3.3).

There are a number of major large-area storms in the gentle upslope region with limits of transposition east of the Mississippi River - beyond the boundaries of the gentle upslope region. In calculating the adjusted rainfall for the eastward transposition of these storms, the adjustment for gentle upslope was not applied. In all such cases the small change in elevation would have altered the total storm adjustment by less than 4 percent.

2.4.6 Example of Storm Adjustments

The rainfall of the May 6-12, 1943 storm (No. 77), centered at Warner, Okla., is used to demonstrate computation of storm adjustments.

The representative storm dew point (section 2.3.3) is located 225 mi (362 km) south-southeast of the rain center. Figure 4 depicts the areas enclosed by the 3- and 9-in. (76- and 229-mm) isohyets, the storm's




Figure 4.--Example of data used for storm adjustments. [May 6-12, 1943 storm, Warner, Okla.]

transposition limits (dashed lines), and the location of the representative storm dew point. As with all major storms, the adjusted rainfall was computed when transposed to the most distance points, in this case A, B, C, and D. Table 2 lists required data and computations necessary for calculating the moisture maximization and transposition adjustments. Table 3 lists additional data and computations for the gentle upslope adjustment.

In our example, we will compute the adjusted storm rainfall for 20,000 mi² (51,800 km²) and a duration of 24 hours where the storm occurred (in place) and for points A, B, C, and D. From the appendix, the observed storm depth is 6.1 in. (155 mm).

The first step is to find the maximum 1000-mb (100-kPa) 12-hr persisting dew point (section 2.3.4) at the given distance and direction from each location (in place, A, B, C, and D). The storm dew point occurred on the 10th of May. Introducing the 15-day transposition into the warm season (section 2.3.4), the maximum 1000-mb (100-kPa) 12-hr persisting dew points (Environmental Data Service 1968) for May 25 are 77, 75, 73, 78, and 76°F (25.0, 23.9, 22.8, 25.6 and 24.4°C), respectively, for the storm in place and for the points A, B, C, and D (table 2, col. 1). The corresponding precipitable water (w_p) values up to 200 mb (20 kPa) (U.S. Weather Bureau 1951) are shown in table 2, col. 2.

The second step is to compute adjustment factors for maximum moisture and transposition (table 2, col. 3a and b). The product of these factors, all that is required for most storms, is shown in table 2, col. 4.

The next step is to consider adjustment for gentle upslope (section 2.4.5). Two of the transposed locations -- A and D -- are in this region. From a generalized topographic map, the elevation of the rainfall center and that of location D are approximately the same (table 3, col. 2); thus, no further adjustment is required for D. Location A is 1,000 ft (305 m) higher than the storm center in place. The increased elevation at A gives a downward adjustment of 8 percent per 1,000 ft (305 m) accounting for the loss of available w_p between 1,000 and 2,000 ft (305 and 610 m) for this maximum w_p . The total storm adjustment for location A is the product of the adjustment factor (col. 1) and gentle upslope factor (col. 3) shown in table 3. Multiplication of the appropriate factors by the storm's observed depth results in the adjusted depths shown in table 3, col. 4.

Were this a tropical storm then an alternate to the dew point transposition adjustment may apply. The alternate, an adjustment for distance-from-coast is described in section 2.4.4.

3. DETAILS OF ANALYSIS

3.1 Minimum Envelopes

All available storm rainfall values that could possibly give highest or near highest values were adjusted and transposed. A total of 30 maps were then prepared showing these highest values, either from adjusted storms in

Table 2.--Example of computations of moisture maximization and transposition adjustments. [Warner, Okla. storm, May 6-12, 1943 (51,800 km²) 24 hours]

Location	(1)		(2)		(3)		(4)
	Maximum dew point °F (°C)		w_p 1000 mb (100 kPa) to 200 mb (20 kPa) in. (mm)		(a) (moisture max.)	(b) (transposition)	Max. moist. and trans. adjust- ment factor (col. 3a x col. 3b)
in place	77	(25.0)	3.191	(81.05)	$\frac{w_p \text{ (max.)}}{w_p \text{ (storm)}} = \frac{3.191}{2.268}$	-----	1.41
A*	75	(23.9)	2.896	(73.56)	$\frac{w_p \text{ (max.)}}{w_p \text{ (storm)}} = \frac{3.191}{2.268}$	$\frac{w_p \text{ (max.A)}}{w_p \text{ (max.)}} = \frac{2.896}{3.191}$	1.28
B	73	(22.8)	2.626	(66.70)	$\frac{w_p \text{ (max.)}}{w_p \text{ (storm)}} = \frac{3.191}{2.268}$	$\frac{w_p \text{ (max.B)}}{w_p \text{ (max.)}} = \frac{2.626}{3.191}$	1.16
C	78	(25.6)	3.349	(85.06)	$\frac{w_p \text{ (max.)}}{w_p \text{ (storm)}} = \frac{3.191}{2.268}$	$\frac{w_p \text{ (max.C)}}{w_p \text{ (max.)}} = \frac{3.349}{3.191}$	1.48
D	76	(24.4)	3.041	(77.24)	$\frac{w_p \text{ (max.)}}{w_p \text{ (storm)}} = \frac{3.191}{2.268}$	$\frac{w_p \text{ (max.D)}}{w_p \text{ (max.)}} = \frac{3.041}{3.191}$	1.34

* Points to which storm was transposed (see fig. 4).

† Storm dew point is 70°F (21.1°C); $w_p = 2.268$ in. (57.61 mm).

Table 3.--Example of total storm adjustments. [Warner, Okla., storm, May 6-12, 1943 for 20,000 mi² (51,800 km²) 24 hours]

Location	(1)	(2)		(3)	(4)	
	Adjustment factor (for moisture maximization and transposition, from table 2, col. 4)	Elevation in gentle upslope region ft	(m)	Gentle upslope adjustment factor	Adjusted 20,000 mi ² (51,800 km ²) 24-hr depth [†] in.	(mm)
in place	1.41	1,000	(305)	none	8.6	(218)
A	1.28	2,000	(610)	0.92	7.2	(183)
B [#]	1.16	—		—	7.1	(180)
C [#]	1.48	—		—	9.0	(229)
D	1.34	1,000	(305)	none	8.2	(208)

[†] Observed depth for 20,000 mi² (51,800 km²) and 24 hours = 6.1 in. (155 mm).

[#] Beyond gentle upslope region.

place or transposed to their outer limits, for 10, 200, 1,000, 5,000, 10,000, and 20,000 mi² (26, 518, 2,590, 12,950, 25,900, and 51,800 km²) for durations of 6, 12, 24, 48, and 72 hours.

Less detailed maps and analyses were prepared for 50,000-mi² (129,500-km²) areas to incorporate the influence of possible extreme values for this area size on areas \leq 20,000 mi² (51,800 km²). Similarly, rainfall values out to 96 hours were considered to take into account the effects of these extremes on rainfalls for durations of \leq 72 hours.

Smooth minimum enveloping isohyets were drawn to the data on each map. These envelopes introduced some regional smoothing. Guidance in determining the general shape and gradients of the analysis came from evaluating numerous other kinds of rainfall data, as follows:

a. Regional patterns of storms plotted in place. For selected areas and durations covered by this report, two sets of maps were developed showing the smooth envelopment of highest areal rainfalls where they occurred. One set was based on observed values and the other on moisture maximized values. Without storm transposition, these maps come close to representing regional variations and gradients of actual storms. The magnitude of PMP must still be determined after storm transposition.

Figures 5 and 6 are examples of data and analyses of observed and moisture maximized rainfall respectively for 10,000-mi² (25,900-km²) areas for 24-hr duration. Storms are identified in tables on both figures. (Many of these storms do not appear in the appendix since transposition of storms give far greater depths.) Figure 5 shows a steep rainfall gradient in central Texas. A similar gradient was maintained in the final product. The trend for higher moisture maximized values (fig. 6) in the Northern Plains States relative to values to the east and west was also maintained in the PMP.

b. Greatest monthly precipitation. Useful guidance, especially appropriate for the larger areas and longer durations, came from a map showing the one greatest average monthly rainfall of record for the period 1931-60 for each State climatic division (U.S. Weather Bureau 1963). These averages are the average of station precipitation within each division for each month of record. The highest of the 360 averages for each division were plotted on a map and analyzed. The data, rounded to the nearest inch for convenience, and the analysis are shown in figure 7.

The smooth analysis takes into account moisture sources and does not allow extreme variation in gradients. The orographically increased 12-in. (305-mm) rainfall for the Black Hills, South Dakota area has been undercut. Some noteworthy features of the map are:

1. Some of the greatest depths along the east slopes of the Appalachians are approximately of the same magnitude as those along the Atlantic coast.




Figure 5.--Envelopment of 24-hr observed storm rainfall (in.) in place of occurrence for 10,000 mi² (25,900 km²).




Figure 6.--Envelopment of 24-hr moisture maximized storm rainfall (in.) in place of occurrence for 10,000 mi² (25,900 km²).




Figure 7.--Envelopment of greatest average monthly precipitation (in.) for State climatic divisions (1931-60).

2. Lower values south of Lake Erie extend southward along the west slopes of the Appalachians.
3. Highest rainfall values are found in the lower Mississippi River Valley.
4. There is a decrease approaching the Continental Divide.
5. There is little difference in values along the entire east coast.

There are some limitations to these mapped greatest monthly values as guidance to regional variation of PMP. The size of the State climatic divisions varies from about 500 to 36,000 mi² (1,295 to 93,200 km²), averaging approximately 10,000 mi² (25,900 km²). All other factors being equal, such as storm centering, etc., the larger the division, the lower the rainfall depth. Additionally, monthly totals may not be representative of 3-day totals.

c. Greatest weekly rainfall. Another guide to regional patterns of PMP, similar to the greatest monthly rainfall averages, is the greatest weekly rainfall averages for climatic divisions. These averages were extracted from tabulation of the average precipitation over each division for each week of the period 1906-35 (McDonald 1944). Similar weekly averages are not readily available for recent years. The climatic divisions for this data set are different from those showing monthly precipitation. The weekly climatic divisions vary in size from 5,000 to 65,000 mi² (12,950 to 168,300 km²) averaging about 20,000 mi² (51,800 km²).

Figure 8 shows these highest average rainfalls for each climatic division. As in the monthly analysis, rainfall for the division including the Black Hills has been undercut. The enveloping lines have many of the same features as the highest monthly precipitation map: A trough of low values in the Great Lakes region, isolines oriented north-south near the Continental Divide, and a region of higher values extending into the Northern Plains. Maximum depths occur along the gulf coast in the states of Mississippi, Alabama, and Florida. The large areas and long durations detract from use of these data but to a lesser degree than the monthly data.

d. Maximum 1-day station rainfall. Another guide to regional PMP isohyets, especially useful for the small areas and short durations, is from maximum 1-day station rainfalls of record (Jennings 1952). These have been updated through 1970. Figure 9 shows the highest recorded station value for each State climatic division. The shape of enveloping lines drawn to these data (fig. 9) gave clues to the location of tight or loose rainfall gradients. Some features of note: An extension or bulge to the northwest into Montana, a dip in the Great Lakes region relative to values to the east and west, and similar magnitudes in the envelopment along the coast from southern Texas through Florida.




Figure 8.--Envelope of greatest average weekly precipitation (in.) for State climatic divisions (1906-35).




Figure 9.--Envelope of the greatest 24-hr station precipitation (in.) within each State climatic division (through 1970).

Another map (not shown) was developed of maximum observed 24-hr station rainfall amounts (Corps of Engineers, U.S. Army 1945-). These data include supplementary rainfall data from surveys after major storms that are often several times greater than amounts measured at nearest regular reporting stations. The general shape and gradients of isohyets for that map were not greatly different from those shown on figure 9, with the exception that the enveloping isohyets near the eastern seaboard paralleled the coast.

e. Maximum persisting dew points. Regional distribution of maximum persisting 12-hr dew points (Environmental Data Service 1968) is an important index to rainfall potential. Use of these charts (not shown) for storm transposition already to some extent incorporates their variation. Many of the features of the dew point charts can be seen in the resulting PMP maps. Examples are the east-west gradients in values near the western boundary of the study area, higher values bulging towards the northwest into the Northern Plains, southwest-northeast orientation of isolines along the Atlantic coast, and a dip or lowering of values near the Great Lakes.

f. Station 100-yr precipitation. Maps of station 100-yr 24-hr precipitation (Hershfield 1961) and 100-yr 48-hr precipitation (Miller 1964) were inspected for useful clues to the regional variation for small area rainfall. Frequencies are perhaps better than maximum 1-day rainfalls in that differences due to varying lengths of record from station to station are normalized. High 100-yr return-period precipitation centers show up along the Appalachians. Other features of the frequency map are isolines paralleling the Gulf of Mexico and Atlantic coasts, almost north-south orientation of isolines near the eastern slopes of the Continental Divide, and lower values in the Great Lakes region as compared to those to the east and west.

g. Regional patterns of other indices. Because thunderstorms, hail, and tornadoes are often associated with major rainfalls, patterns of the occurrences of these phenomena can serve as indices to regional variation of PMP. Regional distributions of these weather phenomena (U.S. Weather Bureau 1969) show several important features, such as maximum occurrence in Oklahoma, a moderately reduced occurrence along the northern Appalachians, and lines of equal occurrences generally parallel to the Rio Grande in Texas. Regional patterns of cloud heights as determined from radar echoes east of the Continental Divide for the period 1962-67 (Grantham and Kantor 1968) support isolines generally parallel to the Continental Divide.

Using these indices, a regionally smooth set of minimum envelopes were drawn to the adjusted rainfall data. Figure 10 is an example for 24 hours $10,000 \text{ mi}^2$ ($25,900 \text{ km}^2$). Values shown, identified by storm index numbers, are moisture maximized rainfall depths in place or at their critical transposed locations.

3.2 Special Problems

3.2.1 Introduction

The analyses of minimum envelopes necessarily required some departures to seemingly objective procedures discussed in previous sections. Such




Figure 10.--Example of minimum smooth envelope of moisture maximized rainfall, in place and transposed. [24 hr/10,000 mi² (25,900 km²) in inches]

departures were necessary to avoid undue emphasis and/or reliance on individual storm values obtained by storm transposition and storm adjustment. These departures involved decisions on "how far" (with respect to transposition) and "how much" (with respect to maximization) that can only be answered by storm experience and meteorological judgment. The most outstanding departures from the objective procedures are explained in this section.

3.2.2 Adjustments Greater Than 50 Percent

The relations among various meteorological parameters that contribute to heavy rainfalls are not yet fully understood nor measured.

Extreme increases in one parameter, say moisture, could well counteract other important factors; therefore, total storm adjustments that increased rainfalls by more than 50 percent were given further attention. If a storm had an adjustment giving an increase greater than 50 percent, but its adjusted depth was supported quite closely by surrounding storm depths with only moderate adjustments, the high adjusted value was accepted. If a high adjustment (greater than 50 percent) gave an amount that stood out among all other storms in a region, this depth was undercut. Undercutting was limited to a value obtained by multiplying the observed depth by 150 percent.

The moisture adjustments for the storms listed in the appendix give a measure of how important this constraint is to the study. Eight of the 53 storms have moisture adjustments greater than 150 percent, ranging from 155 to 189 percent. Six of these high adjustments give rainfall depths that are supported by other storms in the general region with adjustments less than 150 percent. The two exceptions, storm index numbers 8 and 26, have adjustments of 163 and 189 percent, respectively. For storm No. 8, the most critical depth was at 20,000 mi² (51,800 km²) for 12 hours. We used an adjustment of 150 percent giving 8.5 in. (216 mm) and analyzed for this depth. For storm No. 26, the most critical depth was at 10,000 mi² (25,900 km²) for 6 hours. We accepted a value of 7.5 in. (190 mm) which was supported by other storm depths. The 7.5 in. (190 mm) is 160 percent of the observed depth.

3.2.3 Colorado Storm, May 30-31, 1935

This storm produced two intense rainfall centers (fig. 1), one at Cherry Creek, Colo. (No. 55) and the other at Hale, Colo. (No. 56). The Cherry Creek depths were not used since it is near very steep slopes that could have increased the rainfall. Only the areal average rainfall surrounding the Hale center was used. The record-breaking cold air mass associated with this storm could not reasonably occur 15 days later into the warm season. Therefore, the normal procedure of adjusting storms 15 days into the warm season (section 2.3.4) was not applied.

3.2.4 Smethport, Pa. Storm, July 17-18, 1942

The in-place moisture maximized rainfall values for the Smethport, Pa. storm (No. 74) of July 17-18, 1942 (fig. 1), were slightly undercut for 6, 12, and 24-hr durations for 10-mi² (26-km²) areas. The greatest undercutting

(7 percent) was for 6 hours. The slight undercutting avoids excessive envelopment of all other data in a large region surrounding the Smethport location.

3.2.5 Yankeetown, Fla. Storm, September 3-7, 1950

The last exception deals with the rainfall associated with the Yankeetown, Fla. storm (No. 85) of September 3-7, 1950. Inland transposition of this storm incorporates the distance-from-coast adjustment already discussed. This storm is important because it provides the greatest observed rainfall depths in the United States for areas from 10 to 2,000 mi² (26 to 5,180 km²) and durations from 18 to 72 hours.

The outstanding rains of the Yankeetown storm have been attributed to the looping track of the hurricane just off the western coast of Florida, causing the downpour to be concentrated in space. Looping has been observed in many tropical storms along the Atlantic and gulf coasts, summarized by Cry (1965) and updated. For the period 1901-76, 58 storm tracks show looping or points of recurvature (the latter having an equivalent effect as looping in concentrating rainfall if the storm is moving slowly) over water or land surfaces within 60 n.mi. (111 km) of the coast from Brownsville, Tex., to Eastport, Maine. It is assumed that if other major rain-producing tropical storms had looped or recurved while crossing the coast, the resulting areal rainfall would have been more concentrated.

A partial check of this assumption was made by computing hypothetical areal rainfall depths for two major gulf coast tropical storms (Hurricane Carla, September 10-13, 1961, and the hurricane of August 6-9, 1940) assuming they had looped near the coast. The forward speed of each storm was reduced to the speed of the Yankeetown storm. Assuming the rainfalls in these storms were then closely associated with the storm tracks, recomputation of rain depths gave values of approximately the same magnitude as the Yankeetown storm.

It can be hypothesized that the Yankeetown rainfall (centered near latitude 29°N on the west coast of Florida) was enhanced because air trajectories from both the Gulf of Mexico and the Atlantic Ocean allowed greater transport of moisture into the storm than would be possible along other sections of the gulf coast. To check this hypothesis, the moisture inflow associated with Easy (the storm giving the Yankeetown rainfall) was compared with that of two other tropical storms, Carla (September 1961) and Beulah (September 1967). These were large rain producers near the coast of Texas.

Lacking psychrometric data over the water surface, the portion of the tropical storms that extended over land during the period of heavy rainfall were examined. Dew points were compared, both at the surface and 850-mb (85-kPa) level, at equal distances from the centers of each hurricane. Both Carla and Beulah recorded approximately the same or higher dew points than those found in Easy. The rate of drying in Easy as the moist air from the Atlantic Ocean flowed westward over land was approximately the same as that in the westward flow of moist air from the Gulf of Mexico for Carla and Beulah. Because of these considerations, it was decided to transpose the Yankeetown rainfall along the entire gulf coast of the United States.

The northward transposition limits of Yankeetown along the Atlantic coast has been set as Cape Hatteras, N.C. Remaining is the problem of determining the adjustment for transposition to this point. If no downward adjustment is used, there would be either a large over-envelopment of all other storm rainfall data along the coast or an extreme gradient to the north of Cape Hatteras. The standard transposition adjustment based on maximum dew points extended over the ocean surface (U.S. Weather Bureau 1952) would give no decrease to Cape Hatteras since the 78°F (25.6°C) value (the highest maximum dew point considered) is located north of this point.

As an alternate, the variation in sea-surface temperatures was used. These temperatures, with some overland modification, set upper limits to the amount of water vapor the atmosphere can hold. Both the mean and 95th percentile sea-surface temperatures (U.S. Naval Oceanographic Office 1967) were analyzed for September, the month of the Yankeetown storm. The temperatures were averaged within 400-mi (644-km) diameter circles off the coast from 29° to 38° N latitude. This size circle covers an area considered representative of the area from which a large tropical cyclone could process moisture in 24 hours (Gilman and Peterson 1958). The average temperature determined the precipitable water (w_p) assuming saturation and a pseudo-adiabatic lapse rate through the atmosphere. Figure 11 shows the relation between latitude and w_p in percent of the w_p value at 29°N latitude. A relation based on the average of the w_p for the mean temperature and the 95th percentile temperature was the basis for adjustment of the Yankeetown storm. This gives a 15-percent reduction for transposition to Cape Hatteras. Transpositions farther to the north using this relation gives values that are consistent with other adjusted storm depths.

The latitudinal adjustment for Yankeetown was also applied to the transposition of all tropical storms located near the Atlantic coast south of Cape Hatteras, N.C. None of these storms, so adjusted, affected the minimum envelopes.

3.3 Consistency Checks

3.3.1 Introduction

The minimum PMP maps (fig. 10) were checked for consistency. Anomalies to smooth regional patterns of PMP were eliminated unless there was a meteorological explanation. Consistency in depth duration and depth areal relations at various locations in the study region was maintained. The checks usually resulted in raising the minimum PMP values, although envelopment was minimized.

For the checks, a 2-by-2 degree latitude and longitude grid (154 points) was established. Values were read for each grid point from the minimum PMP maps. Computer techniques aided in processing the large volume of data.




Figure 11.--Adopted transposition adjustment along the Atlantic coast for the Yankeetown, Fla. storm, September 3-7, 1950.

3.3.2 Variation of Incremental PMP with Area Size

A constraint in this study was to maintain the same or lesser incremental PMP with increasing area size. For example, the incremental PMP from 12- to 18-hr duration (PMP for 18 hr minus PMP for 12 hr) could not increase with increasing area size. Individual storm depth-area-duration (D-A-D) relations can and do show increasing incremental rainfall with increasing area size. This is so because control of the D-A-D curves of rainfall can come from several different centers for, say, the 12- and 18-hr maximum areal rainfall depths. Accepted application of PMP to a drainage has been through use of incremental PMP isohyets. Such isohyets would not have internal consistency if incremental PMP increases with increasing area size.

3.3.3 Consistency in Depth-Area-Duration Relations

Depth-area-duration (D-A-D) plots of PMP, with area and with duration as the third parameter, were made for each of the 154 grid points and then smoothed. Figure 12 is an example of depth-duration smoothing and figure 13 an example of depth-area smoothing. These examples show the final values after all adjustments were applied. For these plots, depth was expressed in percent of the rainfall for 10 mi² (26 km²) for 72 hours.

Analyses of the 308 D-A-D plots flagged inconsistencies such as incremental PMP increasing with increasing area size or incremental PMP for a certain area size not decreasing with duration. They also ensured smooth envelopes of D-A-D rainfall values. Such smoothness takes into account the strong probability that nature has not provided maximum depths for the entire range of areas and durations covered by this report.

3.3.4 Cross Section Checks

Another check was made on the gradients of PMP along cross sections of the study region. Gradients established by use of guidance material (section 3.1) and the just described D-A-D smoothing did not necessarily correct regional inconsistencies.

Six north-south and five east-west cross sections of PMP depths were made running along the 103°, 97°, 91°, 85°, 79° and 71° longitude and the 47°, 43°, 39°, 35°, and 31° latitude lines. Two types of plots were made. In the first set, durations were held constant allowing checks on consistency of areal rainfall magnitudes. An example of this type is given in figure 14. In the second type, areas were held constant while durational values were checked. An example of these cross sections is figure 15.

3.3.5 Rainfall Difference Check

Another check was on the differences in PMP between standard durations and between standard area sizes. At each of the 154 grid points, the difference between 24-hr PMP and the 6-hr PMP and the difference between the 72-hr PMP and the 24-hr PMP were computed for each of three area sizes [10, 1,000, and 20,000 mi² (26, 2,590, and 51,800 km²)]. Likewise areal differences in PMP [10-mi² (26-km²) PMP minus 1,000-mi² (2,590-km²) PMP and 1,000-mi² (2,590-km²) PMP minus 20,000-mi² (51,800-km²) PMP] were computed for each of three durations (6, 24, and 72 hours). Mapped values of these differences were analyzed and PMP maps modified when inconsistent differences occurred from one location to another. An example of final differences between 24- and 6-hr values for 20,000 mi² (51,800 km²) is shown in figure 16.

3.3.6 Rainfall Ratio Check

We also maintained consistency in regional trends of durational rainfall ratios (6/24 and 24/72 hour) for areas of 10, 200, 1,000, 5,000, 10,000, and 20,000 mi² (26, 518, 2,590, 12,950, 25,900, and 51,800 km²). Similarly, we maintained consistency in regional trends of areal rainfall ratios




Figure 12.--Example of depth-duration smoothing. [Grid point 39°N, 89°W]




Figure 13.--Example of depth-area smoothing. [Grid point 39°N, 89°W]




Figure 14.--Example of cross-section smoothing--constant duration. [Depth vs. latitude along 91°W longitude for 24 hr]




Figure 15.--Example of cross-section smoothing--constant area. [Depth vs. latitude along 91°W longitude for 1,000 mi² (2,590 km²)]




Figure 16.--Example of checks of durational difference in PMP. [24-hr PMP minus 6-hr PMP (in.) for 20,000 mi² (51,800 km²)]

[20,000/1,000, 20,000/10, 10,000/10, and 1,000/10 mi² (51,800/2,590, 51,800/26, 25,900/26, and 2,590/26 km²)] for durations of 6, 24, and 72 hours. These ratios were allowed to vary from region to region; however, smooth transitions were maintained.

3.3.7 PMP Maps

Modifications made for any one of the consistency checks (sections 3.3.2 to 3.3.6) necessarily required replotting and reanalysis of PMP. The resulting PMP maps covering durations of 6, 12, 24, 48, and 72 hours for areas of 10, 200, 1,000, 5,000, 10,000, and 20,000 mi² (26, 518, 2,590, 12,950, 25,900, and 51,800 km²) are given in figures 18 through 47.

4. EVALUATION OF GENERALIZED PMP CHARTS

4.1 Degree of Envelopment

Evaluation of how much effect storm transposition and modifications due to consistency checks have on the PMP estimates is of interest. For such an evaluation, the magnitudes of moisture maximized storm depths where they occurred (in place) were compared with the PMP estimates for these locations. The comparison of in-place values rather than transposed values circumvents the judgmental decisions on storm transpositions and adjustments.

Table 4 lists the storms that have in-place moisture maximized rainfalls within 10 percent of PMP. Observed maximum areal average rainfall depths for these storms are found in the appendix. Only the most critical rainfall depth (for the duration and area coming closest to PMP) was used in the table. The table also gives the moisture adjustment for each storm.¹

Table 4 shows that four storms give in-place moisture maximized rainfall greater than PMP. Three of these storms (Nos. 2, 51, and 77) were undercut by < 2 percent. The moisture maximized depth for the storm (No. 2) of May 30-June 1, 1889 [20,000 mi² (51,800 km²) for 48 hours] of 11.4 in. (290 mm) was undercut by 0.2 in. (5 mm). Similarly for the storm (No. 51) of September 16-17, 1932, the depth [10,000 mi² (25,900 km²) for 12 hours] of 7.0 in. (178 mm) was undercut by 0.1 in. (2.5 mm), and the depth for the storm (No. 77) of May 6-12, 1943 [20,000 mi² (51,800 km²) for 48 hours] of 14.1 in. (358 mm) was undercut by 0.1 in. (2.5 mm). Because of smoothing and other constraints to PMP, increasing the values for these area sizes and durations by only 0.1 or 0.2 in. (2.5 or 5 mm) means much more significant envelopment at other areas and durations. This is particularly so with regard to the constraint on incremental PMP with respect to increasing area size (section 3.3.2).

¹The cases with moisture adjustments greater than 150% are supported by rainfalls in other nearby storms with adjustments less than 150% (section 3.2.2).

Table 4.--Storms that give moisture maximized rainfall within 10 percent of PMP for at least one area size and duration.

<u>Storm Index No.</u> (see fig.1)	<u>Storm Assignment No.</u>	<u>Date</u>	<u>In-place Moisture Adj. (%)</u>	<u>Ratio: Moist. Max. Rainfall*/PMP</u>
74	OR9-23	7/17-18/1942	110	1.07
2	SA1-1	5/30-6/1/1889	163	1.02
51	NA1-20B	9/16-17/1932	127	1.01
77	SW2-20	5/6-12/1943	141	1.01
88	SW3-22	6/23-28/1954	116	1.00
3	MR4-3	6/4-7/1896	155	1.00
47	LMV2-20	3/11-16/1929	134	1.00
85	SA5-8	9/3-7/1950	110	1.00
14	UMV2-5	6/9-10/1905	148	.99
7	GM3-4	6/27-7/1/1899	116	.98
87	MR10-8	6/7/1953	171	.98
42	MR4-24	9/17-19/1926	134	.98
22	UMV1-11A	7/18-23/1909	134	.98
68	NA2-4	9/1/1940	122	.98
97	SW3-24	9/19-24/1967	116	.97
69	SW2-18	9/2-6/1940	141	.97
54	LMV4-21	5/16-20/1935	128	.97
8	LMV2-5	4/15-18/1900	150	.97
1	OR9-19	9/10-13/1878	122	.97
100	NA2-24A	6/19-23/1972	121	.97
20	SW1-11	10/19-24/1908	163	.95
53	SW2-11	4/3-4/1934	149	.94
11	GI4-9	10/7-11/1903	144	.94
56	--	5/30-31/1935	122	.93
26	LMV3-19	3/24-28/1914	150	.93
44	NA1-17	11/2-4/1927	148	.93
65	--	6/19-20/1939	128	.92
86	MR10-2	7/9-13/1951	128	.91
17	GM3-14	8/4-6/1906	121	.91
67	MR4-5	6/3-4/1940	163	.90

* For the standard area size and standard duration giving the highest ratio.

Of more concern was the undercutting of the July 17-18, 1942 storm (No. 74) centered at Smethport, Pa. This storm's in-place moisture maximized 10-mi² (26-km²) 6-hr depth of 27.2 in. (690 mm) is undercut by 7 percent. Without this undercutting there would be excessive envelopment in a large region surrounding the Smethport location for numerous area sizes and durations.

Figure 1 identifies the 30 storms listed in table 4. One of these storms (No. 97) is centered outside the study region. This storm is included because it produced important large-area rainfalls that extended into the United States. Considering deficiencies in the total storm sample, the distribution of the 30 storms indicates reasonably comparable PMP over the study region. In our judgment, these comparisons indicate that envelopment and smoothing steps did not raise the PMP values excessively.

4.2 Use of PMP for all Durations in one PMP Storm

4.2.1 Introduction

In application of the all-season PMP values, a concern is whether PMP for all durations for any given area size can occur in one PMP storm. It is possible that the storms controlling at short durations could be different in type or season than those controlling at long durations. If this should be the case, use of PMP values for all durations in one PMP storm would be unrealistic. A test was made to determine if such cross season or different storm type control exists for a given area size. We labeled this test "storm commonality."

4.2.2 Storm Commonality Test

A clearcut solution of the problem would be to type each storm used in the report. The difficulty with this approach is that whatever typing system is used, many storms would not easily fit into distinct types. This is particularly so because we are dealing with extreme events that are difficult to categorize just because they are rare.

Storm rainfall data were surveyed to see if within seven regions the greatest or near greatest depths for three durations (6, 24, and 72 hours) came from the same storm. Each standard area size [10, 200, 1,000, 10,000, and 20,000 mi² (26, 518, 2,590, 25,900, and 51,800 km²)] was considered separately.

Boundaries for the seven regions are shown in figure 17. For each zone and area size, all the moisture maximized rainfall depths that came within 15 percent of the greatest depth for each duration were determined. If among these data a common storm showed up for all three durations, we assumed "storm commonality" was fulfilled.

Of 35 cases (7 regions and 5 area sizes), 26 met the commonality requirement. The nine exceptions are listed in table 5.




Figure 17.---Regions for storm commonality test.

Table 5.--Exceptions to "storm commonality"

Region	Area Size	
	mi ²	(km ²)
I	10; 200	(26; 518)
III	1,000	(2,590)
IV	200; 10,000; 20,000	(518; 25,900; 51,800)
VI	200	(518)
VII	200; 1,000	(518; 2,590)

Examination of these nine exceptions showed that seven of them would meet the commonality requirement if values from different storms, still within 15 percent of the greatest value but definitively of the same storm type, were allowed to be combined.

The two remaining exceptions are in zone IV for 10,000 and 20,000 mi² (25,900 and 51,800 km²). For 10,000 mi² (25,900 km²) we obtain storm commonality if the criteria lowered to 19 percent of the greatest moisture maximized depth. For 20,000 mi² (51,800 km²) storm commonality was obtained if 23 percent of the greatest depth were allowed.

In the test for "storm commonality", our storm sample for some area sizes and zones of necessity must deal with storms of less than PMP magnitude. The thresholds set for the data samples were arbitrary; however, if full transposition of the storms were allowed (section 2.4), the thresholds used could have been much more stringent and still show "storm commonality".

We conclude there is not undue maximization in the region covered by this study to assume PMP for all durations can be used in one PMP storm for any drainage size.

5. USE OF PMP CHARTS

The set of PMP maps of this report are given in figures 18 through 47. Generalized PMP estimates for any drainage in the United States, east of 105 degrees longitude, for drainages between 10 and 20,000 mi² (26 and 51,800 km²) and for durations from 6 to 72 hours can be determined by following these steps:

- a. Determine the geographic location and size of the drainage under study.
- b. From the PMP maps (figures 18 through 47) record the average PMP depths for the basin location. (See section 1.4.2 concerning estimates located in stippled areas.) It is not necessary to use each PMP map, but we recommend that PMP values from at least four of the six area sizes closest to the basin size be considered. For these areas, tabulate PMP values for all durations, 6, 12, 24, 48, and 72 hours. Example: If the drainage covers

11,300 mi² (29,250 km²) tabulate PMP for 1,000, 5,000, 10,000, and 20,000 mi² (2,590, 12,950, 25,900, 51,800 km²) for 6, 12, 24, 48, and 72 hours.

c. Plot the PMP depths on semilog paper (depth vs. area). Draw smooth duration curves through the plotted data points (as in fig. 13, except that the depths should be plotted directly in inches).

d. From the depth-area-duration graph of step c, determine the PMP depths at the basin size for each duration.

e. Plot these basin area PMP values on linear graph paper (depth vs. duration). Draw a smooth curve connecting these points. Interpolate along this curve to obtain PMP depths for other durations, if required.

NOTE: To determine PMP for a basin located in one of the Gulf Coast States south of the last PMP isoline shown (for example, a basin in Florida), use the PMP values given by the southernmost isolines.

ACKNOWLEDGMENTS

The authors express their appreciation to Mr. John F. Miller, Chief of the Water Management Information Division, Office of Hydrology, NWS, and Dr. Vance A. Myers, Chief, Special Studies Branch, for their guidance, comments and editorial review of the manuscript. We appreciate the large amount of technical assistance from Miriam McCarty, Marion Choate, Wallace Brewer, Ray Evans, Roxanne Johnson and Teresa Johnson, and we thank Virginia Hostler, Cora Ludwig, and Clara Brown for typing the report.

REFERENCES

- American Meteorological Society, 1959: *Glossary of Meteorology*. Boston, Mass., 638 pp.
- Atmospheric Environment Service, 1961-: *Storm Rainfall in Canada*, Downsview, Ontario, Canada.
- Corps of Engineers, U.S. Army, 1945-: *Storm Rainfall in the United States*, Washington, D.C.
- Cry, George W., 1965: Tropical cyclones of the North Atlantic Ocean, tracks and frequencies of hurricanes and tropical storms, 1871-1963. *Technical Paper* No. 55, Weather Bureau, U.S. Department of Commerce, Washington, D.C., 148 pp.
- Environmental Data Service, 1968: Maximum persisting 12-hour 1000-mb dew points (°F) monthly and of record. *Climatic Atlas of the United States*, Environmental Science Services Administration, U.S. Department of Commerce, Washington, D.C., pp. 59-60.
- Gilman, Charles S., and Peterson, Kendall R., 1958: Northern floods of 1955: Meteorology of the floods. *Journal of the Hydraulics Division*, Vol. 84, No. HY3, pp. 1661-1 to 1661-37.
- Goodyear, Hugo V., and Riedel, John T., 1965: Probable maximum precipitation Susquehanna River drainage above Harrisburg, Pennsylvania. *Hydrometeorological Report* No. 40, Weather Bureau, U.S. Department of Commerce, Washington, D.C., 70 pp.
- Grantham, Donald D., and Kantor, Arthur J., 1968: Climatological distributions and range effects on height detection of high altitude radar echoes. *Proceedings of the Thirteenth Radar Meteorological Conference*, 20-23 August 1968, McGill University, Montreal, Canada, American Meteorological Society, Boston, Mass., pp. 298-303.
- Hansen, E.M., Schwarz, Francis K., and Riedel, John T., 1977: Probable maximum precipitation estimates, Colorado River and Great Basin drainages. *Hydrometeorological Report* No. 49, National Weather Service, National Oceanic and Atmospheric Administration, U.S. Department of Commerce, Silver Spring, Md., 161 pp.
- Hansen, E.M., and Schreiner, Louis C.,: Application of probable maximum precipitation estimates, United States east of the 105th meridian. *Hydrometeorological Report* No. 52, National Weather Service, National Oceanic and Atmospheric Administration, U.S. Department of Commerce, Silver Spring, Md. (in preparation).
- Hershfield, David M., 1961: Rainfall frequency atlas of the United States for durations from 30 minutes to 24 hours and return periods from 1 to 100 years. *Technical Paper* No. 40, Weather Bureau, U.S. Department of Commerce, Washington, D.C., 115 pp.

- Jennings, Arthur H., 1952: Maximum 24-hour precipitation in the United States. *Technical Paper* No. 16, Weather Bureau, U.S. Department of Commerce, Washington, D.C., 284 pp.
- McDonald, Willard F., 1944: *Average Precipitation in the United States for the Period 1906 to 1935 Inclusive*. Weather Bureau, U.S. Department of Commerce, Washington, D.C., 69 pp.
- Miller, John F., 1963: Probable maximum precipitation and rainfall-frequency data for Alaska. *Technical Paper* No. 47, Weather Bureau, U.S. Department of Commerce, Washington, D.C., 69 pp.
- Miller, John F., 1964: Two- to ten-day precipitation for return periods of 2 to 100 years in the contiguous United States. *Technical Paper* No. 49, Weather Bureau, U.S. Department of Commerce, Washington, D.C., 29 pp.
- Paulhus, Joseph L.H., and Gilman, Charles S., 1953: Evaluation of probable maximum precipitation. *Transactions of the American Geophysical Union*, Vol. 34, No. 5, Washington, D.C., pp. 701-708.
- Riedel, John T., Appleby, James F., and Schloemer, Robert W., 1956: Seasonal variation of the probable maximum precipitation east of the 105th meridian for areas from 10 to 1000 square miles and durations of 6, 12, 24, and 48 hours. *Hydrometeorological Report* No. 33, Weather Bureau, U.S. Department of Commerce, Washington, D.C., 58 pp.
- Riedel, John T., Schwarz, Francis K., and Weaver, Robert L., 1969: Probable maximum precipitation over South Platte River, Colorado, and Minnesota River, Minnesota. *Hydrometeorological Report* No. 44, Weather Bureau, Environmental Science Services Administration, U.S. Department of Commerce, Washington, D.C., 114 pp.
- Riedel, John T., 1973: Probable maximum precipitation and snowmelt criteria for Red River of the North above Pembina, and Souris River above Minot, North Dakota. *Hydrometeorological Report* No. 48, National Weather Service, National Oceanic and Atmospheric Administration, U.S. Department of Commerce, Silver Spring, Md., 69 pp.
- Schoner, Robert W., 1968: Climatological regime of rainfall associated with hurricanes after landfall. *ESSA Technical Memorandum* WBTM-ER-29, Weather Bureau, Environmental Science Services Administration, U.S. Department of Commerce, Garden City, N.Y., 25 pp.
- Schwarz, Francis K., 1965: Probable maximum and TVA precipitation over the Tennessee River basin above Chattanooga. *Hydrometeorological Report* NO. 41, Weather Bureau, U.S. Department of Commerce, Washington, D.C., 148 pp.

- Schwarz, Francis K., 1967: The role of persistence, instability, and moisture in the intense rainstorms in eastern Colorado, June 14-17, 1965. *ESSA Technical Memorandum* WBTM HYDRO-3, Weather Bureau, Environmental Science Services Administration, U.S. Department of Commerce, Washington, D.C., 21 pp.
- Schwarz, Francis K., and Helfert, Norbert F., 1969: Probable maximum and TVA precipitation for Tennessee River basins up to 3000 square miles in area and durations to 72 hours. *Hydrometeorological Report* No. 45, Weather Bureau, Environmental Science Services Administration, U.S. Department of Commerce, Silver Spring, Md., 166 pp.
- Shipe, Albert P., and Riedel, John T., 1976: Greatest known areal storm rainfall depths for the contiguous United States. *NOAA Technical Memorandum* NWS HYDRO-33, National Weather Service, National Oceanic and Atmospheric Administration, U.S. Department of Commerce, Silver Spring, Md., 174 pp.
- U.S. Naval Oceanographic Office, 1967: Oceanographic Atlas of the North Atlantic Ocean, Section 2, physical properties. *Publication No. 700*, Oceanographic Office, Department of the Navy, Washington, D.C., 300 pp.
- U.S. Weather Bureau, 1946: Manual for depth-area-duration analysis of storm precipitation. *Cooperative Studies Technical Paper* No. 1, U.S. Department of Commerce, Washington, D.C., 82 pp.
- U.S. Weather Bureau, 1947: Generalized estimates of maximum possible precipitation over the United States east of the 105th meridian, for areas of 10, 200, and 500 square miles. *Hydrometeorological Report* No. 23, U.S. Department of Commerce, Washington, D.C., 77 pp.
- U.S. Weather Bureau, 1951: Tables of precipitable water and other factors for a saturated pseudo-adiabatic atmosphere. *Technical Paper* No. 14, U.S. Department of Commerce, Washington, D.C., 27 pp.
- U.S. Weather Bureau, 1952: Generalized estimates of maximum possible precipitation over New England and New York. *Hydrometeorological Report* No. 28, U.S. Department of Commerce, Washington, D.C., 14 pp.
- U.S. Weather Bureau, 1960: Generalized estimates of probable maximum precipitation for the United States west of the 105th meridian for areas to 400 square miles and durations to 24 hours. *Technical Paper* No. 38, U.S. Department of Commerce, Washington, D.C., 66 pp.
- U.S. Weather Bureau, 1961: Interim report probable maximum precipitation in California. *Hydrometeorological Report* No. 36, U.S. Department of Commerce, Washington, D.C. 202 pp.
- U.S. Weather Bureau, 1963: Decennial census of United States climate - monthly average for state climatic divisions, 1931-1960. *Climatology of the United States* No. 85, U.S. Department of Commerce, Washington, D.C.

- U.S. Weather Bureau, 1966: Probable maximum precipitation, northwest states. *Hydrometeorological Report* No. 43, Environmental Science Services Administration, U.S. Department of Commerce, Washington, D.C., 228 pp.
- U.S. Weather Bureau, 1969: Severe local storm occurrences, 1955-1967. *ESSA Technical Memorandum* WBTM FCST 12, Environmental Science Services Administration, U.S. Department of Commerce, Silver Spring, Md., 77 pp.
- Wiesner, Clarence J., 1970: *Hydrometeorology*. Chapman and Hall LTD., London, England, 232 pp.
- World Meteorological Organization, 1969a: Estimation of maximum floods. *WMO* No. 233, TP 126, *Technical Note* No. 98, Geneva, Switzerland, 288 pp.
- World Meteorological Organization, 1969b: Manual for depth-area-duration analysis of storm precipitation. *WMO* No. 129, Geneva, Switzerland, 114 pp.
- World Meteorological Organization, 1973: Manual for estimation of probable maximum precipitation. *WMO* No. 332, *Operational Hydrology Report* No. 1, Geneva, Switzerland, 190 pp.




Figure 18.--All-season PMP (in.) for 6 hr 10 mi² (26 km²).




Figure 19.--All-season PMP (in.) for 12 hr 10 mi² (26 km²).




Figure 20.--All-season PMP (in.) for 24 hr 10 mi² (26 km²).




Figure 21.--All-season PMP (in.) for 48 hr 10 mi² (26 km²).




Figure 22.--All-season PMP (in.) for 72 hr 10 mi² (26 km²).




Figure 23.--All-season PMP (in.) for 6 hr 200 mi² (518 km²).




Figure 24.--All-season PMP (in.) for 12 hr 200 mi² (518 km²).




Figure 25.--All-season PMP (in.) for 24 hr 200 mi² (518 km²).




Figure 26.--All-season PMP (in.) for 48 hr 200 mi² (518 km²).




Figure 27.--All-season PMP (in.) for 72 hr 200 mi² (518 km²).




Figure 28.--All-season PMP (in.) for 6 hr 1,000 mi² (2,590 km²).




Figure 29.--All-season PMP (in.) for 12 hr 1,000 mi² (2,590 km²).




Figure 30.--All-season PMP (in.) for 24 hr 1,000 mi² (2,590 km²).




Figure 31.--All-season PMP (in.) for 48 hr 1,000 mi² (2,590 km²).




Figure 32.--All-season PMP (in.) for 72 hr 1,000 mi² (2,590 km²).




Figure 33.--All-season PMP (in.) for 6 hr 5,000 mi² (12,950 km²).




Figure 34.--All-season PMP (in.) for 12 hr 5,000 mi² (12,950 km²).




Figure 35.--All-season PMP (in.) for 24 hr 5,000 mi² (12,950 km²).




Figure 36.--All-season PMP (in.) for 48 hr 5,000 mi² (12,950 km²).




Figure 37.--All-season PMP (in.) for 72 hr 5,000 mi² (12,950 km²).




Figure 38.--All-season PMP (in.) for 6 hr 10,000 mi² (25,900 km²).




Figure 39.--All-season PMP (in.) for 12 hr 10,000 mi² (25,900 km²).




Figure 40.--All-season PMP (in.) for 24 hr 10,000 mi² (25,900 km²).




Figure 41.--All-season PMP (in.) for 48 hr 10,000 mi² (25,900 km²).




Figure 42.--All-season PMP (in.) for 72 hr 10,000 mi² (25,900 km²).




Figure 43.--All-season PMP (in.) for 6 hr 20,000 mi² (51,800 km²).




Figure 44.--All-season PMP (in.) for 12 hr 20,000 mi² (51,800 km²).




Figure 45.--All-season PMP (in.) for 24 hr 20,000 mi² (51,800 km²).




Figure 46.--All-season PMP (in.) for 48 hr 20,000 mi² (51,800 km²).




Figure 47.--All-season PMP (in.) for 72 hr 20,000 mi² (51,800 km²).

APPENDIX -- MAXIMUM OBSERVED AREAL RAINFALL FOR IMPORTANT STORMS

The following is a list of observed maximum rainfall depths of the most important storms for selected area sizes and durations. Other information shown are:

- a. Storm index number. Used in this report for identification purposes.
- b. Storm assignment number (enclosed in parenthesis). This number is assigned by Corps of Engineers or Atmospheric Environment Service, Canada, for storm identification. Those storms without a storm assignment number refer to unofficial rainfall data acquired by the Hydrometeorological Branch.
- c. Date of storm.
- d. Location of storm rainfall center.
- e. In-place moisture adjustment of the storm.

The location of the rainfall centers, with storm index numbers, are shown in figure 1.

Conversions from English to the metric system for these tables:

$$1 \text{ in.} = 25.4 \text{ mm}$$

$$1 \text{ mi}^2 = 2.59 \text{ km}^2$$

APPENDIX - - IMPORTANT STORMS

STORM INDEX NO. 1 (OR 9-19) DATE 9/10-13/1878 RAINFALL CENTER JEFFERSON,OH MOIST.ADJ.=122

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS										
	6	12	18	24	30	36	48	60	66		
10	5.9	11.2	11.7	12.2	13.0	13.4	14.3	14.9	15.0		
100	5.8	10.9	11.6	12.1	12.7	13.2	14.1	14.6	14.7		
200	5.8	10.8	11.4	11.9	12.5	12.9	13.9	14.4	14.5		
1000	5.3	10.1	10.6	11.0	11.7	12.1	12.9	13.4	13.5		
5000	4.1	8.0	8.8	9.2	9.9	10.3	10.9	11.3	11.3		
10000	3.5	6.8	7.5	8.1	8.8	9.0	9.7	9.9	10.0		
20000	2.8	5.4	6.1	6.7	7.2	7.5	8.1	8.4	8.4		
50000	1.9	3.5	4.1	4.6	4.9	5.2	5.8	6.1	6.1		

STORM INDEX NO. 4 (UMV 1-2) DATE 7/18-22/1897 RAINFALL CENTER LAMBERT,MN MOIST.ADJ.=148

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS										
	6	12	18	24	30	36	48	60	72	96	
10	3.2	5.2	6.2	6.5	6.5	6.5	6.9	8.0	8.0	8.2	
100	3.1	4.8	6.0	6.3	6.3	6.3	6.8	7.9	7.9	8.2	
200	3.0	4.6	5.9	6.2	6.2	6.2	6.7	7.8	7.8	8.1	
1000	2.7	4.2	5.5	5.8	5.8	5.8	6.3	7.3	7.3	7.3	
5000	2.3	3.4	4.3	4.5	4.7	4.7	5.2	6.1	6.2	6.4	
10000	1.9	3.0	3.8	4.0	4.2	4.2	4.5	5.4	5.5	5.7	
20000	1.7	2.8	3.5	3.7	3.8	3.8	4.2	4.8	5.0	5.3	
50000	1.3	2.3	2.9	3.1	3.3	3.4	3.7	3.9	4.1	4.6	

STORM INDEX NO. 2 (SA 1-1) DATE 5/30-6/1/1889 RAINFALL CENTER WELLSBORO,PA MOIST.ADJ.=163

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS							
	6	12	18	24	30	36	48	
10	7.4	8.6	9.1	9.2	9.2	9.7	9.8	
100	7.2	8.3	8.9	9.0	9.0	9.5	9.6	
200	7.1	8.2	8.7	8.8	8.8	9.3	9.4	
1000	6.7	7.7	8.2	8.3	8.3	8.7	8.8	
5000	3.9	4.9	6.4	6.8	7.5	8.0	8.1	
10000	2.8	4.0	5.0	5.7	7.0	7.6	7.7	
20000	2.1	3.2	4.0	4.7	6.3	6.8	7.0	
50000	1.4	2.4	3.1	3.6	4.8	5.4	5.6	

STORM INDEX NO. 6 (NA 1-7B) DATE 7/26-29/1897 RAINFALL CENTER JEWELL,MD MOIST.ADJ.=141

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS									
	6	12	18	24	30	36	48	60		
10	13.0	14.5	14.7	14.7	14.7	14.7	15.8	15.8		
100	10.5	11.7	11.9	11.9	11.9	11.9	12.8	12.8		
200	9.4	10.5	10.6	10.6	10.6	10.6	11.5	11.5		
1000	5.5	6.0	6.2	6.2	6.2	6.2	7.0	7.0		
5000	2.3	2.7	3.0	3.1	3.2	3.2	3.6	3.7		

STORM INDEX NO. 3 (MR 4-3) DATE 6/4-7/1896 RAINFALL CENTER GREELEY,NB MOIST.ADJ.=155

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS												
	6	12	18	24	30	36	48	60	72				
10	12.0	12.0	12.2	12.3	12.3	12.3	12.3	12.3	12.3				
100	11.6	11.6	11.6	11.8	11.8	11.8	11.8	11.8	11.8				
200	11.2	11.2	11.2	11.5	11.5	11.5	11.5	11.5	11.5				
1000	8.7	8.9	9.0	9.2	9.4	9.4	9.4	9.4	9.4				
5000	4.0	4.3	4.9	5.1	5.2	5.3	5.3	5.3	5.3				
10000	2.4	2.8	3.7	4.0	4.1	4.2	4.2	4.4	4.5				
20000	1.3	1.8	2.6	3.0	3.1	3.2	3.2	3.7	3.8				
50000	.6	1.1	1.7	2.1	2.3	2.4	2.5	3.1	3.3				

STORM INDEX NO. 7 (GM 3-4) DATE 6/27-7/1/1899 RAINFALL CENTER HEARNE,TX MOIST.ADJ.=116

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS												
	6	12	18	24	30	36	48	60	72	96			
10	6.9	12.6	18.6	24.1	26.4	29.0	30.8	34.0	34.5	34.5			
100	6.3	12.1	18.1	23.3	25.7	28.2	30.0	32.8	33.6	33.6			
200	6.2	11.8	17.8	23.0	25.3	27.8	29.5	32.2	33.1	33.1			
1000	5.5	10.8	16.3	21.1	23.1	25.6	27.1	29.7	30.4	30.5			
5000	4.2	7.8	11.4	14.7	16.4	18.7	20.7	23.6	24.4	25.1			
10000	3.5	6.0	8.7	11.2	13.1	15.1	17.4	20.5	21.3	22.1			
20000	2.8	4.5	6.3	8.2	9.7	11.6	13.8	16.5	17.6	18.6			
50000	1.9	2.7	3.7	4.8	5.6	6.9	8.5	9.9	11.0	12.0			

APPENDIX - - IMPORTANT STORMS

STORM INDEX NO. 8 (LMV 2-5) DATE 4/15-18/1900 STORM INDEX NO. 14 (UMV 2-5) DATE 6/9-10/1905
 RAINFALL CENTER EUTAW,AL MOIST.ADJ.=163* RAINFALL CENTER BONAPART,IA MOIST.ADJ.=148

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS							
	6	12	18	24	30	36	48	60
10	7.6	9.9	12.2	12.6	13.7	13.9	13.9	13.9
100	6.7	9.8	11.9	12.4	13.4	13.6	13.6	13.7
200	6.4	9.7	11.7	12.2	13.2	13.4	13.4	13.5
1000	5.5	9.1	10.8	11.3	12.3	12.6	12.7	12.8
5000	4.3	7.5	9.0	9.9	10.7	11.7	11.7	11.8
10000	3.7	6.6	8.0	8.9	9.8	10.3	11.0	11.1
20000	3.1	5.7	6.9	7.8	8.5	9.1	9.9	10.2
50000	2.2	4.2	5.1	5.9	6.6	7.1	7.8	8.3

Moisture adj. limited to 150 percent for
 this study (see section 3.2.2).

STORM INDEX NO. 11 (GL 4-9) DATE 10/7-11/1903
 RAINFALL CENTER PATTERSON,NJ MOIST.ADJ.=144

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS									
	6	12	18	24	30	36	48	60	72	96
10	5.4	8.0	11.7	13.7	14.5	14.9	15.0	15.0	15.0	15.5
100	5.0	7.3	10.9	12.8	13.5	13.8	14.0	14.0	14.4	14.5
200	4.7	7.1	10.4	12.4	13.1	13.4	13.5	13.5	13.9	14.0
1000	3.7	6.4	8.9	10.9	11.7	12.0	12.1	12.1	12.4	12.5
5000	2.6	4.9	6.9	9.0	9.6	9.7	9.9	9.9	10.2	10.2
10000	2.1	4.1	5.8	7.7	8.3	8.5	8.7	8.7	8.9	9.0
20000	1.7	3.2	4.5	6.1	6.7	7.1	7.4	7.4	7.6	7.7

STORM INDEX NO. 13 (GL 2-12) DATE 6/3-8/1905
 RAINFALL CENTER MEDFORD,WI MOIST.ADJ.=141

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS									
	6	12	18	24	30	36	48	60	72	96
10	7.2	8.4	8.5	8.9	9.1	9.9	10.5	11.2	11.2	11.2
100	6.8	8.1	8.3	8.5	8.7	9.6	10.1	10.7	10.7	10.7
200	6.6	7.8	8.0	8.2	8.5	9.2	9.9	10.5	10.5	10.5
1000	5.4	6.2	6.4	7.0	7.6	8.0	8.7	9.3	9.3	9.3
5000	3.8	4.5	4.8	5.5	6.1	6.5	7.0	7.6	7.7	7.8
10000	3.1	3.8	4.0	4.8	5.4	5.8	6.2	6.9	7.0	7.1
20000	2.4	3.0	3.3	4.1	4.8	5.1	5.3	6.1	6.2	6.3
50000	1.5	2.1	2.4	2.9	3.5	3.6	4.0	4.5	4.7	4.8

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS	
	6	12
10	10.0	12.0
100	9.2	11.5
200	8.9	11.3
1000	8.0	10.0
5000	5.8	7.3
10000	4.4	5.6
20000	3.0	3.9

STORM INDEX NO. 16 (MR 5-13) DATE 6/6-8/1906
 RAINFALL CENTER WARRICK,MT MOIST.ADJ.=156

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS							
	6	12	18	24	30	36	48	54
10	6.0	7.8	8.4	10.2	10.9	11.6	13.1	13.3
100	5.0	7.1	7.6	9.2	9.7	10.5	11.8	12.2
200	4.6	6.6	7.1	8.7	9.2	9.9	11.2	11.5
1000	3.5	5.0	5.4	6.7	7.1	7.6	8.7	8.9
5000	2.1	3.0	3.2	4.2	4.4	4.9	5.7	5.9
10000	1.7	2.5	2.7	3.4	3.8	4.2	5.0	5.2
20000	1.5	2.2	2.5	2.9	3.5	3.7	4.2	4.3

STORM INDEX NO. 17 (GM 3-14) DATE 8/4-6/1906
 RAINFALL CENTER KNICKERBOCKER,TX MOIST.ADJ.=121

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS						
	6	12	18	24	30	36	48
10	7.8	7.9	7.9	8.6	9.0	9.0	9.0
100	7.6	7.9	7.9	8.6	9.0	9.0	9.0
200	7.5	7.9	7.9	8.6	9.0	9.0	9.0
1000	7.0	7.8	7.8	8.3	9.0	9.0	9.0
5000	5.8	6.6	7.1	8.2	8.2	8.2	8.2
10000	4.8	5.5	5.5	6.1	7.0	7.0	7.1
20000	3.3	3.9	4.0	4.3	5.3	5.3	5.5

APPENDIX - - IMPORTANT STORMS

STORM INDEX NO. 20 (SW 1-11) DATE 10/19-24/1908 STORM INDEX NO. 29 (GL 2-16) DATE 8/31-9/1/1914
 RAINFALL CENTER MEEKER,OK MOIST.ADJ.=163 RAINFALL CENTER COOPER,MI MOIST.ADJ.=155

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES											MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES											
AREA	DURATION OF RAINFALL IN HOURS										AREA	DURATION OF RAINFALL IN HOURS										
SQ.MI.	6	12	18	24	30	36	48	60	72	90	SQ.MI.	6	12	18	24	30	36	48	60	72	90	
10	9.4	10.0	10.0	11.4	11.8	12.0	14.5	14.9	15.2	15.8	10	12.6										
100	8.2	9.3	9.4	10.3	11.3	11.5	13.6	14.4	14.9	15.4	100	11.3										
1000	6.3	7.5	7.7	8.6	9.9	10.2	12.7	13.3	13.7	14.0	200	10.0										
5000	4.4	5.4	5.7	6.6	7.6	8.2	10.5	11.3	11.7	12.1	1000	5.7										
10000	3.5	4.5	4.8	5.6	6.4	7.1	9.2	10.0	10.6	11.0												
20000	2.7	3.6	3.9	4.6	5.3	5.9	7.7	8.6	9.0	9.6												
50000	1.6	2.4	2.8	3.4	3.8	4.3	5.6	6.2	6.6	7.2												

STORM INDEX NO. 22 (UMV 1-11A) DATE 7/18-23/1909 STORM INDEX NO. 31 (SA 2-9) DATE 7/13-17/1916
 RAINFALL CENTER BEAULIEU,MN MOIST.ADJ.=134 RAINFALL CENTER ALTAPASS,NC MOIST. ADJ.=121

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES											MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES										
AREA	DURATION OF RAINFALL IN HOURS										AREA	DURATION OF RAINFALL IN HOURS									
SQ.MI.	6	12	18	24	30	36	48	60	72	96	SQ.MI.	6	12	18	24	30	36	48	60	72	96
10	10.5	10.7	10.8	11.5	11.7	11.8	11.8	12.0	12.1	12.1	10	8.0	12.6	17.0	22.2	22.9	23.0	23.2	23.7	23.7	23.8
100	10.3	10.5	10.7	11.3	11.5	11.7	11.7	12.0	12.0	12.0	100	7.2	12.0	15.6	19.3	20.8	21.1	21.7	22.1	22.1	22.2
200	10.1	10.4	10.5	11.1	11.3	11.5	11.5	11.8	11.8	11.8	200	6.9	11.7	15.0	18.3	19.9	20.3	20.9	21.3	21.4	21.4
1000	9.2	9.6	9.7	10.0	10.4	10.6	10.6	10.8	10.9	10.9	1000	5.9	10.4	12.9	15.0	16.7	17.3	18.1	18.4	18.6	18.7
5000	4.8	5.9	6.0	6.1	6.7	7.0	7.2	7.9	8.0	8.1	5000	3.9	7.4	9.3	10.9	12.0	12.6	13.4	13.6	13.8	14.0
											10000	3.0	5.5	7.2	8.6	9.4	9.9	10.6	10.8	11.0	11.2
											20000	2.1	3.8	5.0	5.9	6.6	7.3	8.0	8.2	8.4	8.6

STORM INDEX NO. 26 (LMV 3-19) DATE 3/24-28/1914 STORM INDEX NO. 33 (GM 5-15B) DATE 9/15-17/1919
 RAINFALL CENTER MERRYVILLE,LA MOIST.ADJ.=189* RAINFALL CENTER MEEK,NM MOIST.ADJ.=134

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES											MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES											
AREA	DURATION OF RAINFALL IN HOURS										AREA	DURATION OF RAINFALL IN HOURS										
SQ.MI.	6	12	18	24	30	36	48	60	72	96	SQ.MI.	6	12	18	24	30	36	48	54	54		
10	8.3	12.0	12.4	12.6	12.6	12.6	12.9	12.9	12.9	12.9	10	3.8	4.5	6.2	7.4	8.5	9.1	9.5	9.5			
100	8.0	11.0	11.7	11.9	12.0	12.0	12.2	12.3	12.3	12.3	100	3.2	4.2	5.1	6.4	7.3	7.9	8.3	8.3			
200	7.8	10.6	11.4	11.6	11.7	11.7	11.9	12.0	12.0	12.0	200	3.0	4.1	4.7	6.0	6.9	7.5	7.9	7.9			
1000	7.2	9.7	10.5	10.7	10.8	10.8	11.0	11.2	11.2	11.2	1000	2.5	3.4	4.0	5.0	5.8	6.5	6.9	9.6			
5000	6.1	7.9	8.7	9.0	9.1	9.1	9.3	9.5	9.6	9.6	5000	1.9	2.7	3.2	4.0	4.8	5.3	5.9	6.0			
10000	4.7	6.1	7.1	7.6	7.8	7.8	8.1	8.4	8.6	8.7	10000	1.6	2.4	2.9	3.6	4.3	4.8	5.5	5.6			
20000	2.9	3.7	4.5	4.9	5.1	5.3	6.4	7.2	7.5	7.6	20000	1.3	2.0	2.5	3.1	3.8	4.3	5.1	5.2			
50000	2.0	2.6	3.2	3.8	4.1	4.2	4.9	5.6	5.8	6.0	50000	.9	1.6	2.1	2.6	3.2	3.7	4.6	4.7			

*Moisture adj. limited to 160 percent for this study (see section 3.2.2).

APPENDIX - - IMPORTANT STORMS

STORM INDEX NO. 36 (MR 4-21) DATE 6/17-21/1921
RAINFALL CENTER SPRINGBROOK,MT MOIST.ADJ.=128

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

Table with columns: AREA SQ.MI., DURATION OF RAINFALL IN HOURS (6, 12, 18, 24, 30, 36, 48, 60, 72, 96). Rows show rainfall depth for areas 10, 100, 200, 1000, 5000, 10000, and 20000.

STORM INDEX NO. 42 (MR 4-24) DATE 9/17-19/1926
RAINFALL CENTER BOYDEN,IA MOIST.ADJ.=134

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

Table with columns: AREA SQ.MI., DURATION OF RAINFALL IN HOURS (6, 12, 18, 24, 30, 36, 48). Rows show rainfall depth for areas 10, 100, 200, 1000, 5000, 10000, 20000, and 50000.

STORM INDEX NO. 37 (GM 4-12) DATE 9/8-10/1921
RAINFALL CENTER THRALL,TX MOIST.ADJ.=105

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

Table with columns: AREA SQ.MI., DURATION OF RAINFALL IN HOURS (6, 12, 18, 24, 30, 36, 48). Rows show rainfall depth for areas 10, 100, 200, 1000, 5000, and 10000.

STORM INDEX NO. 44 (NA 1-17) DATE 11/2-4/1927
RAINFALL CENTER KINSMAN NOTCH,NH MOIST.ADJ.=148

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

Table with columns: AREA SQ.MI., DURATION OF RAINFALL IN HOURS (6, 12, 18, 24, 30, 36, 48). Rows show rainfall depth for areas 10, 100, 200, 1000, 5000, 10000, 20000, and 50000.

STORM INDEX NO. 38 (MR 4-23) DATE 9/27-10/1/1923
RAINFALL CENTER SAVAGETON,WY MOIST.ADJ.=141

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

Table with columns: AREA SQ.MI., DURATION OF RAINFALL IN HOURS (6, 12, 18, 24, 30, 36, 48, 60, 72, 96). Rows show rainfall depth for areas 10, 100, 200, 1000, 5000, 10000, 20000, and 50000.

STORM INDEX NO. 47 (LMV 2-20) DATE 3/ 11-16/1929
RAINFALL CENTER ELBA,AL MOIST.ADJ.=134

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

Table with columns: AREA SQ.MI., DURATION OF RAINFALL IN HOURS (6, 12, 18, 24, 30, 36, 48, 60, 72, 96). Rows show rainfall depth for areas 10, 100, 200, 1000, 5000, 10000, 20000, and 50000.

APPENDIX - - IMPORTANT STORMS

STORM INDEX NO. 49 (GM 5-1) DATE 6/30-7/2/1932
 RAINFALL CENTER STATE FISH HATCHERY, TX MOIST.ADJ.=116

STORM INDEX NO. 53 (SW 2-11) DATE 4/3-4/1934
 RAINFALL CENTER CHEYENNE, OK MOIST.ADJ.=149

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS						
	6	12	18	24	30	36	42
10	13.3	19.5	30.0	31.7	32.9	33.6	33.7
100	11.2	15.8	23.7	25.8	26.8	27.5	27.7
200	10.3	14.3	21.2	23.8	24.9	25.5	25.7
1000	7.7	10.5	15.5	19.0	20.2	20.7	20.9
5000	4.8	6.8	9.8	13.5	14.9	15.3	15.6
10000	3.6	5.2	7.4	10.3	11.3	11.6	11.8
20000	2.4	3.6	4.9	7.0	7.7	7.9	8.1

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS		
	6	12	18
10	17.3	20.8	21.3
100	14.4	17.1	17.7
200	13.3	15.7	16.4
1000	9.1	10.7	11.1

STORM INDEX NO. 50 (NA 1-20A) DATE 9/16-17/1932
 RAINFALL CENTER SCITUATE, RI MOIST.ADJ.=148

STORM INDEX NO. 54 (LMV 4-21) DATE 5/16-20/1935
 RAINFALL CENTER SIMMESPORT, LA MOIST.ADJ.=128

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS						
	6	12	18	24	30	36	48
10	7.0	10.2	11.9	12.2	12.2	12.2	12.2
200	6.8	10.2	11.1	11.6	11.6	11.6	11.6
1000	5.8	8.6	9.5	10.2	10.2	10.2	10.2
5000	4.0	6.5	7.3	7.9	8.1	8.2	8.2
10000	3.2	5.5	6.5	6.9	7.2	7.4	7.5

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS										
	6	12	18	24	30	36	48	60	72	96	
10	13.8	14.1	14.1	14.1	14.1	14.1	14.1	14.1	14.1	14.1	
100	13.1	13.2	13.3	13.3	13.3	13.3	13.3	13.3	13.4	13.4	
200	12.5	12.6	12.7	12.7	12.7	12.7	12.7	12.7	12.8	12.8	
1000	10.2	10.3	10.4	10.4	10.5	10.7	10.8	10.8	10.9	11.0	
5000	7.1	7.6	7.7	7.7	8.1	8.3	8.7	8.8	8.8	8.8	
10000	5.7	6.2	6.3	6.4	6.9	7.2	7.7	7.8	7.8	7.8	
20000	4.1	4.7	4.9	5.0	5.5	5.7	6.5	6.6	6.7	6.8	
50000	2.0	2.6	2.9	3.2	3.4	3.7	4.6	4.9	5.0	5.3	

STORM INDEX NO. 51 (NA 1-20B) DATE 9/16-17/1932
 RAINFALL CENTER RIPOGENUS DAM, ME MOIST.ADJ.=127

STORM INDEX NO. 56 (- -) DATE 5/30-31/1935
 RAINFALL CENTER HALE, CO MOIST.ADJ.=122

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS			
	6	12	18	24
10	7.7	8.1	8.4	8.7
100	6.9	8.0	8.3	8.6
200	6.5	7.8	8.1	8.5
1000	5.2	7.2	7.5	7.9
5000	3.6	6.1	6.4	6.7
10000	3.0	5.5	5.9	6.3

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS			
	6	12	18	24
10	16.5	22.2	22.2	22.2
100	11.0	15.4	15.4	15.4
200	9.9	12.6	12.6	12.6
1000	4.6	7.2	7.2	7.2
5000	1.9	3.5	3.8	4.0

APPENDIX - - IMPORTANT STORMS

STORM INDEX NO. 57 (GM 5-20) DATE 5/31/1935
 RAINFALL CENTER WOODWARD RANCH, TX MOIST.ADJ.=121

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS		
	6	10	
10	20.4	20.4	
100	16.3	16.5	
200	14.1	14.6	
1000	8.6	8.8	
5000	3.9	4.2	

STORM INDEX NO. 67 (MR 4-5) DATE 6/3-4/1940
 RAINFALL CENTER GRANT TOWNSHIP, NB MOIST.ADJ.=163

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS		
	6	12	18
10	13.0	13.0	13.0
100	10.6	11.7	11.7
200	9.6	11.2	11.2
1000	7.2	8.9	9.0
5000	4.2	5.5	5.7
10000	3.1	4.4	4.6
20000	2.1	3.3	3.5

STORM INDEX NO. 59 (NA 1-27) DATE 7/ 6-10/1935
 RAINFALL CENTER HECTOR, NY MOIST.ADJ.=122

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS									
	6	12	18	24	30	36	48	60	72	90
10	5.2	10.2	11.4	11.8	12.0	13.4	14.2	14.2	14.2	14.2
100	4.9	8.6	10.1	10.5	10.7	11.5	13.0	13.1	13.4	13.6
200	4.7	8.0	9.6	10.0	10.3	10.9	12.5	12.6	12.9	13.2
1000	4.0	6.7	8.2	8.6	8.8	9.0	10.6	10.8	11.1	11.5
5000	2.7	4.8	5.9	6.4	6.6	6.8	7.7	8.2	8.5	8.7
10000	2.1	3.7	4.6	5.1	5.4	5.7	6.4	7.0	7.2	7.5
20000	1.3	2.6	3.2	3.7	4.1	4.5	5.1	5.6	5.9	6.2

STORM INDEX NO. 68 (NA 2-4) DATE 9/1/1940
 RAINFALL CENTER EWAN, NJ MOIST.ADJ.=122

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS	
	6	12
10	20.1	22.7
100	17.1	18.8
200	15.0	16.5
1000	8.8	10.5

STORM INDEX NO. 65 (- -) DATE 6/19-20/1939
 RAINFALL CENTER SNYDER, TX MOIST.ADJ.=128

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS
	6
10	18.8
100	14.2
200	11.9
1000	6.5

STORM INDEX NO. 69 (SW 2-18) DATE 9/2-6/1940
 RAINFALL CENTER HALLETT, OK MOIST.ADJ.=141

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS							
	6	12	18	24	30	36	48	54
10	18.4	23.4	23.6	23.6	23.6	23.6	23.6	23.6
100	14.7	19.2	19.4	19.6	19.7	19.8	19.8	19.8
200	12.5	17.6	17.8	18.0	18.1	18.2	18.3	18.3
1000	7.9	13.3	13.4	13.6	13.7	14.0	14.1	14.1
5000	4.3	7.3	7.4	7.5	7.7	7.8	7.9	8.0
10000	3.0	5.3	5.4	5.5	5.6	5.7	5.8	5.9
20000	2.0	3.9	4.1	4.2	4.3	4.4	4.5	4.6

APPENDIX -- IMPORTANT STORMS

STORM INDEX NO. 71 (UMV 1-22) DATE 8/28-31/1941
 RAINFALL CENTER HAYWARD,WI MOIST.ADJ.=134

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS									
	6	12	18	24	30	36	48	60	72	
10	8.5	11.5	12.4	12.4	13.3	13.8	14.4	15.0	15.0	
100	8.1	11.0	11.8	11.8	12.7	13.3	13.8	14.3	14.5	
200	7.8	10.6	11.3	11.3	12.3	13.0	13.4	13.9	14.1	
1000	5.6	8.2	9.0	9.1	10.0	10.9	11.5	11.9	12.0	
5000	3.0	5.2	5.9	6.3	7.2	8.1	8.9	9.3	9.5	
10000	2.1	3.8	4.6	5.1	5.9	6.8	7.8	8.2	8.4	
20000	1.5	2.7	3.4	3.8	4.7	5.5	6.5	7.1	7.3	
50000	.9	1.6	2.1	2.5	3.1	3.6	4.5	5.1	5.2	

STORM INDEX NO. 77 (SW 2-20) DATE 5/6-12/1943
 RAINFALL CENTER WARNER,OK MOIST.ADJ.=141

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS										
	6	12	18	24	30	36	48	60	72	96	
10	9.9	12.3	14.6	17.2	19.5	21.5	24.4	24.9	24.9	24.9	
100	8.7	10.8	12.4	14.9	17.1	19.3	21.8	22.5	22.5	22.5	
200	7.4	9.5	11.4	13.8	16.0	18.3	20.6	21.3	21.3	21.3	
1000	4.3	6.3	9.0	11.1	13.3	15.4	17.1	18.0	18.0	18.0	
5000	3.0	4.5	6.8	8.3	10.5	12.1	13.4	14.4	14.4	14.4	
10000	2.6	3.9	5.8	7.2	9.1	10.4	11.7	12.6	12.6	12.8	
20000	2.1	3.3	4.9	6.1	7.6	8.7	10.0	10.7	10.8	11.1	
50000	1.6	2.5	3.7	4.6	5.7	6.5	7.7	8.1	8.3	8.8	

STORM INDEX NO. 74 (OR 9-23) DATE 7/17-18/1942
 RAINFALL CENTER SMETHPORT,PA MOIST.ADJ.=110

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS			
	6	12	18	24
10	24.7	26.7	28.7	29.2
100	16.4	19.4	21.8	22.4
200	13.1	16.8	19.3	19.9
1000	6.4	10.3	12.6	13.3

STORM INDEX NO. 78 (MR 6-15) DATE 6/10-13/1944
 RAINFALL CENTER STANTON,NB MOIST.ADJ.=141

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS										
	6	12	18	24	30	36	48	60	72	78	
10	13.4	15.3	15.3	15.3	15.3	15.3	16.2	16.4	16.7	16.7	
100	11.7	13.6	13.6	13.6	13.6	13.7	14.8	14.9	15.1	15.1	
200	11.1	12.9	12.9	12.9	12.9	13.1	14.1	14.3	14.4	14.4	
1000	7.8	9.0	9.3	9.3	9.3	9.4	10.1	10.4	10.4	10.4	
5000	3.4	4.0	4.2	4.6	4.7	4.9	5.3	5.5	5.7	5.8	
10000	2.2	2.5	2.7	3.5	3.9	4.1	4.5	4.7	4.9	5.0	

STORM INDEX NO. 76 (SA 1-28A) DATE 10/11-17/1942
 RAINFALL CENTER BIG MEADOWS,VA MOIST.ADJ.=148

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS										
	6	12	18	24	30	36	48	60	72	96	
10	6.0	8.4	10.9	13.4	14.2	15.6	17.4	18.4	18.7	18.8	
100	4.3	6.0	9.2	11.2	12.5	13.8	16.6	18.0	18.4	18.6	
200	3.9	5.6	8.6	10.5	11.8	13.0	16.1	17.5	17.8	18.1	
1000	3.1	4.9	7.4	9.1	10.3	11.1	13.8	15.0	15.3	15.5	
5000	2.3	3.8	5.9	7.2	8.1	8.9	10.7	11.6	11.8	12.1	
10000	1.8	3.2	4.5	5.7	6.5	7.1	8.9	9.6	9.8	10.1	
20000	1.1	2.2	3.0	3.9	4.6	5.1	6.8	7.3	7.5	7.9	

STORM INDEX NO. 80 (MR 7-2B) DATE 8/12-16/1946
 RAINFALL CENTER COLLINSVILLE,IL MOIST.ADJ.=121

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS										
	6	12	18	24	30	36	48	60	72	96	
10	6.0	9.8	12.1	12.1	13.7	17.5	17.6	18.3	18.3	18.9	
100	5.6	8.8	10.9	11.1	13.2	16.6	16.7	17.5	17.6	18.0	
200	5.4	8.3	10.5	10.6	13.0	16.2	16.3	17.2	17.3	17.7	
1000	4.9	7.0	8.9	9.0	12.6	14.7	14.8	15.9	16.0	16.3	
5000	3.3	4.8	5.9	6.0	8.6	10.4	10.6	11.3	11.4	11.6	
10000	2.4	3.7	4.5	4.6	6.6	8.0	8.2	8.7	8.8	9.0	
20000	1.5	2.5	3.1	3.2	4.6	5.6	5.8	6.0	6.1	6.3	

APPENDIX -- IMPORTANT STORMS

STORM INDEX NO. 82 (- -) DATE 6/23-24/1948 STORM INDEX NO. 87 (MR 10-8) DATE 6/7/1953
 RAINFALL CENTER DEL RIO, TX MOIST.ADJ.=121 RAINFALL CENTER RITTER, IA MOIST.ADJ.=171

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS			
	6	12	18	24
10	13.2	20.7	25.2	26.2
100	11.3	18.2	22.5	23.8
200	10.3	16.9	21.1	22.5
1000	7.7	13.6	16.8	17.9
5000	4.7	8.0	9.9	10.8
10000	3.2	5.5	6.8	7.2

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS		
	6	12	20
10	9.1	10.5	10.7
100	7.4	9.4	10.0
1000	6.1	7.9	8.4
5000	4.4	5.9	6.5
10000	3.5	4.8	5.4

STORM INDEX NO. 85 (SA 5-8) DATE 9/3-7/1950
 RAINFALL CENTER YANKEETOWN, FL MOIST.ADJ.=110

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS									
	6	12	18	24	30	36	48	60	72	96
10	16.0	28.6	36.3	38.7	40.6	41.8	43.1	44.7	45.2	45.2
100	14.0	26.3	32.5	35.2	36.5	37.9	38.9	40.2	40.6	40.8
200	13.4	25.6	31.4	34.2	35.3	36.7	37.7	38.8	39.2	39.6
1000	11.4	22.6	27.4	30.2	31.6	32.9	33.7	34.4	34.9	35.4
5000	5.4	9.7	13.3	15.5	17.5	18.4	19.7	20.2	21.0	21.8
10000	3.3	6.6	8.6	10.6	12.1	13.1	14.7	15.6	16.4	17.3
20000	2.3	4.3	5.8	7.5	8.8	9.6	11.2	12.5	13.5	14.2

STORM INDEX NO. 88 (SW 3-22) DATE 6/23-28/1954
 RAINFALL CENTER VIC PIERCE, TX MOIST.ADJ.=116

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS									
	6	12	18	24	30	36	48	60	72	
10	16.0	20.1	22.5	26.7	30.7	32.0	34.6	34.6	34.6	
100	12.6	16.5	19.7	23.6	27.6	29.2	31.5	31.5	31.5	
200	10.9	14.9	18.6	22.5	25.9	27.5	29.5	29.5	29.5	
1000	6.6	9.7	14.6	18.4	20.1	21.5	23.0	23.0	23.0	
5000	2.8	4.9	7.4	8.9	10.4	11.9	13.7	14.3	14.3	
10000	1.7	3.2	4.7	5.7	7.1	8.0	9.8	10.4	10.5	
20000	1.2	2.0	2.8	3.6	4.5	5.2	6.5	7.0	7.2	

STORM INDEX NO. 86 (MR 10-2) DATE 7/9-13/1951
 RAINFALL CENTER COUNCIL GROVE, KS MOIST.ADJ.=128

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS									
	6	12	18	24	30	36	48	60	72	96
10	5.3	7.0	7.9	8.6	11.8	13.1	14.3	17.2	18.2	18.2
100	4.7	6.4	7.4	7.9	10.6	12.4	13.8	16.3	17.5	17.5
200	4.6	6.2	7.2	7.5	10.2	12.0	13.3	15.9	17.0	17.0
1000	4.0	5.5	6.3	6.6	9.0	10.5	11.5	14.2	15.5	15.5
5000	3.4	4.5	5.1	5.4	7.2	8.4	9.3	11.7	13.0	13.1
10000	2.9	3.9	4.4	4.8	6.2	7.3	8.2	10.4	11.4	11.5
20000	2.4	3.2	3.7	4.1	5.1	6.1	6.9	8.6	9.4	9.6
50000	1.3	2.0	2.5	2.8	3.4	4.0	4.7	5.8	6.3	6.5

STORM INDEX NO. 90 (ONT 10-54) DATE 10/14-15/1954
 RAINFALL CENTER NR. BOLTON, CANADA MOIST.ADJ.=122

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS					
	6	12	24	30	48	78
10	5.4	7.2	9.0	9.4	10.0	10.4
100	4.6	6.5	8.1	8.5	8.9	9.2
200	4.4	6.2	7.5	8.1	8.5	8.8
1000	3.6	5.2	6.4	6.8	7.3	7.5
5000	2.1	3.4	4.8	5.4	5.8	6.2
10000	1.6	2.7	4.2	4.6	5.3	5.5
20000	1.1	2.1	3.4	3.9	4.6	4.9

APPENDIX - - IMPORTANT STORMS

STORM INDEX NO. 91 (NA 2-22A) DATE 8/17-20/1955
 RAINFALL CENTER WESTFIELD,MA MOIST.ADJ.=110

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS							
	6	12	18	24	30	36	48	60
10	7.8	11.1	13.0	16.4	18.5	18.9	19.4	19.4
100	7.6	10.5	11.6	14.6	17.6	18.1	18.8	19.0
200	7.4	10.2	11.4	14.2	17.1	17.6	18.2	18.4
1000	6.2	9.2	10.2	12.4	15.4	15.9	16.2	16.4
5000	4.0	6.3	7.9	9.5	11.7	12.1	12.6	13.0
10000	3.1	5.0	6.5	8.0	9.7	10.0	10.6	10.8
20000	2.1	3.6	4.9	6.3	7.6	7.9	8.3	8.5

STORM INDEX NO. 99 (NA 2-23) DATE 8/19-20/1969
 RAINFALL CENTER TYRO,VA MOIST.ADJ.=105

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS		
	6	12	18
10	14.2	25.4	25.4
100	12.9	21.7	21.7
200	11.7	19.6	19.6
1000	8.1	13.5	13.5
5000	4.4	7.5	8.0
10000	3.3	5.8	6.3

STORM INDEX NO. 93 (QUE 8-57) DATE 8/3-4/1957
 RAINFALL CENTER ST.PIERRE BAPTISTE,CANADA MOIST.ADJ.=121

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS		
	6	12	18
100	8.4	8.6	8.7
200	7.5	7.6	7.8
1000	4.4	5.2	5.4
5000	2.4	3.1	3.3

STORM INDEX NO.100 (NA 2-24A) DATE 6/19-23/1972
 RAINFALL CENTER ZERBE,PA MOIST.ADJ.=121

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS										
	6	12	18	24	30	36	48	60	72	96	
10	8.0	11.9	13.3	14.3	15.8	16.9	17.8	18.3	18.5	18.6	
100	7.1	10.9	12.5	13.7	15.3	16.0	16.7	17.3	17.4	17.5	
200	6.6	10.4	12.0	13.4	15.0	15.6	16.3	16.8	16.9	17.0	
1000	5.3	8.9	10.5	12.3	13.8	14.4	14.9	15.2	15.3	15.4	
5000	3.8	6.8	8.4	10.0	11.2	12.0	12.6	12.9	13.0	13.2	
10000	3.2	5.7	7.3	8.7	9.9	10.5	11.3	11.7	11.8	12.0	
20000	2.5	4.4	6.0	7.3	8.3	8.9	9.9	10.4	10.5	10.7	
50000	1.6	2.8	4.1	5.1	5.9	6.6	7.7	8.4	8.6	8.8	

STORM INDEX NO. 97 (SW 3-24) DATE 9/19-24/1967
 RAINFALL CENTER SOMBRERETILLO,MEXICO MOIST.ADJ.=116

MAXIMUM AVERAGE DEPTH OF RAINFALL IN INCHES

AREA SQ.MI.	DURATION OF RAINFALL IN HOURS									
	6	12	18	24	30	36	48	60	72	96
10	9.2	12.2	15.2	18.7	21.8	24.8	26.2	32.0	32.0	32.5
100	7.3	10.4	13.2	17.6	20.7	21.7	23.9	30.0	30.0	30.9
200	6.7	9.7	12.3	16.4	19.2	20.3	23.0	28.8	28.8	29.9
1000	5.3	7.9	10.0	11.9	14.4	16.8	20.3	23.8	25.1	26.0
5000	3.7	5.8	7.6	8.9	10.8	13.1	17.2	19.2	20.7	21.7
10000	3.1	4.9	6.5	7.8	9.5	11.4	15.2	17.3	18.5	20.0
20000	2.4	4.0	5.4	6.7	8.1	9.8	13.0	15.0	16.3	18.2
50000	1.4	2.7	3.9	5.1	6.3	7.6	9.9	11.9	13.2	15.6

(Continued from inside front cover)

- No. 45. Probable maximum and TVA precipitation for Tennessee River Basins up to 3,000 square miles in area and durations to 72 hours. 1969.
- No. 46. Probable maximum precipitation, Mekong River Basin. 1970.
- No. 47. Meteorological criteria for extreme floods for four basins in the Tennessee and Cumberland River Watersheds. 1973.
- No. 48. Probable Maximum Precipitation and Snowmelt Criteria For Red River of the North Above Pembina, and Souris River Above Minot, North Dakota. 1973.
- No. 49. Probable Maximum Precipitation Estimates, Colorado River and Great Basin Drainages. 1977.
- No. 50. The Meteorology of Important Rainstorms in the Colorado River and Great Basin Drainages. In preparation.

**USWB 1961 - Technical Paper No. 40, Rainfall Frequency Atlas
of the United States for Durations from 30 Minutes to 24 Hours
and Return Periods from 1 to 100 Years,
U.S. Department of Commerce, Weather Bureau,
1961, Rev. January 1963.**

Environmental Resources Management
206 East 9th Street, Suite 1700
Austin, Texas 78701
(512) 459-4700

TECHNICAL PAPER NO. 40

RAINFALL FREQUENCY ATLAS OF THE UNITED STATES

for Durations from 30 Minutes to 24 Hours and
Return Periods from 1 to 100 Years

Prepared by
DAVID M. HERSHFIELD
Cooperative Studies Section, Hydrologic Services Division
for
Engineering Division, Soil Conservation Service
U.S. Department of Agriculture



WASHINGTON, D.C.

May 1961

Repaginated and Reprinted January 1963

TECHNICAL PAPER NO. 40

RAINFALL FREQUENCY ATLAS OF THE UNITED STATES

**for Durations from 30 Minutes to 24 Hours and
Return Periods from 1 to 100 Years**



WASHINGTON, D.C.

May 1961

Repaginated and Reprinted January 1963

Weather Bureau Technical Papers

- *No. 1. Ten-year normals of pressure tendencies and hourly station pressures for the United States. Washington, D.C. 1943.
*Supplement: Normal 3-hourly pressure changes for the United States at the intermediate synoptic hours. Washington, D.C. 1945.
- *No. 2. Maximum recorded United States point rainfall for 5 minutes to 24 hours at 207 first order stations. Washington, D.C. 1947.
- *No. 3. Extreme temperatures in the upper air. Washington, D.C. 1947.
- *No. 4. Topographically adjusted normal isohyetal maps for western Colorado. Washington, D.C. 1947.
- *No. 5. Highest persisting dewpoints in western United States. Washington, D.C. 1948.
- *No. 6. Upper air average values of temperature, pressure, and relative humidity over the United States and Alaska. Washington, D.C. 1945.
- *No. 7. A report on thunderstorm conditions affecting flight operations. Washington, D.C. 1948.
- *No. 8. The climatic handbook for Washington, D.C. Washington, D.C. 1949.
- *No. 9. Temperature at selected stations in the United States, Alaska, Hawaii, and Puerto Rico. Washington, D.C. 1949.
- No. 10. Mean precipitable water in the United States. Washington, D.C. 1949. .30
- No. 11. Weekly mean values of daily total solar and sky radiation. Washington, D.C. 1949. .15. Supplement No. 1, 1955. .05.
- *No. 12. Sunshine and cloudiness at selected stations in the United States, Alaska, Hawaii, and Puerto Rico. Washington, D.C. 1951.
- No. 13. Mean monthly and annual evaporation data from free water surface for the United States, Alaska, Hawaii, and the West Indies. Washington, D.C. 1950. .15
- *No. 14. Tables of precipitable water and other factors for a saturated pseudo-adiabatic atmosphere. Washington, D.C. 1951.
- No. 15. Maximum station precipitation for 1, 2, 3, 6, 12, and 24 hours: Part I: Utah, Part II: Idaho, 1951, each .25; Part III: Florida, 1952, .45; Part IV: Maryland, Delaware, and District of Columbia; Part V: New Jersey, 1953, each .25; Part VI: New England, 1953, .60; Part VII: South Carolina, 1953, .25; Part VIII: Virginia, 1954, .50; Part IX: Georgia, 1954, .40; Part X: New York, 1954, .60; Part XI: North Carolina; Part XII: Oregon, 1955, each .55; Part XIII: Kentucky, 1955, .45; Part XIV: Louisiana; Part XV: Alabama, 1955, each .35; Part XVI: Pennsylvania, 1956, .65; Part XVII: Mississippi, 1956, .40; Part XVIII: West Virginia, 1956, .35; Part XIX: Tennessee, 1956, .45; Part XX: Indiana, 1956, .55; Part XXI: Illinois, 1958, .50; Part XXII: Ohio, 1958, .65; Part XXIII: California, 1959, \$1.50; Part XXIV: Texas, 1959, \$1.00; Part XXV: Arkansas, 1960, .50.
- *No. 16. Maximum 24-hour precipitation in the United States. Washington, D.C. 1952.
- No. 17. Kansas-Missouri floods of June-July 1951. Kansas City, Mo. 1952. .60
- *No. 18. Measurements of diffuse solar radiation at Blue Hill Observatory. Washington, D.C. 1952.
- No. 19. Mean number of thunderstorm days in the United States. Washington, D.C. 1952. .15
- No. 20. Tornado occurrences in the United States. Washington, D.C. 1952. .35
- *No. 21. Normal weather charts for the Northern Hemisphere. Washington, D.C. 1952.
- *No. 22. Wind patterns over lower Lake Mead. Washington, D.C. 1953.
- No. 23. Floods of April 1952—Upper Mississippi, Missouri, Red River of the North. Washington, D.C. 1954. \$1.00
- No. 24. Rainfall intensities for local drainage design in the United States. For durations of 5 to 240 minutes and 2-, 5-, and 10-year return periods. Part I: West of 115th meridian. Washington, D.C. 1953, .20; Part II: Between 105° W. and 115° W. Washington, D.C. 1954. .15
- No. 25. Rainfall intensity-duration-frequency curves. For selected stations in the United States, Alaska, Hawaiian Islands, and Puerto Rico. Washington, D.C. 1955. .40
- No. 26. Hurricane rains and floods of August 1955, Carolinas to New England. Washington, D.C. 1956. \$1.00
- *No. 27. The climate of the Matanuska Valley. Washington, D.C. 1956.
- *No. 28. Rainfall intensities for local drainage design in western United States. For durations of 20 minutes to 24 hours and 1- to 100-year return periods. Washington, D.C. 1956.
- No. 29. Rainfall intensity-frequency regime. Part 1—The Ohio Valley, 1957, .30; Part 2—Southeastern United States, 1958, \$1.25; Part 3—The Middle Atlantic Region, 1958, .30; Part 4—Northeastern United States, 1959, \$1.25; Part 5—Great Lakes Region, 1960. \$1.50
- No. 30. Tornado deaths in the United States. Washington, D.C. 1957. .50
- No. 31. Monthly normal temperatures, precipitation, and degree days. Washington, D.C. 1956. .25
- No. 32. Upper-air climatology of the United States. Part 1—Averages for isobaric surfaces, height, temperature, humidity, and density. 1957, \$1.25; Part 2—Extremes and standard deviations of average heights and temperatures. 1958, .65; Part 3—Vector winds and shear. 1959. .50
- No. 33. Rainfall and floods of April, May, and June 1957 in the South-Central States. Washington, D.C. 1958. \$1.75
- No. 34. Upper wind distribution statistical parameter estimates. Washington, D.C. 1958. .40
- No. 35. Climatology and weather services of the St. Lawrence Seaway and Great Lakes. Washington, D.C. 1959. .45
- No. 36. North Atlantic tropical cyclones. Washington, D.C. 1959. \$1.00
- No. 37. Evaporation maps for the United States. Washington, D.C. 1959. .65
- No. 38. Generalized estimates of probable maximum precipitation for the United States west of the 105th meridian for areas to 400 square miles and durations to 24 hours. Washington, D.C. 1960. \$1.00
- No. 39. Verification of the Weather Bureau's 30-day outlooks. Washington, D.C. 1961. .40

*Out of print.

PREFACE

This publication is intended as a convenient summary of empirical relationships, working guides, and maps, useful in practical problems requiring rainfall frequency data. It is an outgrowth of several previous Weather Bureau publications on this subject prepared under the direction of the author and contains an expansion and generalization of the ideas and results in earlier papers. This work has been supported and financed by the Soil Conservation Service, Department of Agriculture, to provide material for use in developing planning and design criteria for the Watershed Protection and Flood Prevention program (P.L. 566, 83d Congress and as amended).

The paper is divided into two parts. The first part presents the rainfall analyses. Included are measures of the quality of the various relationships, comparisons with previous works of a similar nature, numerical examples, discussions of the limitations of the results, transformation from point to areal frequency, and seasonal variation. The second part presents 49 rainfall frequency maps based on a comprehensive and integrated collection of up-to-date statistics, several related maps, and seasonal variation diagrams. The rainfall frequency (isopluvial) maps are for selected durations from 30 minutes to 24 hours and return periods from 1 to 100 years.

This study was prepared in the Cooperative Studies Section (Joseph L. H. Paulhus, Chief) of Hydrologic Services Division (William E. Hiatt, Chief). Coordination with the Soil Conservation Service, Department of Agriculture, was maintained through Harold O. Ogrosky, Chief, Hydrology Branch, Engineering Division. Assistance in the study was received from several people. In particular, the author wishes to acknowledge the help of William E. Miller who programmed the frequency and duration functions and supervised the processing of all the data; Normalee S. Foat who supervised the collection of the basic data; Howard Thompson who prepared the maps for analysis; Walter T. Wilson, a former colleague, who was associated with the development of a large portion of the material presented here; Max A. Kohler, A. L. Shands, and Leonard L. Weiss, of the Weather Bureau, and V. Mockus and R. G. Andrews, of the Soil Conservation Service, who reviewed the manuscript and made many helpful suggestions. Carol W. Gardner performed the drafting.

CONTENTS

	Page		Page
PREFACE.....	ii	PARTS II: CHARTS—Continued.....	
INTRODUCTION.....	1	9.—2-year 1-hour rainfall.....	16
Historical review.....	1	10.—5-year 1-hour rainfall.....	17
General approach.....	1	11.—10-year 1-hour rainfall.....	18
PART I: ANALYSES.....	1	12.—25-year 1-hour rainfall.....	19
Basic data.....	1	13.—50-year 1-hour rainfall.....	20
Duration analysis.....	2	14.—100-year 1-hour rainfall.....	21
Frequency analysis.....	2	15.—1-year 2-hour rainfall.....	22
Isopluvial maps.....	4	16.—2-year 2-hour rainfall.....	23
Guides for estimating durations and/or return periods not presented on the maps.....	5	17.—5-year 2-hour rainfall.....	24
Comparisons with previous rainfall frequency studies.....	6	18.—10-year 2-hour rainfall.....	25
Probability considerations.....	6	19.—25-year 2-hour rainfall.....	26
Probable maximum precipitation (PMP).....	6	20.—50-year 2-hour rainfall.....	27
Area-depth relationships.....	7	21.—100-year 2-hour rainfall.....	28
Seasonal variation.....	7	22.—1-year 3-hour rainfall.....	29
References.....	7	23.—2-year 3-hour rainfall.....	30
List of tables.....		24.—5-year 3-hour rainfall.....	31
1. Sources of point rainfall data.....	1	25.—10-year 3-hour rainfall.....	32
2. Empirical factors for converting partial-duration series to annual series.....	3	26.—25-year 3-hour rainfall.....	33
3. Average relationship between 30-minute rainfall and shorter duration rainfall for the same return period.....	5	27.—50-year 3-hour rainfall.....	34
List of illustrations.....		28.—100-year 3-hour rainfall.....	35
Figure 1.—Relation between 2-year 60-minute rainfall and 2-year clock-hour rainfall; relation between 2-year 1440-minute rainfall and 2-year observational-day rainfall.....	1	29.—1-year 6-hour rainfall.....	36
Figure 2.—Rainfall depth-duration diagram.....	2	30.—2-year 6-hour rainfall.....	37
Figure 3.—Relation between observed 2-year 2-hour rainfall and 2-year 2-hour rainfall computed from duration diagram.....	2	31.—5-year 6-hour rainfall.....	38
Figure 4.—Relation between observed 2-year 6-hour rainfall and 2-year 6-hour rainfall computed from duration diagram.....	2	32.—10-year 6-hour rainfall.....	39
Figure 5.—Relation between 2-year 30-minute rainfall and 2-year 60-minute rainfall.....	2	33.—25-year 6-hour rainfall.....	40
Figure 6.—Relation between partial-duration and annual series.....	2	34.—50-year 6-hour rainfall.....	41
Figure 7.—Rainfall depth versus return period.....	3	35.—100-year 6-hour rainfall.....	42
Figure 8.—Distribution of 1-hour stations.....	3	36.—1-year 12-hour rainfall.....	43
Figure 9.—Distribution of 24-hour stations.....	4	37.—2-year 12-hour rainfall.....	44
Figure 10.—Grid density used to construct additional maps.....	5	38.—5-year 12-hour rainfall.....	45
Figure 11.—Relation between means from 50-year and 10-year records (24-hour duration).....	6	39.—10-year 12-hour rainfall.....	46
Figure 12.—Example of internal consistency check.....	6	40.—25-year 12-hour rainfall.....	47
Figure 13.—Example of extrapolating to long return periods.....	6	41.—50-year 12-hour rainfall.....	48
Figure 14.—Relationship between design return period, T years, design period, T_d , and probability of not being exceeded in T_d years.....	6	42.—100-year 12-hour rainfall.....	49
Figure 15.—Area-depth curves.....	6	43.—1-year 24-hour rainfall.....	50
PART II: CHARTS.....		44.—2-year 24-hour rainfall.....	51
1.—1-year 30-minute rainfall.....	8	45.—5-year 24-hour rainfall.....	52
2.—2-year 30-minute rainfall.....	9	46.—10-year 24-hour rainfall.....	53
3.—5-year 30-minute rainfall.....	10	47.—25-year 24-hour rainfall.....	54
4.—10-year 30-minute rainfall.....	11	48.—50-year 24-hour rainfall.....	55
5.—25-year 30-minute rainfall.....	12	49.—100-year 24-hour rainfall.....	56
6.—50-year 30-minute rainfall.....	13	50.—Probable maximum 6-hour precipitation for 10 square miles.....	57
7.—100-year 30-minute rainfall.....	14	51.—Ratio of probable maximum 6-hour precipitation for 10 square miles to 100-year 6-hour rainfall.....	58
8.—1-year 1-hour rainfall.....	15	52.—Seasonal probability of intense rainfall, 1-hour duration.....	59
		53.—Seasonal probability of intense rainfall, 6-hour duration.....	60
		54.—Seasonal probability of intense rainfall, 24-hour duration.....	61

RAINFALL FREQUENCY ATLAS OF THE UNITED STATES for Durations from 30 Minutes to 24 Hours and Return Periods from 1 to 100 Years

DAVID M. HERSHFIELD

Cooperative Studies Section, U.S. Weather Bureau, Washington, D.C.

INTRODUCTION

Historical review

Until about 1953, economic and engineering design requiring rainfall frequency data was based largely on Yarnell's paper [1] which contains a series of generalized maps for several combinations of durations and return periods. Yarnell's maps are based on data from about 200 first-order Weather Bureau stations which maintained complete recording-gage records. In 1940, about 5 years after Yarnell's paper was published, a hydrologic network of recording gages was installed to supplement both the Weather Bureau recording gages and the relatively larger number of nonrecording gages. The additional recording gages have subsequently increased the amount of short-duration data by a factor of 20.

Weather Bureau *Technical Paper No. 24*, Parts I and II [2], prepared for the Corps of Engineers in connection with their military construction program, contained the first studies covering an extended area which exploited the hydrologic network data. The results of this work showed the importance of the additional data in defining the short-duration rainfall frequency regime in the mountainous regions of the West. In many instances, the differences between *Technical Paper No. 24* and Yarnell reach a factor of three, with the former generally being larger. Relationships developed and knowledge gained from these studies in the United States were then used to prepare similar reports for the coastal regions of North Africa [3] and several Arctic regions [4] where recording-gage data were lacking.

Cooperation between the Weather Bureau and the Soil Conservation Service began in 1955 for the purpose of defining the depth-area-duration-frequency regime in the United States. *Technical Paper No. 25* [5], which was partly a by-product of previous work performed for the Corps of Engineers, was the first paper published under the sponsorship of the Soil Conservation Service. This paper contains a series of rainfall intensity-duration-frequency curves for 200 first-order Weather Bureau stations. This was followed by *Technical Paper No. 28* [6], which is an expansion of *Technical Paper No. 24* to longer return periods and durations. Next to be published were the five parts of the *Technical Paper No. 29* series [7], which cover the region east of 90° W. Included in this series are seasonal variation on a frequency basis and area-depth curves so that the point frequency values can be transformed to areal frequency. Except for the region between 90° W. and 105° W., the contiguous United States has been covered by generalized rainfall frequency studies prepared by the Weather Bureau since 1953.

General approach

The approach followed in the present study is basically that utilized in [6] and [7]. In these references, simplified duration and return-period relationships and several key maps were used to determine additional combinations of return periods and durations. In

this study, four key maps provided the basic data for these two relationships which were programmed to permit digital computer computations for a 3500-point grid on each of 45 additional maps.

PART I: ANALYSES

Basic data

Types of data.—The data used in this study are divided into three categories. First, there are the recording-gage data from the long-record first-order Weather Bureau stations. There are 200 such stations with records long enough to provide adequate results within the range of return periods of this paper. These data are for the n -minute period containing the maximum rainfall. Second, there are the recording-gage data of the hydrologic network which are published for clock-hour intervals. These data were processed for the 24 consecutive clock-hour intervals containing the maximum rainfall—not calendar-day. Finally, there is the very large amount of nonrecording-gage data with observations made once daily. Use was made of these data to help define both the 24-hour rainfall regime and also the shorter duration regimes through applications of empirical relationships.

Station data.—The sources of data are indicated in table 1. The data from the 200 long-record Weather Bureau stations were used to develop most of the relationships which will be described later. Long records from more than 1600 stations were analyzed to define the relationships for the rarer frequencies (return periods), and statistics from short portions of the record from about 5000 stations were used as an aid in defining the regional pattern for the 2-year return period. Several thousand additional stations were considered but not plotted where the station density was adjudged to be adequate.

Period and length of record.—The nonrecording short-record data were compiled for the period 1938–1957 and long-record data from the earliest year available through 1957. The recording-gage data cover the period 1940–1958. Data from the long-record Weather Bureau stations were processed through 1958. No record of less than five years was used to estimate the 2-year values.

TABLE 1.—Sources of point rainfall data

Duration	No. of stations	Average length of record (yr.)	Reference No.
30-min. to 24-hr.-----	200	48	8, 9, 10
Hourly-----	2081	14	11, 12
Daily (recording)-----	1350	16	11, 12
Daily (nonrecording)-----	3409	15	13
Daily (nonrecording)-----	1426	47	13

Clock-hour vs. 60-minute and observational-day vs. 1440-minute rainfall.—In order to exploit the clock-hour and observational-day data, it was necessary to determine their relationship to the 60-minute and 1440-minute periods containing the maximum rainfall. It was found that 1.13 times a rainfall value for a particular return period based on a series of annual maximum clock-hour rainfalls was equivalent to the amount for the same return period obtained from a series of 60-minute rainfalls. By coincidence, it was found that the same factor can be used to transform observational-day amounts to corresponding 1440-minute return-period amounts. The equation, n -year 1440-minute rainfall (or 60-minute) equals 1.13 times n -year observational-day (or clock-hour) rainfall, is not built on a causal relationship. This is an average index relationship because the distributions of 60-minute and 1440-minute rainfall are very irregular or unpredictable during their respective time intervals. In addition, the annual maxima from the two series for the same year from corresponding durations do not necessarily come from the same storm. Graphical comparisons of these data are presented in figure 1, which shows very good agreement.

24 consecutive clock-hour rainfall vs. 1440-minute rainfall.—The recording-gage data were collected from published sources for the 24 consecutive clock-hours containing the maximum rainfall. Be-

cause of the arbitrary beginning and ending on the hour, a series of these data provides statistics which are slightly smaller in magnitude than those from the 1440-minute series. The average bias was found to be approximately one percent. All such data in this paper have been adjusted by this factor.

Station exposure.—In refined analysis of mean annual and mean seasonal rainfall data it is necessary to evaluate station exposures by methods such as double-mass curve analysis [14]. Such methods do not appear to apply to extreme values. Except for some subjective selections (particularly for long records) of stations that have had consistent exposures, no attempt has been made to adjust rainfall values to a standard exposure. The effects of varying exposure are implicitly included in the areal sampling error and are probably averaged out in the process of smoothing the isopluvial lines.

Rain or snow.—The term rainfall has been used in reference to all durations even though some snow as well as rain is included in some of the smaller 24-hour amounts for the high-elevation stations. Comparison of arrays of all ranking snow events with those known to have only rain has shown trivial differences in the frequency relations for several high-elevation stations tested. The heavier (rarer frequency) 24-hour events and all short-duration events consist entirely of rain.




FIGURE 1.—Relation between 2-year 60-minute rainfall and 2-year clock-hour rainfall; relation between 2-year 1440-minute rainfall and 2-year observational-day rainfall.




FIGURE 2.—Rainfall depth-duration diagram.

Duration analysis

Duration interpolation diagram.—A generalized duration relationship was developed with which the rainfall depth for a selected return period can be computed for any duration between 1 and 24 hours, when the 1- and 24-hour values for that particular return period are given (see fig. 2). This generalization was obtained empirically from data for the 200 Weather Bureau first-order stations. To use this diagram, a straightedge is laid across the values given for 1 and 24 hours and the values for other durations are read at the proper intersections. The quality of this relationship for the 2- and 6-hour durations is illustrated in figures 3 and 4 for stations with a wide range in rainfall magnitude.

Relationship between 30-minute and 60-minute rainfall.—If a 30-minute ordinate is positioned to the left of the 60-minute ordinate on the duration interpolation diagram of figure 2, acceptable estimates can be made of the 30-minute rainfall. This relationship was used in several previous studies. However, tests showed that better results can be obtained by simply multiplying the 60-minute rainfall by the average 30- to 60-minute ratio. The empirical relationship used for estimating the 30-minute rainfall is 0.79 times the 60-minute rainfall. The quality of this relationship is illustrated in figure 5.

Frequency analysis

Two types of series.—This discussion requires consideration of two methods of selecting and analyzing intense rainfall data. One method, using the partial-duration series, includes all the high values. The other uses the annual series which consists only of the highest value for each year. The highest value of record, of course, is the top value of each series, but at lower frequency levels (shorter return periods) the two series diverge. The partial-duration series, having the highest values regardless of the year in which they occur, recognizes that the second highest of some year occasionally exceeds the highest of some other year. The purposes to be served by the atlas require that the results be expressed in terms of partial-duration




FIGURE 3.—Relation between observed 2-year 2-hour rainfall and 2-year 2-hour rainfall computed from duration diagram.




FIGURE 4.—Relation between observed 2-year 6-hour rainfall and 2-year 6-hour rainfall computed from duration diagram.

frequencies. In order to avoid laborious processing of partial-duration data, the annual series were collected, analyzed, and the resulting statistics transformed to partial-duration statistics.

Conversion factors for two series.—Table 2, based on a sample of a number of widely scattered Weather Bureau first-order stations, gives the empirical factors for converting the partial-duration series to the annual series.




FIGURE 5.—Relation between 2-year 30-minute rainfall and 2-year 60-minute rainfall.




FIGURE 6.—Relation between partial-duration and annual series.




FIGURE 7.—Rainfall depth versus return period.

EXAMPLE. If the 2-, 5-, and 10-year partial-duration series values estimated from the maps at a particular point are 3.00, 3.75, and 4.21 inches, respectively, what are the annual series values for corresponding return periods? Multiplying by the appropriate conversion factors of table 2 gives 2.64, 3.60, and 4.17 inches.

The quality of the relationship between the mean of the partial-duration series and the mean of the annual series data for the 1-, 6-, and 24-hour durations is illustrated in figure 6. The means for both series are equivalent to the 2.3-year return period. Tests with samples of record length from 10 to 50 years indicate that the factors of table 2 are independent of record length.

TABLE 2.—Empirical factors for converting partial-duration series to annual series

Return period	Conversion factor
2-year.....	0.88
5-year.....	0.96
10-year.....	0.99

Frequency considerations.—Extreme values of rainfall depth form a frequency distribution which may be defined in terms of its moments. Investigations of hundreds of rainfall distributions with lengths of record ordinarily encountered in practice (less than 50 years) indicate that these records are too short to provide reliable statistics beyond the first and second moments. The distribution must therefore be regarded as a function of the first two moments. The 2-year value is a measure of the first moment—the central

tendency of the distribution. The relationship of the 2-year to the 100-year value is a measure of the second moment—the dispersion of the distribution. These two parameters, 2-year and 100-year rainfall, are used in conjunction with the return-period diagram of figure 7 for estimating values for other return periods.

Construction of return-period diagram.—The return-period diagram of figure 7 is based on data from the long-record Weather Bureau stations. The spacing of the vertical lines on the diagram is partly empirical and partly theoretical. From 1 to 10 years it is entirely empirical, based on freehand curves drawn through plottings of partial-duration series data. For the 20-year and longer return periods reliance was placed on the Gumbel procedure for fitting annual series data to the Fisher-Tippett type I distribution [15]. The transition was smoothed subjectively between 10- and 20-year return periods. If rainfall values for return periods between 2 and 100 years are taken from the return-period diagram of figure 7, converted to annual series values by applying the factors of table 2, and plotted on either Gumbel or log-normal paper, the points will very nearly approximate a straight line.




FIGURE 8.—Distribution of 1-hour stations.

Use of diagram.—The two intercepts needed for the frequency relation in the diagram of figure 7 are the 2-year values obtained from the 2-year maps and the 100-year values from the 100-year maps. Thus, given the rainfall values for both 2- and 100-year return periods, values for other return periods are functionally related and may be determined from the frequency diagram which is entered with the 2- and 100-year values.

General applicability of return-period relationship.—Tests have shown that within the range of the data and the purpose of this paper, the return-period relationship is also independent of duration. In other words, for 30 minutes, or 24 hours, or any other duration within the scope of this report, the 2-year and 100-year values define the values for other return periods in a consistent manner. Studies have disclosed no regional pattern that would improve the return-period diagram which appears to have application over the entire United States.

Secular trend.—The use of short-record data introduces the question of possible secular trend and biased sample. Routine tests with subsamples of equal size from different periods of record for the same

station showed no appreciable trend, indicating that the direct use of the relatively recent short-record data is legitimate.

Storms combined into one distribution.—The question of whether a distribution of extreme rainfall is a function of storm type (tropical or nontropical storm) has been investigated and the results presented in a recent paper [16]. It was found that no well-defined dichotomy exists between the hydrologic characteristics of hurricane or tropical storm rainfall and those of rainfall from other types of storms. The conventional procedure of analyzing the annual maxima without regard to storm type is to be preferred because it avoids non-systematic sampling. It also eliminates having to attach a storm-type label to the rainfall, which in some cases of intermediate storm type (as when a tropical storm becomes extratropical) is arbitrary.

Predictive value of theoretical distribution.—Estimation of return periods requires an assumption concerning the parametric form of the distribution function. Since less than 10 percent of the more than 6000 stations used in this study have records for 60 years or longer, this raises the question of the predictive value of the results—particularly, for the longer return periods. As indicated previously,




FIGURE 9.—Distribution of 24-hour stations.

reliance was placed on the Gumbel procedure for fitting data to the Fisher-Tippett type I distribution to determine the longer return periods. A recent study [17] of 60-minute data which was designed to appraise the predictive value of the Gumbel procedure provided definite evidence for its acceptability.

Isopluvial maps

Methodology.—The factors considered in the construction of the isopluvial maps were availability of data, reliability of the return period estimates, and the range of duration and return periods required for this paper. Because of the large amount of data for the 1- and 24-hour durations and the relatively small standard error associated with the estimates of the 2-year values, the 2-year 1- and 24-hour maps were constructed first. Except for the 30-minute duration, the 1- and 24-hour durations envelop the durations required for this study. The 100-year 1- and 24-hour maps were then prepared because this is the upper limit of return period. The four key maps: 2-year 1-hour, 2-year 24-hour, 100-year 1-hour, and 100-year

24-hour, provided the data to be used jointly with the duration and frequency relationships of the previous sections for obtaining values for the other 45 maps. This procedure permits variation in two directions—one for duration and the other for return period. The 49 isopluvial maps are presented in Part II as Charts 1 to 49.

Data for 2-year 1-hour map.—The dot map of figure 8 shows the location of the stations for which data were actually plotted on the map. Additional stations were considered in the analysis but not plotted in regions where the physiography could have no conceivable influence on systematic changes in the rainfall regime. All available recording-gage data with at least 5 years of record were plotted for the mountainous region west of 104° W. In all, a total of 2281 stations were used to define the 2-year 1-hour pattern of which 60 percent are for the western third of the country.

Data for 2-year 24-hour map.—Figure 9 shows the locations of the 6000 stations which provided the 24-hour data used to define the 2-year 24-hour isopluvial pattern. Use was made of most of the stations in mountainous regions including those with only 5 years of record. As indicated previously, the data have been adjusted where

necessary so that they are for the 1440-minute period containing the maximum rainfall rather than observational-day.

Smoothing of 2-year 1-hour and 2-year 24-hour isopluvial lines.—The manner of construction involves the question of how much to smooth the data, and an understanding of the problem of data smoothing is necessary to the most effective use of the maps. The problem of drawing isopluvial lines through a field of data is analogous in some important respects to drawing regression lines through the data of a scatter diagram. Just as isolines can be drawn so as to fit every point on the map, an irregular regression line can be drawn to pass through every point; but the complicated pattern in each case would be unrealistic in most instances. The two qualities, smoothness and fit, are basically inconsistent in the sense that smoothness may not be improved beyond a certain point without some sacrifice of closeness of fit, and vice versa. The 2-year 1- and 24-hour maps were deliberately drawn so that the standard error of estimate (the inherent error of interpolation) was commensurate with the sampling and other errors in the data and methods of analysis.

Ratio of 100-year to 2-year 1- and 24-hour rainfall.—Two working maps were prepared showing the 100-year to 2-year ratio for the 1- and 24-hour durations. In order to minimize the exaggerated effect that an outlier (anomalous event) from a short record has on the magnitude of the 100-year value, only the data from stations with minimum record lengths of 18 years for the 1-hour and 40 years for the 24-hour were used in this analysis. As a result of the large sampling errors associated with these ratios, it is not unusual to find a station with a ratio of 2.0 located near a 3.0 ratio even in regions where orographic influences on the rainfall regime are absent. As a group, the stations' ratios mask out the station-to-station disparities and provide a more reliable indication of the direction of distribution than the individual station data. A macro-examination revealed that some systematic geographical variation was present which would justify the construction of smoothed ratio maps with a small range. The isopleth patterns constructed for the two maps are not identical but the ratios on both maps range from about 2.0 to 3.0. The average ratio is about 2.3 for the 24-hour duration and 2.2 for the 1-hour.

100-year 1-hour and 24-hour maps.—The 100-year values which were computed for 3500 selected points (fig. 10) are the product of the values from the 2-year maps and the 100-year to 2-year ratio maps. Good definition of the complexity of pattern and steepness of gradient of the 2-year 1- and 24-hour maps determined the geographically unbalanced grid density of figure 10.

45 additional maps.—The 3500-point grid of figure 10 was also used to define the isopluvial patterns of the 45 additional maps. Four values—one from each of the four key maps—were read for each grid point. Programming of the duration and return-period relationships plus the four values for each point permitted digital computer computation for the 45 additional points. The isolines were positioned by interpolation with reference to numbers at the grid points. This was necessary to maintain the internal consistency of the series of maps. Pronounced "high" and "low" are positioned in consistent locations on all maps. Where the 1- to 24-hour ratio for a particular area is small, the 24-hour values have the greatest influence on the pattern of the intermediate duration maps. Where the 1- to 24-hour ratio is large, the 1-hour value appears to have the most influence on the intermediate duration pattern.

Reliability of results.—The term reliability is used here in the statistical sense to refer to the degree of confidence that can be placed in the accuracy of the results. The reliability of results is influenced by sampling error in time, sampling error in space, and by the manner in which the maps were constructed. Sampling error in space is a result of the two factors: (1) the chance occurrence of an anomalous storm which has a disproportionate effect on one station's statistics but not on the statistics of a nearby station, and (2) the geographical distribution of stations. Where stations are farther apart than in the dense networks studied for this project, stations may experience rainfalls that are nonrepresentative of their vicinity, or may completely miss rainfalls that are representative. Similarly, sampling error in time results from rainfalls not occurring according to their average regime during a brief record. A brief period of record may include some nonrepresentative large storms, or may miss some important storms that occurred before or after the period of record at a given station. In evaluating the effects of areal and time sampling errors, it is pertinent to look for and to evaluate bias and dispersion. This is discussed in the following paragraphs.

Spatial sampling error.—In developing the area-depth relations, it was necessary to examine data from several dense networks. Some of these dense networks were in regions where the physiography could have little or no effect on the rainfall regime. Examination of these data showed, for example, that the standard deviation of point rainfall for the 2-year return period for a flat area of 300 square miles is about 20 percent of the mean value. Seventy 24-hour stations in Iowa, each with more than 40 years of record, provided another indication of the effect of spatial sampling error. Iowa's rainfall regime is not influenced locally by orography or bodies of water. The 2-year 24-hour isopluvials in Iowa show a range from 3.0 to 3.3 inches. The average deviation of the 70 2-year values from the

smoothed isopluvials is about 0.2 inch. Since there are no assignable causes for these dispersions, they must be regarded as a residual error in sampling the relatively small amount of extreme-value data available for each station.

The geographical distribution of the stations used in the analysis is portrayed on the dot maps of figures 8 and 9. Even this relatively dense network cannot reveal very accurately the fine structure of the isopluvial pattern in the mountainous regions of the West. A measure of the sampling error is provided by a comparison of a 2-year 1-hour generalized map for Los Angeles County (4000 square miles) based on 30 stations with one based on 110 stations. The average difference for values from randomly selected points from both maps was found to be approximately 20 percent.

Sampling error in time.—Sampling error in time is present because the data at individual stations are intended to represent a mean condition that would hold over a long period of time. Daily data from 200 geographically dispersed long-record stations were analyzed for 10- and 50-year records to determine the reliability or level of confidence that should be placed on the results from the short-record data. The diagram of figure 11 shows the scatter of the means of the extreme-value distributions for the two different lengths of record. The slight bias which is exhibited is a result of the skewness of the extreme-value distribution. Accordingly, more weight was given to the longer-record stations in the construction of the isopluvials.

Isoline interval.—The isoline intervals are 0.2, 0.5, or 1.0 inch depending on the range and magnitude of the rainfall values. A uniform interval has been used on a particular map except in the two following instances: (1) a dashed intermediate line has been placed between two widely separated lines as an aid to interpolation, and (2) a larger interval was used where necessitated by a steep gradient. "Lows" that close within the boundaries of the United States have been hatched inwardly.

Maintenance of consistency.—Numerous statistical maps were made in the course of these investigations in order to maintain the internal consistency. In situations where it has been necessary to estimate hourly data from daily observations, experience has demonstrated that the ratio of 1-hour to corresponding 24-hour values for the same return period does not vary greatly over a small region. This knowledge served as a useful guide in smoothing the isopluvials. On the windward sides of high mountains in western United States, the 1- to 24-hour ratio is as low as 10 percent. In southern Arizona and some parts of midwestern United States, it is greater than 60 percent. In general, except for Arizona, the ratio is less than 40 percent west of the Continental Divide and greater than 40 percent to the east. There is a fair relationship between this ratio and the climatic factor, mean annual number of thunderstorm days. The two parameters, 2-year daily rainfall and the mean annual number of thunderstorm days, have been used jointly to provide an estimate of short-duration rainfalls [18]. A 1- to 24-hour ratio of 40 percent is approximately the average for the United States.

Examination of physiographic parameters.—Work with mean annual and mean seasonal rainfall has resulted in the derivation of empirically defined parameters relating rainfall data to the physiography of a region. Elevation, slope, orientation, distance from moisture source, and other parameters have been useful in drawing maps of mean rainfall. These and other parameters were examined in an effort to refine the maps presented here. However, tests showed that the use of these parameters would result in no improvement in the rainfall-frequency pattern because of the sampling and other error inherent in values obtained for each station.

Evaluation.—In general, the standard error of estimate ranges from a minimum of about 10 percent, where a point value can be used directly as taken from a flat region of one of the 2-year maps to 50 percent where a 100-year value of short-duration rainfall must be estimated for an appreciable area in a more rugged region.

Internal inconsistency.—On some maps the isoline interval does not reveal the fact that the magnitude does not vary linearly by interpolation. Therefore, interpolation of several combinations of durations and return periods for the point of interest might result in such inconsistencies as a 12-hour value being larger than a 24-

hour value for the same return period or that a 50-year value exceeds the 100-year value for the same duration. These errors, however, are well within the acknowledged margin of error. If the reader is interested in more than one duration or return period this potential source of inconsistency can be eliminated by constructing a series of depth-duration-frequency curves by fitting smoothed curves on logarithmic paper to the values interpolated from all 49 maps. Figure 12 illustrates a set of curves for the point at 35° N., 90° W. The interpolated values for a particular duration should very nearly approximate a straight line on the return-period diagram of figure 7.

Obsolescence.—Additional stations rather than longer records will speed obsolescence and lessen the current accuracy of the maps. The comparison with Yarnell's paper [1] is a case in point. Where data for new stations are available, particularly in the mountainous regions, the isopluvial patterns of the two papers show pronounced differences. At stations which were used for both papers, even with 25 years of additional data, the differences are negligible.

Guides for estimating durations and/or return periods not presented on the maps

Intermediate durations and return periods.—In some instances, it might be required to obtain values within the range of return periods and durations presented in this paper but for which no maps have been prepared. A diagram similar to that illustrated in figure 12 can serve as a nomogram for estimating these required values.

Return periods longer than 100 years.—Values for return periods longer than 100 years can be obtained by plotting several values from 2 to 100 years from the same point on all the maps on either log-normal or extreme-value probability paper. A straight line fitted to the data and extrapolated will provide an acceptable estimate of, say, the 200-year value. It should be remembered that the values on the maps are for the partial-duration series, therefore, the 2-, 5-, and 10-year values should first be reduced by the factors of table 2.

EXAMPLE. The 200-year 1-hour value is required for the point

at 35° N., 90° W. The 2-, 5-, 10-, 25-, 50-, and 100-year values are estimated from the maps to be 1.7, 2.2, 2.5, 2.9, 3.1, and 3.5 inches. After multiplying the 2-year value by 0.88, the 5-year value by 0.96, and the 10-year value by 0.99, the six values are plotted on extreme-value probability paper, a line is fitted to the data and extrapolated linearly. The 200-year value is thus estimated to be about 3.8 inches (see fig. 13).

Durations shorter than 30 minutes.—If durations shorter than 30 minutes are required, the average relationships between 30-minute rainfall on the one hand and the 5-, 10-, and 15-minute rainfall on the other can be obtained from table 3. These relationships were developed from the data of the 200 Weather Bureau first-order stations.

TABLE 3.—Average relationship between 30-minute rainfall and shorter duration rainfall for the same return period

Duration (min.)	5	10	15
Ratio	0.37	0.57	0.72
Average error (percent)	8	7	5




FIGURE 10.—Grid density used to construct additional maps.




FIGURE 11.—Relation between means from 50-year and 10-year records (24-hour duration).




FIGURE 12.—Example of internal consistency check.

Comparisons with previous rainfall frequency studies

Yarnell.—A comparison of the results of this paper with those obtained by Yarnell's paper [1] brings out several interesting points. First, both papers show approximately the same values for the Weather Bureau first-order stations even though 25 years of additional data are now available. Second, even though thousands of additional stations were used in this study, the differences between the two papers in the eastern half of the country are quite small

and rarely exceed 10 percent. However, in the mountainous regions of the West, the enlarged inventory of data now available has had a profound effect on the isopluvial pattern. In general, the results from this paper are larger in the West with the differences occasionally reaching a factor of three.

Technical Paper No. 25.—*Technical Paper No. 25* [5] contains a series of rainfall intensity-duration-frequency curves for the 200 Weather Bureau stations. The curves were developed from each station's data with no consideration given to anomalous events or to areal generalization. The average difference between the two papers is approximately 10 percent with no bias. After accounting for the fact that this atlas is for the partial-duration series and *Technical Paper No. 25* is for the annual series, the differences can be ascribed to the considerable areal generalization used in this paper.

Technical Paper No. 24, Parts I and II; Technical Paper No. 28.—The differences in refinement between *Technical Paper No. 24* [2] and *Technical Paper No. 28* [6] on the one hand and this paper on the other do not, however, seem to influence the end results to an important degree. Inspection of the values in several rugged areas, as well as in flat areas, reveals disparities which average about 20 percent. This is attributable to the much larger amount of data (both longer records and more stations) and the greater areal generalization used in this paper.

Technical Paper No. 29, Parts 1 through 5.—The salient feature of the comparison of *Technical Paper No. 29* [7] with this paper is the very small disparities between the four key maps and the slightly larger disparities between the intermediate maps. The average differences are of the order of magnitude of 10 and 20 percent, respectively. The larger difference between the intermediate maps




FIGURE 13.—Example of extrapolating to long return periods.

is attributable to the smoothing of these maps in a consistent manner for this paper.

Probability considerations

General.—The analysis presented thus far has been mainly concerned with attaching a probability to a particular magnitude of rainfall at a particular location. Once this probability has been determined, consideration must also be given to the corollary question: What is the probability that the n -year event will occur at least once in the next n years?

From elementary probability theory it is known that there is a good chance that the n -year event will occur at least once before n years have elapsed. For example, if an event has the probability $1/n$ of occurring in a particular year (assume the annual series is being used), where n is 10 or greater, the probability, P , of the event occurring at least once among n observations (or years) is

$$P = 1 - (1 - 1/n)^n \approx 1 - e^{-1} = 0.63$$

Thus, for example, the probability that the 10-year event will occur at least once in the next 10 years is 0.63, or about 2 chances out of 3.

Relationship between design return period, T years, design period, T_d , and probability of not being exceeded in T_d years.—Figure 14, prepared from theoretical computations, shows the relationship between the design return period, T years, design period, T_d , and probability of not being exceeded in T_d years [19].

EXAMPLE. What design return period should the engineer use to be approximately 90 percent certain that it will not be exceeded in the next 10 years? Entering the design period coordinate at 10 years until the 90 percent line is intersected, the design return period is estimated to be 100 years. In terms of rainfall magnitude, the 100-year value is approximately 50 percent larger than the 10-year value.




FIGURE 14.—Relationship between design return period, T years, design period, T_d , and probability of not being exceeded in T_d years.




FIGURE 15.—Area-depth curves.

Probable maximum precipitation (PMP)

The 6-hour PMP and its relationship to the 100-year 6-hour rainfall.—Opposed to the probability method of rainfall estimation presented in this paper is the probable maximum precipitation (PMP) method which uses a combination of physical model and several estimated meteorological parameters. The main purpose of the PMP method is to provide complete-safety design criteria in cases where structure failure would be disastrous. The 6-hour PMP map of Chart 50 is based on the 10-square-mile values of *Hydrometeorological Report No. 33* [20] for the region east of 105° W. and on Weather Bureau *Technical Paper No. 38* [21] for the West. Chart 51 presents the ratios of the PMP values to the 100-year point rainfalls of this paper. Examination of this map shows that the ratios vary from less than 2 to about 9. These results must be considered merely indicative of the order of magnitude of extremely rare rainfalls.

Area-depth relationships

General.—For drainage areas larger than a few square miles consideration must be given not only to point rainfall, but to the average depth over the entire drainage area. The average area-depth relationship, as a percent of the point values, has been determined for 20 dense networks up to 400 square miles from various regions in the United States [7].

The area-depth curves of figure 15 must be viewed operationally. The operation is related to the purpose and application. In application the process is to select a point value from an isopluvial map. This point value is the average depth for the location concerned, for a given frequency and duration. It is a composite. The area-depth curve relates this average point value, for a given duration and frequency and within a given area, to the average depth over that area for the corresponding duration and frequency.

The data used to develop the area-depth curves of figure 15 exhibited no systematic regional pattern [7]. Duration turned out to be the major parameter. None of the dense networks had sufficient length of record to evaluate the effect of magnitude (or return period) on the area-depth relationship. For areas up to 400 square miles, it is tentatively accepted that storm magnitude (or return period) is not a parameter in the area-depth relationship. The reliability of this relationship appears to be best for the longer durations.

EXAMPLE What is the average depth of 2-year 3-hour rainfall for a 200-square-mile drainage area in the vicinity of 37° N, 86° W.? From the 2-year 3-hour map, 2.0 inches is estimated as the average depth for points in the area. However, the average 3-hour depth over the drainage area would be less than 2.0 inches for the 2-year return period. Referring to figure 15, it is seen that the 3-hour curve intersects the area scale at 200 square miles at ratio 0.8. Accordingly, the 2-year 3-hour average depth over 200 square miles is 0.8 times 2.0, or 1.6 inches.

Seasonal variation

Introduction.—To this point, the frequency analysis has followed the conventional procedures of using only the annual maxima or the n -maximum events for n years of record. Obviously, some months contribute more events to these series than others and, in fact, some months might not contribute at all to these two series. Seasonal variation serves the purpose of showing how often these rainfall events occur during a specific month. For example, a practical problem concerned with seasonal variation may be illustrated by the fact that the 100-year 1-hour rain may come from a summer thunderstorm, with considerable infiltration, whereas the 100-year flood may come from a lesser storm occurring on frozen or snow-covered ground in the late winter or early spring.

Seasonal probability diagrams.—A total of 24 seasonal variation diagrams is presented in Charts 52, 53, and 54 for the 1-, 6-, and 24-hour durations for 8 subregions of the United States east of 105° W. The 15 diagrams covering the region east of 90° W. are identical to those presented previously in *Technical Paper No. 29* [7]. The smoothed isopleths of a diagram for a particular duration are based on the average relationship from approximately 15 stations in each subregion. Some variation exists from station to station, suggesting a slight subregional pattern, but no attempt was made to define it because there is no conclusive method of determining whether this pattern is a climatic fact or an accident of sampling. The slight regional discontinuities between curves of adjacent subregions can be smoothed locally for all practical purposes. No seasonal variation relationships are presented for the mountainous region west of 105° W. because of the influence of local climatic and topographic conditions. This would call for seasonal distribution curves constructed from each station's data instead of average and more reliable curves based on groups of stations.

Application to areal rainfall.—The analysis of a limited amount of areal rainfall data in the same manner as the point data gave seasonal variations which exhibited no substantial difference from those of the point data. This lends some confidence in using these diagrams as a guide for small areas.

EXAMPLE. Determine the probability of occurrence of a 10-year 1-hour rainfall for the months May through August for the point at 45° N., 85° W. From Chart 52, the probabilities for each month are interpolated to be 1, 2, 4, and 2 percent, respectively. In other words, the probability of occurrence of a 10-year 1-hour rainfall in May of any particular year is 1 percent; for June, 2 percent; and so forth. (Additional examples are given in all five parts of *Technical Paper No. 29*.)

References

1. D. L. Yarnell, "Rainfall Intensity-Frequency Data," *Miscellaneous Publication No. 204*, U.S. Department of Agriculture, Washington, D.C., 1935, 68 pp.
2. U.S. Weather Bureau, "Rainfall Intensities for Local Drainage Design in the United States for Durations of 5 to 240 Minutes and 2-, 5-, and 10-Year Return Periods," *Technical Paper No. 24*, "Part I: West of the 115th Meridian," Washington, D.C., August 1953, 19 pp. Revised February 1955. "Part II: Between 105° W. and 115° W.," Washington, D.C., August 1954, 9 pp.
3. U.S. Weather Bureau, "Rainfall Intensities for Local Drainage Design in Coastal Regions of North Africa, Longitude 11° W. to 14° E. for Durations of 5 to 240 Minutes and 2-, 5-, and 10-Year Return Periods," Washington, D.C., September 1954, 13 pp.
4. U.S. Weather Bureau, "Rainfall Intensities for Local Drainage Design in Arctic and Subarctic Regions of Alaska, Canada, Greenland, and Iceland for Durations of 5 to 240 Minutes and 2-, 5-, 10-, 20-, and 50-Year Return Periods," Washington, D.C., September 1955, 13 pp.
5. U.S. Weather Bureau, "Rainfall Intensity-Duration-Frequency Curves for Selected Stations in the United States, Alaska, Hawaiian Islands, and Puerto Rico," *Technical Paper No. 25*, Washington, D.C., December 1955, 53 pp.
6. U.S. Weather Bureau, "Rainfall Intensities for Local Drainage Design in Western United States," *Technical Paper No. 28*, Washington, D.C., November 1956, 46 pp.
7. U.S. Weather Bureau, "Rainfall Intensity-Frequency Regime," *Technical Paper No. 29*, "Part 1: The Ohio Valley," June 1957, 44 pp.; "Part 2: Southeastern United States," March 1958, 51 pp.; "Part 3: The Middle Atlantic Region," July 1958, 37 pp.; "Part 4: Northeastern United States," May 1959, 35 pp.; "Part 5: Great Lakes Region," February 1960, 31 pp. Washington, D.C.
8. U.S. Weather Bureau, Form 1017, 1890-1958.
9. U.S. Weather Bureau, *Climatological Record Book*, 1890-1958.
10. U.S. Weather Bureau, *Climatological Data, National Summary*, monthly, 1950-1958.
11. U.S. Weather Bureau, *Hydrologic Bulletin*, 1940-1948.
12. U.S. Weather Bureau, *Hourly Precipitation Data*, 1951-1958.
13. U.S. Weather Bureau, *Climatological Data*, by Sections 1897-1958.
14. M. A. Kohler, "Double-Mass Analysis for Testing the Consistency of Records and for Making Required Adjustments," *Bulletin of the American Meteorological Society*, vol. 30, No. 5, May 1949, pp. 188-189.
15. E. J. Gumbel, *Statistics of Extremes*, Columbia University Press, 1958, 375 pp.
16. D. M. Hershfield and W. T. Wilson, "A Comparison of Extreme Rainfall Depths from Tropical and Nontropical Storms," *Journal of Geophysical Research*, vol. 65, No. 3, March 1960, pp. 959-982.
17. D. M. Hershfield and M. A. Kohler, "An Empirical Appraisal of the Gumbel Extreme-Value Procedure," *Journal of Geophysical Research*, vol. 65, No. 6, June 1960, pp. 1737-1746.
18. D. M. Hershfield, L. L. Weiss, and W. T. Wilson, "Synthesis of Rainfall Intensity-Frequency Regime," *Proceedings, American Society of Civil Engineers*, vol. 81, Sep. No. 744, July 1955, pp. 1-6.
19. Arnold Court, "Some New Statistical Techniques in Geophysics," *Advances in Geophysics*, vol. 1, Academic Press, New York, 1952, pp. 45-85.
20. U.S. Weather Bureau, "Seasonal Variation of the Probable Maximum Precipitation East of the 105th Meridian for Areas from 10 to 1000 Square Miles and Durations of 6, 12, 24, and 48 Hours," *Hydrometeorological Report No. 33*, April 1956, 58 pp.
21. U.S. Weather Bureau, "Generalized Estimates of Probable Maximum Precipitation for the United States West of the 105th Meridian for Areas to 400 Square Miles and Durations to 24 Hours," *Technical Paper No. 33*, 1960, 66 pp.


PART II

Charts 1-49: Isopluvial maps.


Charts 50-51: The 6-hour probable maximum precipitation and its relationship to the 100-year 6-hour rainfall.

Charts 52-54: Diagrams of seasonal probability of intense rainfall, for 1-, 6-, and 24-hour durations.


1 - YEAR 30 - MINUTE RAINFALL (INCHES)




2-YEAR 30-MINUTE RAINFALL (INCHES)




5-YEAR 30-MINUTE RAINFALL (INCHES)




10-YEAR 30-MINUTE RAINFALL (INCHES)




25-YEAR 30-MINUTE RAINFALL (INCHES)




50-YEAR 30-MINUTE RAINFALL (INCHES)




100-YEAR 30-MINUTE RAINFALL (INCHES)




1-YEAR 1-HOUR RAINFALL (INCHES)




2-YEAR 1-HOUR RAINFALL (INCHES)




5-YEAR 1-HOUR RAINFALL (INCHES)




10-YEAR 1-HOUR RAINFALL (INCHES)




25-YEAR 1-HOUR RAINFALL (INCHES)




50-YEAR 1-HOUR RAINFALL (INCHES)




100-YEAR 1-HOUR RAINFALL (INCHES)




1-YEAR 2-HOUR RAINFALL (INCHES)




2-YEAR 2-HOUR RAINFALL (INCHES)



5-YEAR 2-HOUR RAINFALL (INCHES)



10-YEAR 2-HOUR RAINFALL (INCHES)




0 100 200 300 400 500 600
ALBERS EQUAL AREA PROJECTION
STANDARD PARALLELS 31° AND 41°

25-YEAR 2-HOUR RAINFALL (INCHES)




50-YEAR 2-HOUR RAINFALL (INCHES)




ALBERS EQUAL AREA PROJECTION
STANDARD PARALLELS 27° AND 41°


100-YEAR 2-HOUR RAINFALL (INCHES)



1-YEAR 3-HOUR RAINFALL (INCHES)




2-YEAR 3-HOUR RAINFALL (INCHES)




ALBERS EQUAL AREA PROJECTION
STANDARD PARALLELS 25° AND 49°


5-YEAR 3-HOUR RAINFALL (INCHES)




10-YEAR 3-HOUR RAINFALL (INCHES)




25-YEAR 3-HOUR RAINFALL (INCHES)




50-YEAR 3-HOUR RAINFALL (INCHES)




100-YEAR 3-HOUR RAINFALL (INCHES)




1-YEAR 6-HOUR RAINFALL (INCHES)




2-YEAR 6-HOUR RAINFALL (INCHES)




5-YEAR 6-HOUR RAINFALL (INCHES)




10-YEAR 6-HOUR RAINFALL (INCHES)




25-YEAR 6-HOUR RAINFALL (INCHES)




50-YEAR 6-HOUR RAINFALL (INCHES)




100-YEAR 6-HOUR RAINFALL (INCHES)




1-YEAR 12-HOUR RAINFALL (INCHES)



2-YEAR 12-HOUR RAINFALL (INCHES)




5-YEAR 12-HOUR RAINFALL (INCHES)




ALBERS EQUAL AREA PROJECTION
STANDARD PARALLELS 25° AND 45°


10-YEAR 12-HOUR RAINFALL (INCHES)




25-YEAR 12-HOUR RAINFALL (INCHES)




50-YEAR 12-HOUR RAINFALL (INCHES)




100-YEAR 12-HOUR RAINFALL (INCHES)




1-YEAR 24-HOUR RAINFALL (INCHES)




2-YEAR 24-HOUR RAINFALL (INCHES)




5-YEAR 24-HOUR RAINFALL (INCHES)




10-YEAR 24-HOUR RAINFALL (INCHES)




25-YEAR 24-HOUR RAINFALL (INCHES)



50-YEAR 24-HOUR RAINFALL (INCHES)




100-YEAR 24-HOUR RAINFALL (INCHES)




ALBERS EQUAL AREA PROJECTION
STANDARD PARALLELS 25° AND 45°










PROBABLE MAXIMUM 6-HOUR PRECIPITATION FOR 10 SQUARE MILES (INCHES)



**RATIO OF PROBABLE MAXIMUM 6-HOUR PRECIPITATION FOR 10 SQUARE MILES
TO 100-YEAR 6-HOUR RAINFALL**












SEASONAL PROBABILITY OF INTENSE 1-HOUR RAINFALL












PROBABILITY IN PERCENT OF OBTAINING A RAINFALL IN ANY MONTH OF A PARTICULAR YEAR EQUAL TO OR EXCEEDING THE RETURN PERIOD VALUES TAKEN FROM THE ISOPLUVIAL MAPS.

SEASONAL PROBABILITY OF INTENSE 6-HOUR RAINFALL



PROBABILITY IN PERCENT OF OBTAINING A RAINFALL IN ANY MONTH OF A PARTICULAR YEAR EQUAL TO OR EXCEEDING THE RETURN PERIOD VALUES TAKEN FROM THE ISOPLUVIAL MAPS.

SEASONAL PROBABILITY OF INTENSE 24-HOUR RAINFALL



PROBABILITY IN PERCENT OF OBTAINING A RAINFALL IN ANY MONTH OF A PARTICULAR YEAR EQUAL TO OR EXCEEDING THE RETURN PERIOD VALUES TAKEN FROM THE ISOPLUVIAL MAPS.

**USWB 1964 - Technical Paper No. 49, Two- to Ten-Day
Precipitation for Return Periods of 2 to 100 Years in the
Contiguous United States,
U.S. Department of Commerce, Weather Bureau, 1964.**

TECHNICAL PAPER NO. 49

TWO- TO TEN-DAY PRECIPITATION FOR RETURN PERIODS OF
2 TO 100 YEARS IN THE CONTIGUOUS UNITED STATES



WASHINGTON, D.C.

1964

OKLAHOMA CITY, OKLA.
RECEIVED
OCT 5 - 1964
USGS
SURFACE WATER BRANCH

U.S. DEPARTMENT OF COMMERCE

LUTHER H. HODGES, *Secretary*

WEATHER BUREAU

ROBERT M. WHITE, *Chief*

TECHNICAL PAPER NO. 49

Two- to Ten-Day Precipitation for Return Periods of
2 to 100 Years in the Contiguous United States

Prepared by

JOHN F. MILLER

Cooperative Studies Section, Office of Hydrology, U.S. Weather Bureau

for

Engineering Division, Soil Conservation Service, U.S. Department of Agriculture



WASHINGTON, D.C.

1964

PREFACE

Authority.—This report was prepared for the Soil Conservation Service to provide generalized rainfall information for planning and design purposes in connection with its Watershed Protection and Flood Prevention Program (authorization: P.L. 566, 83d Congress, and as amended).

Scope.—Precipitation data for various hydrologic design problems involving areas up to 400 square miles and durations from 2 to 10 days are presented. The data consist of generalized estimates of rainfall-frequency data for return periods from 2 to 100 years.

Accuracy of results.—The degree of accuracy of the generalized estimates depicted on the rainfall-frequency maps presented in this report is believed to be adequate for practically all engineering purposes. It should be expected that somewhat greater accuracy might have been obtained had the maps been based on data from the several thousand available precipitation gages instead of from a few hundred. However, the collection and frequency analysis of rainfall data for durations up to 10 days for a few thousand gages would have been a formidable task and an extremely costly enterprise. Furthermore, the accuracy of the results obtained is much greater than indicated by the relatively small number of stations used since the approach involved the projection of the 24-hour rainfall-frequency maps of *Technical Paper No. 40* [1], which are based on data from several thousand stations. The possible greater accuracy that might have been obtained by use of data from a much larger number of gages was judged to be incommensurate with the much greater cost involved.

Acknowledgments.—The project was under the general supervision of J. L. H. Paulhus, Chief of the Cooperative Studies Section of the Office of Hydrology, W. E. Hiatt, Acting Director. L. L. Weiss assisted with the investigations. W. E. Miller and N. S. Foat supervised the collection and processing of the basic data. Drafting was supervised by C. W. Gardner. Coordination with the Soil Conservation Service was maintained through H. O. Ogrosky, Chief, Hydrology Branch, Engineering Division.

CONTENTS

	Page
PREFACE.....	ii
INTRODUCTION.....	1
BASIC DATA.....	1
Summarization of data—Period and length of record—Station exposure.	
DURATION ANALYSIS.....	2
<i>n</i> -hour vs. observational-day precipitation—Duration-interpolation diagram.	
FREQUENCY ANALYSIS.....	2
Two types of series—Frequency considerations—Construction of return-period diagram—Use of return-period diagram—General applicability of return-period diagram—Secular trend.	
ISOPLUVIAL MAPS.....	2
Relation between 2-year 24- and 240-hour amounts—Smoothing of isopluvial maps—2-year 10-day map—Ratio of 100-year to 2-year values—100-year 10-day map—22 additional maps—Reliability of results—Isoline interval—Smoothing values read from maps.	
DEPTH-AREA RELATIONSHIPS.....	4
Introduction—Data used—Determination of area of networks—Construction of the curves—Geographic variation.	
SEASONAL VARIATION.....	4
REFERENCES.....	5

LIST OF ILLUSTRATIONS

Figure 1.—Precipitation stations.....	1
Figure 2.—Relation between 2-year 2-observational-day and 2-year 48-hour precipitation.....	2
Figure 3.—Duration-interpolation diagram.....	2
Figure 4.—Relation between 2-year 4-day precipitation computed by extreme value analysis and 2-year 4-day precipitation estimated from duration-interpolation diagram (fig. 3).....	2
Figure 5.—Return-period—interpolation diagram.....	2
Figure 6.—Relationship for estimating 2-year 10-day precipitation.....	3
Figure 7.—Relation between 2-year 10-day precipitation computed by extreme value analysis and 2-year 10-day precipitation estimated from figure 6.....	3

	Page
Figure 8.—Points for which precipitation-frequency data were computed.....	4
Figure 9.—Smoothing values read from isopluvial maps.....	5
Figure 10.—Depth-area curves.....	5
Figure 11.—Location of dense networks used to develop depth-area curves.....	5
Figure 12.—2-year 2-day precipitation (in.).....	6
Figure 13.—5-year 2-day precipitation (in.).....	7
Figure 14.—10-year 2-day precipitation (in.).....	8
Figure 15.—25-year 2-day precipitation (in.).....	9
Figure 16.—50-year 2-day precipitation (in.).....	10
Figure 17.—100-year 2-day precipitation (in.).....	11
Figure 18.—2-year 4-day precipitation (in.).....	12
Figure 19.—5-year 4-day precipitation (in.).....	13
Figure 20.—10-year 4-day precipitation (in.).....	14
Figure 21.—25-year 4-day precipitation (in.).....	15
Figure 22.—50-year 4-day precipitation (in.).....	16
Figure 23.—100-year 4-day precipitation (in.).....	17
Figure 24.—2-year 7-day precipitation (in.).....	18
Figure 25.—5-year 7-day precipitation (in.).....	19
Figure 26.—10-year 7-day precipitation (in.).....	20
Figure 27.—25-year 7-day precipitation (in.).....	21
Figure 28.—50-year 7-day precipitation (in.).....	22
Figure 29.—100-year 7-day precipitation (in.).....	23
Figure 30.—2-year 10-day precipitation (in.).....	24
Figure 31.—5-year 10-day precipitation (in.).....	25
Figure 32.—10-year 10-day precipitation (in.).....	26
Figure 33.—25-year 10-day precipitation (in.).....	27
Figure 34.—50-year 10-day precipitation (in.).....	28
Figure 35.—100-year 10-day precipitation (in.).....	29

Two- to Ten-Day Precipitation for Return Periods of 2 to 100 Years in the Contiguous United States

JOHN F. MILLER

Cooperative Studies Section, Office of Hydrology, U.S. Weather Bureau, Washington, D.C.

INTRODUCTION

The "Rainfall Frequency Atlas of the United States," [1] presents generalized estimates for durations from 30 minutes to 24 hours and return periods from 1 to 100 years. The present report is an extension of that work. In a series of maps and diagrams this report provides generalized estimates of the precipitation-frequency regime of the United States for durations from 2 to 10 days and for return periods from 2 to 100 years.

A relation for obtaining 10-day values from 1- and 24-hour data was developed and was applied to the 1- and 24-hour values of [1]. Two key maps, the 2-year and 100-year 10-day maps, were then constructed. These maps, together with two key maps from the Atlas, the 2-year and 100-year 24-hour, were used with generalized duration and return-period diagrams to provide estimates for a 3300-point grid for 22 additional maps.

BASIC DATA

Summarization of data.—First, daily data from 94 stations were summarized into sequences from 1 to 10 days. The stations (encircled dots in fig. 1) were so distributed geographically as to provide a good representation of the various precipitation regimes. Their data were the basis for the conversion factors for adjusting observational-day amounts to n -hour amounts and for the duration- and return-period—interpolation diagrams. One- and 10-day data were then summarized for 276 additional stations (plain dots in fig. 1). These data were used to supplement the data from the first group of 94 stations to develop the relation between 1- and 10-day amounts.

Period and length of record.—Data for the 94 stations in the first category were tabulated for the 50-year period, 1912–61, except for a few cases of missing or incomplete data. The average length of record available from all stations was 49 years. Data for the 276 stations in the second group were tabulated for the 20-year period, 1942–61. Breaks in record at a few stations necessitated tabulation of a few years of data prior to 1942 to obtain a 20-year record. In a few cases, 18 or 19 years of data were used when a 20-year record was not available. In no case, however, was less than 18 years of data used.

Station exposure.—In refined analysis of mean annual and mean seasonal rainfall data it is necessary to evaluate station exposures by methods such as double-mass-curve analysis [2]. Such methods are not appropriate for extreme values. Except for selection of stations that had had consistent exposures during the period of record used, no attempt has been made to adjust precipitation values to a standard exposure.




FIGURE 1.—Precipitation stations.

DURATION ANALYSIS

Observational-day vs. n-hour precipitation.—Since the basic data consisted mostly of observational-day amounts, relations had to be established between observational-day data and the corresponding n-hour amounts, i.e., the 2-observational-day to 48-hour, the 3-observational-day to 72-hour, etc. These relations are ratios of the mean of the annual series (see section on Frequency Analysis) of the n-hour precipitation to the mean of the annual series of the corresponding observational-day data. The adjustment factors are shown in table 1. The conversion factor between the observational-day and n-hour amounts is an average relationship. A graphical illustration of the quality of the relationships, based on data from 50 widely distributed stations, is shown in figure 2 for the 2-year 48-hour and 2-observational-day precipitation. Differences between amounts for the 48-hour and longer durations and the corresponding n-minute amounts are negligible.

TABLE 1.—Empirical factors for converting observational-day amounts to the corresponding n-hour amounts

Observational-day	Conversion factor to n-hour
2	1.04
3	1.03
4	1.03
5	1.02
6	1.02
7	1.02
8	1.02
9	1.01
10	1.01

Duration-interpolation diagram.—A generalized relationship was developed for estimating precipitation for any duration between 2 and 10 days for a selected return period when the 2- and 10-day amounts for that return period are given (fig. 3). This generalization was obtained empirically from data for the 94 stations. The duration-interpolation diagram was developed using data for the 2-year return period. To use this diagram, a straightedge is laid across the values given for 2 and 10 days, and the amounts for other durations are read at the proper intersections. The quality of this relationship is illustrated in figure 4 for the 96-hour duration and 2-year return period. Tests have shown negligible differences for other return periods. The inclusion of regional variation and other parameters produced no improvement.

FREQUENCY ANALYSIS

Two types of series.—Frequency analyses of precipitation data are based on one of two types of data series. The annual series consists only of the highest value for each year. The partial-duration series recognizes that the second highest of some year occasionally exceeds the highest of some other year, and utilizes all items above a base value which is selected to yield n-items for n-years. The highest value of record, of course, is the top value of either series, but the lower values in the partial-duration series tend to be higher than those of the annual series.

The purposes served by this publication require that the results be expressed in terms of partial-duration frequencies. In order to avoid laborious processing of partial-duration data, the annual series

TABLE 2.—Empirical factors for converting partial-duration series to annual series

Return period	Conversion factor
2-yr.	0.88
5-yr.	0.85
10-yr.	0.80




FIGURE 2.—Relation between 2-year 2-observational-day and 2-year 48-hour precipitation.

were collected, analyzed, and the resulting statistics transformed to partial-duration statistics. Consequently, the maps of figures 12 to 35 are, in effect, based on partial-duration series data. These data may be converted to annual series data by multiplying by the factors given in table 2, which is based on data from 25 widely scattered stations. The two types of data series show no appreciable differences for return periods greater than 10 years. These conversion factors are the same as those used in [1].

Frequency considerations.—Extreme values of rainfall depth form a frequency distribution which may be defined in terms of its statistical moments. Investigation of hundreds of rainfall distributions, with lengths of record ordinarily encountered in practice (usually less than 50 years) indicates that these records are too short to provide reliable statistics beyond the first and second moments. The distribution must therefore be regarded as a function of the first two moments. The 2-year value is a measure of the first moment—the central tendency of the distribution. The relationship of the 2-year to 100-year value is a measure of the second moment—the dispersion of the distribution.

Construction of return-period diagram.—The return-period diagram of figure 5 was obtained by the method described by Weiss [3]. If values for return periods between 2 and 100 years are read from the return-period diagram, then converted to annual series values by applying the factors of table 2 and plotted on either extreme or log-normal probability paper, the points will very nearly define a straight line.

Use of the return-period diagram.—The two intercepts needed for the frequency relation of figure 5 are the 2-year and 100-year values obtained from the maps of this report. Thus, given the 2- and 100-year return-period values for a particular duration, a straightedge is laid across these values on the diagram and the intermediate values are determined.

General applicability of return-period relationship.—Tests have shown that within the range of the data and the purpose of this paper, the return-period relationship is independent of duration. Comparison of this relationship with that developed for durations




FIGURE 3.—Duration-interpolation diagram.

less than 24 hours [1] has shown only negligible differences. Studies have not disclosed any regional pattern that would improve the relationship.

Secular trend.—The use of short-record data introduces the question of possible secular trend and biased sample. Routine tests with subsamples of equal size from different periods of record for each of several stations showed no appreciable trend, indicating that the direct use of short-record data is legitimate.

ISOPLUVIAL MAPS

Relation between 2-year 24- and 240-hour amounts.—Processing of hourly data for durations in excess of 24 hours is a laborious and costly task. For this reason, it was decided to estimate rather than compute 2- to 10-day rainfalls for the majority of the stations. Relationships, using in part data already available for the shorter




FIGURE 4.—Relation between 2-year 4-day precipitation computed by extreme value analysis and 2-year 4-day precipitation estimated from duration-interpolation diagram (fig. 3).




FIGURE 5.—Return-period interpolation diagram.




FIGURE 6.—Relation for estimating 2-year 10-day precipitation from 2-year 1- and 24-hour rainfall and latitude.

durations, were developed to estimate amounts for longer durations. Since satisfactory duration-interpolation and return-period diagrams were available, the 10-day duration was selected for development of such a relation. A total of 285 stations with hourly data provided the basic data. The parameters used to estimate the 2-year 10-day values were: (1) the 2-year 24-hour rainfall, (2) the 2-year 1-hour rainfall, and (3) latitude. The use of latitude as a parameter implies a smooth geographic variation with isopleths of departure of estimated from computed 2-year 10-day amounts parallel to the latitude circles. To test this hypothesis departures from the computed 2-year 10-day amounts were plotted on a map. The isopleths showed that, in general, there was an orderly latitudinal variation in these departures. In the development of this relationship (fig. 6) all 24- and 1-hour data were adjusted to the corresponding n -minute amounts. The 10-day values were adjusted to the corresponding 240-hour amounts.

Introduction of additional parameters in the relationship of figure 6 did not improve the results. Other parameters tested included elevation and mean annual number of days with precipitation greater than 0.49 in. The index of correlation between the computed and estimated amounts was 0.99, with a standard error of estimate of 0.53 in. The mean of the computed values was 5.31 in. The scatter of estimated vs. computed values is shown in figure 7.

Smoothing of isopluvial maps.—The analysis of a series of maps involves the question of how much to smooth the data. An understanding of the degree of smoothing in the analysis is necessary to the most effective use of the maps. The problem of drawing isopluvial lines through a field of data is analogous, in some important respects, to drawing regression lines on a scatter diagram. Just as an irregular regression line can be drawn to every point on a scatter diagram, so isopleths may be drawn to fit every point. Such a complicated pattern of many small highs and lows would be unrealistic in most cases. There is a degree of inconsistency between smoothness and

closeness of fit. Any analysis must strive for a balance between the two, sacrificing some closeness of fit for smoothness and vice versa. The maps of this report were drawn so that the standard error of estimate was commensurate with the sampling and other errors in the data and methods used.

2-year 10-day map (fig. 30).—The relationship (fig. 6) described in the preceding paragraphs, and the 2-year 1-hour and 2-year 24-hour maps of [1] were used to estimate the 2-year 10-day values for a grid of 3300 points (fig. 8). Also plotted on the map were the data for the 370 stations (fig. 1) for which 10-day data had been tabulated. On this and other similar maps all precipitation data have been adjusted by the factors of table 1 to n -hour amounts, i.e., the 2-day map presents 48-hour amounts, the 4-day presents 96-hour amounts, etc.

Ratio of 100-year to 2-year values.—A working map was prepared showing the 100-year to 2-year ratio for the 10-day amounts. A smooth geographical pattern was indicated. The ratio varied from about 1.8 to 3.0 with an average ratio about 2.2. The highest ratios were found in southern California and along the western slopes of the Sierra, with the lowest ratios in western Oregon and Washington.

100-year 10-day map (fig. 35).—The 100-year 10-day values were computed for the grid points of figure 8 by multiplying the values read from the 2-year 10-day map by those from the 100- to 2-year ratio map. As a further aid in the analysis of the isopluvial pattern, the 100-year 10-day values computed for the 370 stations for which data had been processed were also plotted, in addition to the grid points.

22 additional maps.—For the 22 intermediate maps required for this report, values were computed for the 3300 grid points (fig. 8). First, values were read from the 2-year 24-hour and 10-day maps and the 100-year 24-hour and 10-day maps. Then, the duration-interpolation diagram (fig. 3) and the return-period diagram (fig. 5) were used to compute amounts for the grid points. The frequency values




FIGURE 7.—Relation between 2-year 10-day precipitation computed by extreme value analysis and 2-year 10-day precipitation estimated from figure 6.

computed for stations for which data were processed were also plotted on each of the maps. Isolines were then drawn. Pronounced "high" and "low" are positioned in consistent locations on all the maps. The 24 precipitation-frequency maps are shown at the end of the text (figs. 12-35).

Reliability of results.—The term reliability is used here in the statistical sense to refer to the degree of confidence that can be placed in the accuracy of the results. The reliability is influenced by the accuracy of [1] and the accuracy of the relationships developed for this report. The accuracy of the results presented in [1] was dis-

cussed in that report. The reliability of the relationships developed may be partially assessed by reference to the various figures indicating a measure of their quality. The scatter of points in these diagrams is a result of sampling error in time and space. Sampling error in space is a result of: (1) the chance occurrence of an anomalous storm which has a disproportionate effect on the record at a station as compared with that of a nearby station, and (2) the use of station data that are not representative of the rainfall regime of the surrounding area. Similarly, sampling error in time results from the use of data for a given period that is not representative for a longer period.




FIGURE 8.—Points for which precipitation-frequency data were computed in deriving the 22 intermediate maps from the 4 key maps, the 2-year 24-hour and 10-day and the 100-year 24-hour and 10-day.

Isoline interval.—In general, a different isoline interval was used east and west of 105° W. longitude. Within each region a dashed intermediate line was added if the isopluvials were widely separated or if the spacing of isopluvials was nonlinear to minimize the errors of interpolation. Occasionally, along the slopes of the Sierras and Cascades of California, Washington, and Oregon, it was necessary to omit an isopluvial because of the extremely steep gradient. Lows that close within the boundaries of the United States have been hatched inwardly.

Smoothing values read from the maps.—The complex patterns and steep gradients of the isopluvials combined with the difficulties of interpolation and accurate location of a specific point on a series of maps might result in inconsistencies in data read from the maps. Such inconsistencies can be minimized by fitting smooth curves to a plot of the data obtained from the maps. Figure 9 illustrates two sets of curves on logarithmic paper, one for a point (a) 39° N., 90° W. and the other (b) at 40°30' N., 111°15' W. Data for the 24-hour

values for these curves have been taken from [1]. An alternative procedure would be to read these values from the duration-interpolation diagram (fig. 3).

In one plot in figure 9 the curve of best fit is a straight line, while in the other, a curve provides a better fit. In regions where the isopluvial pattern is relatively simple and exhibits flat gradients, minor differences in locating points have less effect on the interpolated values, and the plotted points will more clearly define a smooth set of curves. In mountainous regions complex patterns and steep gradients complicate interpolation, and the curves will be more poorly defined.

Interpolated values for a particular duration should define an almost straight line on the return-period diagram of figure 5. Also, the interpolated values for a particular return period should very nearly define a straight line on the duration-interpolation diagram of figure 3.

DEPTH-AREA RELATIONSHIPS

Introduction.—Any value read from an isopluvial map for a point is an average depth for the location, for a given return period and duration. The depth-area curve attempts to relate this average point value, for a given duration and frequency and within a given area, to the average depth over that area for the same duration and frequency. The curves of figure 10 depict the relationship for durations of 1 to 10 days and for areas up to 400 square miles, and are to be used in reducing the point values of precipitation shown on the maps of figures 12 to 35 to areal values.

Data used.—Data from 27 dense networks were used to develop the depth-area curves of figure 10. The networks, together with the total area, number of gages, number of subnetworks, and length of record are listed in table 3, and their locations are shown in figure 11. The average length of record used was 17 years. Only networks that had at least 10 years of record were considered. The

denser networks were subdivided to provide additional points for the smaller areas.

Determination of area of networks.—There is no completely satisfactory method for determining the size of the area for which the precipitation measured by a particular network may be considered to be representative. The size of the area represented by a network in this study was presumed to be equal to the area of the smallest circle encompassing the network. It should not be inferred, however, that such a circle actually delineates the shape and location of the "true" representative area.

Construction of the curves.—The annual series for the period of record for each network was tabulated for the 24- and 48-hour durations, and the 2-, 5-, 10-, 25-, 50-, and 100-year values were computed. The method of computation for the percentage reduction for each network was the same as that used in [4]. These percentage reductions were then plotted on a series of charts, one for each return period, and curves were fitted by eye. The curves for the various return periods were compared, and a mean curve was drawn for each duration. The individual curves drawn for the different return periods varied by no more than about 1 percent from the mean curve, indicating that there was no need for separate curves for each return period.

The 24-hour curve showed only negligible differences from that used in previous reports [1, 4], and it was therefore decided to use the curve originally developed for those reports. For durations longer than 48 hours "cross section" at several sizes of area were taken, and the percentages for the 1-, 24-, and 48-hour values were plotted on semilogarithmic paper. A smooth curve for each size of area was then drawn through these plotted points and extrapolated to 240 hours. Data for the longer durations for a few networks were then tabulated and used to check the extrapolation.

Geographic variation.—While the area-reduction curves of figure 10 are based on networks widely scattered throughout the country, there are many large regions not represented by a network (fig. 11). In the process of constructing the curves, the data from the different networks were closely examined in an attempt to detect regional variations. None was apparent. However, it should be kept in mind that the network sampling was not adequate for delineating regional variations and that the lack of any indication of such variation is not conclusive. Pending the availability of additional dense network data, the curves of figure 10 must be considered applicable to all parts of the country.

SEASONAL VARIATION

The basic data for the precipitation-frequency maps of figures 12 to 35 show seasonal trends. Some months may contribute most of the annual series or partial series data used in the frequency analyses, while other months may contribute little or nothing. Also, the months contributing most of the series data for the shorter durations, say, one or two days, may not be the same as those contributing most of the data for the longer durations, say, nine or ten days. *Technical Paper No. 40* [1] presented a series of seasonal probability charts for 1-, 6-, and 24-hour rainfall for the region east of the Rockies. None was presented for the mountainous region to the west because of the effects of local climatic and topographic influences.

Seasonal probability curves were not derived for this report because the relatively small number of stations providing the basic data precluded the delineation of the boundaries of areas of representativeness for seasonal probability curves. Data from many more stations would have been required to depict properly the regional variations of the seasonal probability curves. It appeared that their usefulness was not commensurate with the costs of collecting and processing the additional data required for their construction.





FIGURE 9.—Smoothing values read from isopluvial maps. Points are values read from maps of figures 12 to 35 for (A) 35°00' N., 90°00' W., and (B) 40°30' N., 111°15' W. The x's are values obtained from the maps of [1].




FIGURE 11.—Location of dense networks used to develop depth-area curves.

TABLE 3.—Dense network data

Network	Area (sq. mi.)	Total No. of gages	No. of Sub-networks	Length of record (years)
California 1	107	4	0	15
California 2	134	4	0	22
California 3	285	4	0	15
California 4	314	4	0	10
California 5	177	5	4	15
California 6	490	0	2	18
California 7	200	4	1	17
California 8	178	4	0	11
California 9	78	5	1	12
California 10	414	4	0	20
Connecticut 1	315	5	2	22
Florida 1	221	5	1	22
Georgia 1	345	4	2	15
Illinois 1	380	18	10	21
Iowa 1	63	9	7	21
Maryland 1	254	7	6	15
Missouri 1	66	5	2	14
Missouri 2	178	7	2	11
New Jersey 1	283	7	5	15
New Jersey 2	180	6	6	23
New York 1	253	4	1	18
New York 2	433	5	4	14
Ohio 1	78	4	1	19
Oregon 1	200	4	1	22
Oregon 2	330	5	0	17
Texas 1	242	4	0	19
Washington 1	380	4	0	12




FIGURE 10.—Depth-area curves.

REFERENCES

1. U.S. Weather Bureau, "Rainfall-Frequency Atlas of the United States," *Technical Paper No. 40*, May 1961, 115 pp.
2. M. A. Kohler, "Double-Mass Analysis for Testing the Consistency of Records and for Making Required Adjustments," *Bulletin of the American Meteorological Society*, vol. 30, No. 5, May 1949, pp. 188-189.
3. L. L. Welss, "A General Relation between Frequency and Duration of Precipitation," *Monthly Weather Review*, vol. 90, No. 3, Mar. 1962, pp. 87-88.
4. U.S. Weather Bureau, "Rainfall Intensity-Frequency Regime, Part II—Southeastern United States," *Technical Paper No. 29*, Mar. 1953, 51 pp.

2-YEAR 2-DAY PRECIPITATION (INCHES)




FIGURE 12.—2-year 2-day precipitation (in.).




FIGURE 13.—5-year 2-day precipitation (in.)




FIGURE 14.—10-year 2-day precipitation (in).




FIGURE 15.—25-year 2-day precipitation (in.).

50-YEAR 2-DAY PRECIPITATION (INCHES)




FIGURE 16.—50-year 2-day precipitation (in.).




FIGURE 17.—100-year 2-day precipitation (in.).




FIGURE 18.—2-year 4-day precipitation (in.).




FIGURE 19.—5-year 4-day precipitation (in.).

10-YEAR 4-DAY PRECIPITATION (INCHES)




FIGURE 20.—10-year 4-day precipitation (in.).




FIGURE 21.—25-year 4-day precipitation (in.).

50-YEAR 4-DAY PRECIPITATION (INCHES)




FIGURE 22.—50-year 4-day precipitation (in.).




FIGURE 23.—100-year 4-day precipitation (in.).

2-YEAR 7-DAY PRECIPITATION (INCHES)




FIGURE 24.—2-year 7-day precipitation (in.).




FIGURE 25.—5-year 7-day precipitation (in.).

10-YEAR 7-DAY PRECIPITATION (INCHES)




FIGURE 26.—10-year 7-day precipitation (in.).




FIGURE 27.—25-year 7-day precipitation (in.).

50-YEAR 7-DAY PRECIPITATION (INCHES)




FIGURE 28.—50-year 7-day precipitation (in.).




FIGURE 29.—100-year 7-day precipitation (in.).




FIGURE 30.—2-year 10-day precipitation (in.).




FIGURE 31.—5-year 10-day precipitation (in.).




FIGURE 32.—10-year 10-day precipitation (in.).




FIGURE 33.—25-year 10-day precipitation (in.).




FIGURE 34.—50-year 10-day precipitation (in.).




FIGURE 35.—100-year 10-day precipitation (in.).